

## ANIMAL PRODUCTION INSTITUTE

### ANNUAL SERVICE FIRE EQUIPMENT SERVICE FOR:

Main building, Ground Floor, First Floor, Second Floor, Dairy factory hall, Genetics unit, Poultry, Bleeding unit, Dairy factory, Analytical, Information centre, Technical services, Feed lot, Bull testing centre, Pig testing centre, Small stock, Farm section, Meat science abattoir, Nutrition germ-plasm, Gate1 & Gate2

### MAIN BUILDING GROUND FLOOR

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
36	Next to exit no 1	NAT FIRE	CO2	5KG	MARCH 2023	Hydrostatic test
37	Next to exit no 1	CHUBB	HOSE REEL	30M PVC	N/A	N/A
38	Passage	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
39	Passage	SAFE QUIP	HOSE REEL	30M	N/A	N/A
40	Passage	GMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
41	Next to exit 3	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
42	Next to exit 3	CHUBB	HOSE REEL	30M	N/A	N/A
43	Passage	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
44	Passage	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
45	Exit 5	CHUBB	HOSE REEL	30M PVC	N/A	N/A
46	Exit 5	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
47	Passage	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
48	Passage next to exit 4	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
49	Entrance next to Reception	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
50	Car Parking	SAFE QUIP	DCP/STP	9KG	MARCH 2025	Service
51	Car Parking	NATEX	DCP/STP	9KG	MARCH 2025	Service
52	Front main office	CHUBB	WATER	HYDRANT	N/A	N/A
53	Outside next to animal Genetics	CHUBB	DCP/STP	9KG	MARCH 2025	Service

## MAIN BUILDING FIRST FLOOR

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
18	Passage	SHAYA	DCP/STP	9KG	MARCH 2023	Service
19	Passage Next to exit	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
21	Passage	CHUBB	HOSE REEL	30M PVC	N/A	N/A
22	Passage next to hose	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
23	Next to tea room	SAFE QUIP	DCP/STP	4.5KG	MARCH 2025	Service
24	Next to lift	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
25	Exit 5	SHAYA	HOSE REEL	30M PVC	N/A	N/A
26	Exit 5	NAT FIRE	CO2	5KG	MARCH 2023	Hydrostatic test
27	Passage	SHAYA	DCP/STP	9KG	MARCH 2021	Service
28	Passage next to exit	CHUBB	HOSE REEL	30M PVC	N/A	N/A
29	Passage next to exit3	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
30	Passage next to exit3	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
31	Next to steps	SHAYA	HOSE REEL	30M PVC	N/A	Service
32	Next to steps	INTA	DCP/STP	4.5KG	MARCH 2025	Service
33	Next to steps	SAFE QUIP	CO2	2KG	MARCH 2023	Hydrostatic test
34	Next to exit 1	CHUBB	HOSE REEL	30M PVC	N/A	N/A
35	Next to exit 1	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT

## MAIN BUILDING SECOND FLOOR

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
1	Micro-biology	GUARD FIRE	CO2	2KG	MARCH 2029	Service
2	Micro-biology	MASTER GUARD	CO2	2KG	MARCH 2029	Service
3	Micro-biology	CIMA UMLILO	CO2	2KG	MARCH 2029	Service
4	Lab	SAFE QUIP	CO2	2KG	MARCH 2023	Hydrostatic test
5	Passage	CHUBB	HOSE REEL	30M PVC	N/A	Service
6	Passage	FIRE ALERT	CO2	2KG	MARCH 2023	Hydrostatic test
7	Passage	SAFE QUIP	CO2	2KG	MARCH 2029	Service
8	Auto clave room	SAFE QUIP	CO2	2KG	MARCH 2029	Service
9	Passage	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
10	Passage	NATEX	CO2	2KG	MARCH 2023	Hydrostatic test
11	Hot Lab	SAFE QUIP	CO2	2KG	MARCH 2023	Hydrostatic test
12	Fermentation Tech	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
13	Passage	SAFE QUIP	CO2	2KG	MARCH 2023	Hydrostatic test
14	Passage	CHUBB	HOSE REEL	30M PVC	N/A	Service
15	Passage	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service
16	Passage	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service
17	Lift room	SHAYA	DCP/STP	9KG	NEW FIRE EXTINGUISHER	Service

## DAIRY FACTORY (HORSE SHOE)

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
1	Stage(top)	CHUBB	CO2	2.27KG	MARCH 2023	Hydrostatic test
2	Inside Hall	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
3	Inside Hall	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
4	Inside Hall	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
5	Inside Hall	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
6	Inside Hall	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT

## GENETICS UNIT ANIMAL PRODUCTION

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
1	Reception	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
2	Office Block	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
3	Office Block	CHUBB	DCP/STP	9KG	MARCH 2025	REPLACEMENT
4	Office Block	CHUBB	DCP/STP	9KG	MARCH 2025	REPLACEMENT
5	Office Block	CHUBB	HOSE REEL	30M PVC	N/A	Service
6	Passage	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACMRNT
7	Passage next to lab	SHAYA	HOSE REEL	30M PVC	N/A	Service
8	Passage next to lab	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
9	Passage next to lab	CHUBB	DCP/STP	4.5KG	MARCH 2023	REPLACEMENT
10	Laboratory	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
11	Passage next to toile	SHAYA	DCP/STP	9KG	MARCH 2025	Service
12	Laboratory	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
13	Inside cabinet	CHUBB	DCP/STP	9KG	MARCH 2025	REPLACEMENT
14	Inside cabinet	CHUBB	DCP/STP	9kg	MARCH 2025	REPLACEMENT
15	Inside cabinet	SHAYA	DCP/STP	9kg	MARCH 2025	Service
16	Inside cabinet SUB	CHUBB	DCP/STP	9kg	MARCH 2025	REPLACEMENT
17	Inside cabinet SUB	SHAYA	DCP/STP	9kg	MARCH 2025	Service
18	Inside cabinet SUB	CHUBB	DCP/STP	9kg	MARCH 2025	REPLACEMENT
19	Back room next to park	SAFE QUIP	DCP/STP	4.5KG	MARCH 2025	Service
20	Main back parking	Safe quip	DCP/STP	9KG	MARCH 2025	Service
21	Main back parking	BLUE CRANE	DCP/STP	9KG	MARCH 2025	Service
22	Outside main office, inside cabinet	SAFE QUIP	DCP/STP	4.5KG	MARCH 2025	Service
23	Outside main office, inside cabinet	SAFE QUIP	DCP/STP	4.5KG	MARCH 2025	Service
62	Outside genetics office	CHUBB	HYDRANT	NORMAL	N/A	Service

## **POULTRY BREEDING UNIT**

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
1	Reception	NATEX	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
2	Battery dept	NATEX	CO2	5KG	MARCH 2023	Hydrostatic test
3	Poultry	SHAYA	DCP/STP	9KG	MARCH 2025	Service
4	Ashari	NATEX	CO2	2KG	MARCH 2023	Hydrostatic test
5	Poultry	NATEX	CO2	5KG	MARCH 2023	Hydrostatic test
6	Poultry inside, outside cabinet	CHUBB	DCP/STP	45KG	MARCH 2025	REPLACEMRNT

## **1.DAIRY FACTORY/ANALYTICAL/INFORMATION CENTRE**

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
24	Factory	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
25	Factory	NATEX	CO2	2KG	MARCH 2023	Hydrostatic test
26	Factory	SHAYA	DCP/STP	9KG	MARCH 2025	Service
27	Factory	NATEX	CO2	2KG	MARCH 2023	Hydrostatic test
	Factory	CHUBB	CO2	5KG	MARCH 2023	Hydrostatic test
	Factory	BLUE CRANE	DCP/STP	4.5KG	MARCH 2025	Service
	Factory	BLUE CRANE	DCP/STP	4.5KG	MARCH 2025	Service
23	Factory	CHUBB	CO2	5KG	MARCH 2029	Service
	Factory	SHAYA	CO2	2KG	MARCH 2025	Service
	Factory	GUADIAN FIRE	CO2	2KG	MARCH 2029	Service
	Factory	SHAYA	CO2	2KG	MARCH 2025	Service

## **2.DAIRY ANALYTICAL DEPARTMENT**

20	Passage	SAFE QUIP	CO2	5KG	MARCH 2023	Hydrostatic test
19	Passage	NATEX	CO2	5KG	MARCH 2023	Hydrostatic test
18	Passage	SHAYA	DCP/STP	9KG	MARCH 2023	Hydrostatic test
17	Room 61B	CHUBB	CO2	5KG	MARCH 2023	Hydrostatic test
16	Room 59	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
15	Analytical	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
14	Room 58	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
13	Passage	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
12	Room	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
11	Passage	CHUBB	CO2	5KG	MARCH 2029	Service

10	Room 56 LAB	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
9	Room 37	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
8	Passage	GUARDIAN	CO2	2KG	MARCH 2023	Hydrostatic test
7	Passage	SAFE QUIP	CO2	2KG	MARCH 2023	Hydrostatic test
6	Room 40	CIMA UMLILO	CO2	2KG	MARCH 2023	Hydrostatic test
5	Room	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test

### **DAIRY ANALYTICAL DEPARTMENT**

ITEM NO	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
4	Room 45	CIMA UMLILO	DCP/STP	2KG	MARCH 2023	Pressure test
3	Passage	CIMA UMLILO	CO2	2KG	MARCH 2023	Pressure test
2	Room	CIMA UMLILO	CO2	2KG	MARCH 2023	Pressure test
1	Room	CIMA UMLILO	DCP/STP	4.5KG	MARCH 2025	Service

### **3.INFORMATION CENTRE**

16	Last Room	Safe quip	CO2	2KG	MARCH 2023	Hydrostatic test
	Entrance	SAFE QUIP	CO2	5KG	MARCH 2023	Hydrostatic test
	Passage	SAFE QUIP	CO2	5KG	MARCH 2023	Hydrostatic test
19	Room 23	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
	Entrance	GUARDIAN	CO2	2KG	MARCH 2023	Hydrostatic test
	Passage	CHUBB	CO2	5KG	MARCH 2023	Hydrostatic test
	Passage	GUARDIAN	CO2	2KG	MARCH 2025	Hydrostatic test
	Office passage	GUARDIAN	CO2	2KG	MARCH 2023	Hydrostatic test
	Passage	SAFE QUIP	CO2	5KG	MARCH 2023	Hydrostatic test

### **4.TECHNICAL SERVICES**

	At the back	CHUBB	HYDRANT	NORMAL	N/A	N/A
	At the back	CHUBB	HYDRANT	NORMAL	N/A	N/A
39	At the back	NATEX	DCP/STP	9KG	MARCH 2025	Service
	Workshop	FLASH	DCP/STP	9KG	MARCH 2025	Service
	Office	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
36	Office	NATEX	CO2	5KG	MARCH 2023	Hydrostatic test
	Sub-station	NATEX	CO2	5KG	MARCH 2025	Hydrostatic test
	Sub-station	CHUBB	DCP/STP	9KG	MARCH 2025	Service

	Technical	NATEX	DCP/STP	9KG	MARCH 2025	Service
	Technical	NATEX	DCP/STP	9KG	MARCH 2025	Service

### **5.FEEDING LOT**

	Feeding lot	SAFE QUIP	DCP/STP	4.5KG	MARCH 2025	Service
	Feeding lot	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Feeding lot	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Feeding lot	CHUBB	HYDRANT	NORMAL	N/A	N/A

### **BULL TESTING CENTRE**

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
1	Office	NATEX	CO2	2KG	MARCH 2023	Hydrostatic test
2	Office	CHUBB	CO2	5KG	MARCH 2023	Hydrostatic test
3	Car Parking	CHUBB	DCP/STP	9KG	MARCH 2025	Service
4	Bull Testing	SAFE QUIP	DCP/STP	9KG	MARCH 2025	Service
5	Bull Testing	CHUBB	DCP/STP	9KG	MARCH 2025	Service
6	Bull Testing	CHUBB	DCP/STP	2.5KG	MARCH 2025	Service
7	Bull Testing	SAFE QUIP	DCP/STP	9KG	MARCH 2025	Service
	Bull Testing	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Bull Testing	CHUBB	HYDRANT	NORMAL	N/A	N/A
	Bull Testing	SAFE QUIP	HYDRANT	NORMAL	NEW HYDRANT	Service

### **PIG TESTING CENTRE**

6	Pig Testing Centre	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service
4	Pig Testing Centre	CHUBB	HOSE REEL	30M PVC	N/A	N/A
3	Pig Testing Centre	SHAYA	DCP/STP	9KG	MARCH 2025	Service
	Pig Testing Centre	CHUBB	HYDRANT	NORMAL	N/A	N/A
	Pig Testing Centre	CHUBB	HYDRANT	NORMAL	N/A	N/A
	Pig Testing Centre	CHUBB	HOSE REEL	30M PVC	N/A	N/A
	Pig Testing Centre	CHUBB	HOSE REEL	30M PVC	N/A	N/A
	Pig Testing Centre	CHUBB	CO2	5KG	MARCH 2023	Hydrostatic test
	Pig Testing Centre	SAFE QUIP	DCP/STP	9KG	MARCH 2025	Service
	Pig Testing Centre	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service

### **SMALL STOCK UNIT**

1	Small Stock Unit	CHUBB	DCP/STP	9KG	MARCH 2025	Service
2	Small Stock Unit	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
3	Small Stock Unit	CHUBB	DCP/STP	9KG	MARCH 2025	Service
4	Small Stock Unit	CHUBB	DCP/STP	9KG	MARCH 2025	Service
5	Small Stock Unit	SHAYA	DCP/STP	9KG	MARCH 2025	Service
6	Small Stock Unit	CHUBB	CO2	2KG	MARCH 2023	Hydrostatic test
7	Small Stock Unit	CHUBB	DCP/STP	9KG	MARCH 2025	Service
8	Small stock Unit	CHUBB	CO2	2.27KG	MARCH 2023	Hydrostatic test 0
	Small Stock Unit	CHUBB	CO2	2KG	MARCH 200	Hydrostatic test
	Small Stock Unit	SAFE QUIP	HYDRANT	NORMAL	N/A	N/a

### **GERM PLASM**

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
4	Office Entrance	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
5	Office	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
8	Next to toilets	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
6	Office passage	MASTER GUARD	CO2	2KG	MARCH 2023	Hydrostatic test
	Passage	CENTA	DCP/STP	9KG	MARCH 2025	Service
	Passage	SHAYA	DCP/STP	9KG	MARCH 2025	Service
	Front Office	WOODLAND	HYDRANT	NORMAL	N/A	N/A
	Front Office	CHUBB	HOSE REEL	30M PVC	N/A	N/A

### **DAIRY PALOUR BUILDING**

2	Office	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
	Office	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
	Office Passage	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
1	Dairy Parlour	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service
	Dairy Parlour	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Dairy Parlour	CHUBB	HYDRANT	NORMAL	N/A	N/A



## **FARM SECTION**

	Diesel Tank	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
	Farm Section	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
	Office	CHUBB	CO2	5KG	MARCH 2023	Hydrostatic test
	Outside Building	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Office Block	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Inside Cabinet	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service
	Outside Passage	SHAYA	DCP/STP	9KG	MARCH 2025	Service
	Outside Building	WOODLAND	HYDRANT	NORMAL	N/A	N/A
	Under Tree	WOODLAND	HYDRANT	NORMAL	N/A	N/A
	Outside Passage	CHUBB	DCP/STP	9KG	MARCH 2025	Service

## **MEAT SCIENCE ABATTOIR**

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
41	Abattoir	CHUBB	DCP/STP	9KG	MARCH 2025	Service
42	Abattoir	CHUBB	DCP/STP	9KG	MARCH 2025	Service
43	Braai place	NATEX	Co2	5KG	MARCH 2023	Hydrostatic test
44	Braai place	SHAYA	DCP/STP	9KG	MARCH 2025	Service
46	Car park inside Cabi	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Abattoir outside	CHUBB	HOSE REEL	30M PVC	N/A	N/A
9	Factory Abattoir	CHUBB	CO2	2.27	MARCH 2023	Hydrostatic test
	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	
38	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
15	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
26	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
23	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
24	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
36	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
29	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
25	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
5	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
22	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
3	Factory Abattoir	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
39	Factory Abattoir	SHAYA	CO2	5KG	MARCH 2023	Hydrostatic test 0

	Factory Abattoir	BLUE CRANE	DCP/STP	4.5KG	MARCH 2025	Service
	Factory Abattoir	BLUE CRANE	DCP/STP	4.5KG	MARCH 2025	Service
15	Factory Abattoir	CHUBB	DCP/STP	4.5KG	MARCH 2025	Service
	Factory Abattoir	BLUE CRANE	DCP/STP	4.5KG	MARCH 2025	Service
8	Factory Abattoir	BLUE CRANE	DCP/STP	4.5KG	MARCH 2025	Service
20	Factory Abattoir	BLUE CRANE	DCP/STP	9KG	MARCH 2025	Service

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
6	Abattoir Factory	SHAYA	DCP/STP	9KG	MARCH 2025	Service
12	Abattoir Factory	CHUBB	HOSE REEL	30M PVC	N/A	N/A
14	Abattoir Factory	CHUBB	HOSE REEL	30M PVC	N/A	N/A
21	Abattoir Factory	CHUBB	HOSE REEL	30M PVC	N/A	N/A
31	Abattoir Factory	CHUBB	HOSE REEL	30M PVC	N/A	N/A
40	Abattoir Factory	CHUBB	HOSE REEL	30M PVC	N/A	N/A
4	Abattoir Factory	CHUBB	HOSE REEL	30M PVC	N/A	N/A
57	Abattoir Factory	SHAYA	DCP/STP	9KG	MARCH 2025	Service

**NEW ISTALLATION AT ABATTOIR MEAT SCIENCE**

2	Reception main entrance	SAFE QUIP	DCP/STP	4.5KG	MARCH 2025	NEW INSTALLATION
	Abattoir at the back	SAFEQUIP	DCP/STP	9KG	MARCH 2025	NEW INSTALLATION
	Gas, Lucifer/transformer	SAFEQUIP	DCP/STP	9KG	MARCH 2025	NEW INSTALLATION
	Substation	SAFEQUIP	CO2	5KG	MARCH 2030	NEW INSTALLATION

## **NUTRITION**

NO OF EQUIPMENTS	LOCATION	MANUFACTURE	TYPE OF EXTINGUISHERS	SIZE OF EXTINGUISHERS	PRESSURE/HYDROSTATIC DUE DATE	RECOMMENDATION
1	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
2	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
3	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
4	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
5	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
11	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
8	Office Block	SHAYA	DCP/STP	9KG	MARCH 2025	Service
9	Office Block	SHAYA	CO2	2KG	MARCH 2023	Hydrostatic test
10	Office Block	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
	Office Block	CHUBB	DCP/STP	4.5KG	MARCH 2025	REPLACEMENT
3	Office Block	CHUBB	HOSE REEL	30M PVC	N/A	N/A
	Office Block	CHUBB	HOSE REEL	30M PVC	N/A	N/A
NEW		SAFE QUIP	DCP/STP	9KG	MARCH 2025 (NEW)	NEW INSTALLATION
	Gate 1	CHUBB	DCP/STP	9KG	MARCH 2025	Service
	Gate 2	CHUBB	DCP/STP	9KG	MARCH 2025	Service

**New extras:**

**1kg DCP X 8**

**2.5kg DCP X 4**