

The Tenderers

Date:
19 June 2026

Enquiries:
DeaneNK@eskom.co.za
Tel No: +27 13 297 9565

Dear Sir/Madam

ENQUIRY NUMBER: E2949GXMPARN

Arnot AGC and Generator Plant RTU Upgrade for a period of 18 Months.

TENDER ADDENDA NO.2:

QUESTION 1:

Please confirm the total number of existing signals associated with the AGC RTU, Generator Plant A RTU, and Generator Plant B RTU, and provide a detailed I/O breakdown (analogue inputs, digital inputs, digital outputs, and status signals) as per the existing RTU database, to enable accurate sizing and design of the replacement RTUs.

References: C3.2 ECC3 CONTRACTOR'S WORKS INFORMATION, Section 3.2.3 – Basic RTU Functions, Pages 11–12

C3.2 ECC3 CONTRACTOR'S WORKS INFORMATION, Section 3.2.6.6.1 – Interface to Hitachi Energy MicroSCADA, Pages 27–28

ANSWER: Please find the attached database (Arnot AGC 001 Database for SCASS) with the signal breakdown of all three RTUs. Attached is also a high-level drawing indicating the connection between the RTUs and MicroSCADA.

QUESTION 2:

Please confirm which signals in the existing system are hardwired, specifically identifying:

Field signals between plant (IDF/marshalling) and RTUs

Signals between the AGC RTU and ABB P14 DCS

Any additional hardwired interfaces within the RTU control system

Furthermore, please confirm whether all such hardwired interfaces are required to remain unchanged as part of the RTU replacement scope.

Reference: C3.2 ECC3 CONTRACTOR'S WORKS INFORMATION, Section 3.2.6.4 – Field Equipment and Cabling Requirements, Pages 22–24.

C3.2 ECC3 CONTRACTOR'S WORKS INFORMATION, Section 3.2.6.6.2 – Interface to ABB P14 DCS, Page 28.

ANSWER: All signals from the field (IDF) to the RTUs and the DCS are hardwired and they shall remain hardwired as part of the RTU Replacement Scope.

NOTE: EXTENSION OF ENQUIRY CLOSING DATE

PLEASE NOTE THAT THE TENDER CLOSING DATE OF 10 JUNE 2026 @10:00AM HAS BEEN EXTENDED TO A NEW TENDER CLOSING DATE OF 30 JUNE 2026@10:00AM.

PLEASE NOTE THAT THE NEW ENQUIRY CLOSING DATE SUPERSEDE INITIAL CLOSING DATE STIPULATED ON THE ENQUIRY DOCUMENTS UPLOADED ON NATIONAL TREASURY E-TENDER PORTAL AND ESKOM TENDER BULLETIN.

NOTE: THE BOQ NUMBER OF MONTHS HAS BEEN CORRECTED TO 18.

PLEASE NOTE THAT OTHER TERMS AND CONDITIONS OF TENDERING REMAIN UNALTERED.

Generation

Division Arnot

Power Station

N4 Nelspruit

Road

Private Bag X2 Rietkuil 1097 SA

Tel +27 13 297 9565 Fax +27 13 297 9142 www.eskom.co.za

Eskom Holdings SOC Limited Reg No 2002/015527/30