

ADDENDUM

Please find below further questions re your responses:

1. Does the 132kV lines have OPGW stringed between the support structure?. *No*
2. Can you Indicate which of the 11kV lines are buried cable, ABC conductor or overhead lines?. *All overhead*