



COMMISSIONING CERTIFICATE

Certificate of commissioning for the fire alarm system at:

Address: CAPE INTERNATIONAL AIRPORT
CBL

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the installation of the fire alarm system, particulars of which are set out below, CERTIFY that the said installation for which I/we have been responsible complies to the best of my/our knowledge and belief with the specification described below and with the recommendations of clause 10 of SANS 10139:2007, except for the variations, if any, stated in this certificate.

Name (in block letters): MOGAMAT KENNY Position: TECHNICIAN

Signature: [Signature] Date: 14/02/2019

For and on behalf of: NEXTEC

Address: 4 MILNER ROAD PAARDEN ISLAND

CAPE TOWN Postcode: 7446

The extent of liability of the signatory is limited to the system described below.

Extent of system covered by this certificate:

L1 SYSTEM

Variations from the recommendations of 11.1 of SANS 10139:2007 (see SANS 10139:2007 clause 7):

- ☒ All equipment operates correctly.
- ☒ Installation work is, as far as can reasonably be ascertained, of an acceptable standard.
- ☒ The entire system has been inspected and tested in accordance with the recommendations of 11.1.2(c) of SANS 10139:2007.
- ☒ The system performs as required by the specification prepared by: a copy of which I/we have been given.
- ☒ Taking into account the guidance contained in clause 9 of SANS 10139:2007, I/we have not identified any obvious potential for an unacceptable rate of false alarms.
- ☒ The documentation described in 11.2 of SANS 10139:2007 has been provided to the user.

The following work should be completed before/after (delete as applicable) the system becomes operational:

NONE

The following potential causes of false alarms should be considered at the time of the next service visit:

NONE

Before the system becomes operational, it should be soak tested in accordance with the recommendations of 9.6.2.6 of SANS 10139:2007 for a period of: (Enter a period of either one week, such period as required by the specification, or such period as recommended by the signatory to this certificate, whichever is the greatest, or delete if not applicable.)