



- LEGEND**
- INNER FENCE 2.4m HIGH 0.54/5633 SHT.1-7
 - - - NON-LETHAL FENCE BY OTHER
 - NEW HIGH SECURITY FENCE 2.4m HIGH
 - PIPE OUTLET 600mm
 - RETAINING WALL
 - 4m DOUBLE LEAF GATE 0.54/398 SHT 2
 - 3m ACCESS GATE

- NOTES**
1. ALL SHRUBS AND BUSHES TO BE REMOVED. NO GRASS COVERING TO BE REMOVED - BUT TO BE CUT.
 2. NEW WINDFALLS AS PER DTL 0.54/290 SHT 13a. NO ANTI-INTRUSION GRID REQUIRED.
 3. NEW BRICK RETAINING WALL 5m LONG AS PER DTL 0.54/290 SHT 13a.
 4. EXISTING BROWN POLES TO BE REMOVED. MAKE PROVISION FOR 3 x 10m GATES ON INNER FENCE POSITION TO BE INDICATED ON SITE.
 5. ANTI-TUNNELING TO BE INSTALLED UNDER HIGH SECURITY FENCE.
 6. ACCESS CONTROL BUILDING TO BE REFURBISHED SEE DTL 0.08/7956 (FUTURE)
 7. SEE DTL 0.08/19022 FOR LIGHTING ON SUBSTATION PERIMETER (FUTURE)
 8. OUTER SECURITY FENCE INSTALLATION TO BE ADDED IN THIS SCOPE AS PER SPECIFICATION NO. 240-70368574.
 9. INNER FENCE GATE CHANGED TO 0.54/8729 SHT.1-3.

**FINAL DESIGN
FOR CONSTRUCTION**

REV	REVISION DESCRIPTION	DRAWN	CHECKED	AUTH	DATE	REFERENCE DRAWINGS
APPROVED BY	<div><div></div><div>Eskom Holdings SOC Ltd Reg No 2002/015527/30</div></div>					
DATE	APOLLO NSP					
CHECKED BY	SECURITY FENCE UPGRADE LAYOUT AND DETAILS					
DATE	AP017P14-SE-E42					
DRAWN BY	PAXA DOYLE					
DATE	13/07/2023					
SCALE	AS SHOWN					
SHEET NUMBER						REVISION
0						0