

Technical Specification for Link Sticks.

Link Stick Specification:

- 1. Insulated Solid Link Stick for Testing Only:** Diameter of 32mm and overall length of 10m. (5x2m Sections)
- 2. Insulated Pentagonal Telescopic Link Stick:** Full extension length of 9m.

The units must conform to International test requirements ASTM D149 which is the 100kv/30cm dielectric withstand test & mechanical requirements in ASTM D711, & ASTM F1826, and in accordance with IEC 855.