

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

To whom it may concern	Date	01 October 2025
	Enquiries	Tintswalo Pataka
	E-mail address	PatakaT@eskom.co.za

Dear Sir/Madam

Request for Enquiry Number	E1819GXMPARN
Description / Project Title	Supply and delivery of Plater shop and Machine shop spares at Arnot Power Station as and when required for a period of five (5) years
Tender Questions Closing Date	10 working days before deadline for tender submission

Item	Questions	Answers	Clarity Published Dates
1.	Kindly supply the Drawings required (circled in RED below in order for us to tender on this RFQ please.	Attached as drawing 13.41_990 and 13.41_993	01 October 2025

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

ESKOM HOLDINGS SOC Ltd
 CONTRACT TITLE: SUPPLY AND DELIVERY OF PLATER SHOP AND MACHINE SHOP SPARES AS AND WHEN REQUIRED AT
 ARNOT POWER STATION FOR A PERIOD OF FIVE (5) YEARS

CONTRACT NO. _____

Item No.	Description	Unit	Quantity	Rate	Price
10	A A  ... TYPE: PLATE; DIMENSIONS: WD 370 MM X LG 1.5 M; MATERIAL: BENNOX GR 43A BS 4360; DRAWING NO: ROSHERVILLE 13-41-993 REV 1; LOWER RING; TOLERANCE ON SIZES 3MM; TO BE ROLLED ACCORDING TO ROSHERVILLE DRAWING; FOR LOESCHE LM18 MILL BODY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	EA	100		
11	CHUTE: TYPE: REJECT RH; DIMENSIONS: WD 370 MM X LG 1.5 M; MATERIAL: STL; DRAWING NO: 13.41/990 REV 1; REJECT CHUTE WITH SLIDING DOOR.; PLATE TO BS4360 GR43A, BAR TO BS970 PT1 (1983) GRADE 070M20, WELD PROCEDURE TO BS4870, FOR USE ON LOESCHE MILL LM18; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	EA	10		
12	CHUTE: TYPE: REJECT LH; DIMENSIONS: WD 420 MM X LG 1.43 M; MATERIAL: STL; DRAWING NO: 13.41/990 REV 1; REJECT SHUTE WITH SLIDING DOOR, PLATE TO BS 4360 GR43A, BAR MATERIAL: TO BS970 PT1(1983) GRADE 070M20, WELD PROCEDURE TO BS4870, FOR USE ON LOESCHE MILL LM18; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	EA	20		

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30