



1. TRENCHES FOR CABLE RUN SHALL BE TO A MINIMUM DEPTH OF 1000mm OR DEPTH OF THE PIPE, UNLESS OTHERWISE SPECIFIED BY THE ENGINEER;
2. ANY PAVING, ROADS, DAMAGE TO FOREIGN SERVICES ETC. SHALL BE REINSTATED BY THE CONTRACTOR TO ORIGINAL CONDITIONAL TO THE APPROVAL OF THE OWNER;
3. COMPACTION TO BE AS PER DRG No. RA27141 OR AS PER THE ENGINEER'S INSTRUCTION;
4. THE CATHODIC PROTECTION DRAWINGS MUST BE READ IN CONJUNCTION WITH THE APPLICABLE PIPELINE PLAN AND SECTIONS;

 **RAND WATER**

BOX 1127
JOHANNESBURG
2000
TEL: 011-682-0911

© RAND WATER 2004 All Rights Reserved

RAND WATER
STANDARD DRAWING

CATHODIC PROTECTION TYPICAL CABLE TRENCH

SCALE : AS SHOWN

DRG No. RA_27376