# NALA LOCAL MUNICIPALITY

CONTRACT No. NLM/TS/004/2025-26

# THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON

# TENDER DRAWINGS



Nala Local Municipality Private Bag X15 Bothaville 9660

Tel: 053 998 4455

Contact Person: Mr. IJ Mokotedi Email: my1wa@yahoo.com





BVi Consulting Engineers (Central) 17 President Steyn Avenue Westdene 9301


Tel: 051 447 2137


Contact Person: Mr. JL Reynders

Email: janr@bvi.co.za











# PIPE STORAGE GUIDELINES N.T.S.

- PIPE STORAGE


  PIPES SHOULD BE STORED ON LEVEL, FLAT GROUND, FREE OF STONES OR SHARP PROTRUSIONS. ALTERNATIVELY, PIPES MAY BE STORED ON TIMBER SUPPORTS OF AT LEAST 76x76mm WIDTH, PLACED MAX. 1.5m APART, WITH SIDE SUPPORTS (±5 SUPPORTS
- PER 6.0m LENGTH). ALL PIPE STACKS AND STORED FITTINGS SHOULD BE COVERED TO AVOID PROLONGED EXPOSURE TO DIRECT SUNLIGHT. WHERE THE PIPES ARE FITTED WITH AN INTEGRAL SOCKET, THEY SHOULD BE
- STACKED WITH SOCKETS PROTRUDING AT ALTERNATE ENDS. ALL PLASTIC PIPES MUST BE COVERED WITH UV-RESISTANT SHADE CLOTH OR TARPS DURING STORAGE TO PREVENT SUN EXPOSURE AND HEAT DISTORTION. ENSURE THAT COVERS ALLOW FOR ADEQUATE VENTILATION TO AVOID MOISTURE BUILDUP. PIPES SHOULD BE SECURELY STORED ON RACKS OR SIMILAR STRUCTURES TO MAINTAIN STABILITY.

PIPE DIAMETER         MAX. NO. OF ROWS STACKED           200mm OR LESS         5           300 TO 530mm         4           600 TO 760mm         3           840 TO 1220mm         2	STORAGE STACKS			
300 TO 530mm 4 600 TO 760mm 3	PIPE DIAMETER			
600 TO 760mm 3	200mm OR LESS	5		
	300 TO 530mm	4		
840 TO 1220mm 2	600 TO 760mm	3		
	840 TO 1220mm	2		







NOTES:



**DETAIL 1 DRAWING RACK** SCALE 1:25





NOTES / LEGEND

DATE INITIAL NO./CODE REVISION DESCRIPTION

COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS



egistration no. 1998/000185/07 Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137





NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON


DRAWING TITLE


TYPICAL SITE CAMP LAYOUT


	APPROVE	ED BY BVi			
JL REYNDER	s	2020300701	20/	10/2025	
ENGINEER/TECHNOLOGIST REG. NO. DATE					
SCALE	SCALE AS SHOWN @ A1 DRAWN DJ COETZEE			ZEE	
DESIGNED	DJ COETZEE	CHECKED	JL REYNDERS		
	SUITABILITY ST	ATUS		REV. NO.	
ISSUED FOR TENDER					
PLAN NUMBER					
PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.					
35431-BCN-ZZZ-00-DR-CIV-003-TS-001					





















# DETAIL F1: BEDDING FOR FLEXIBLE SEWER PIPES

SCALE 1:15




**DETAIL U1: UNDERDRAIN BEDDING** 

SCALE 1:15

BACKFILL FROM EXCAVATED MATERIAL COMPACTED TO 95% MOD. AASHTO DENSITY (TO COMPLY WITH SABS 1200 DB) BACKFILL OF GRANULAR MATERIAL, COMPACTED TO 93% MOD. AASHTO DENSITY D = DIAMETER X = MINIMUM OF 100mm CONCRETE ENCASING (CLASS 20/19) PRECAST CONCRETE BLOCK V-SHAPED ON COMPRESSIBLE MATERIAL UPPER SURFACE (AID TO ALIGNMENT ONLY) (SOFTBOARD OR SIMILAR)

DETAIL E1: **EROSION DITCH CROSSING** 

SCALE 1:15



DETAIL F2: BEDDING FOR POOR NATIVE SOIL **FOUNDING CONDITIONS** 

SCALE 1:15


MAIN FILL FROM EXCAVATED MATERIAL COMPACTED TO 93% MOD. AASHTO DENSITY IN ROAD RESERVES (TO COMPLY WITH SABS 1200 DB) ADDITIONAL U24 BIDIM RAP AROUND BEDDING IN COHESIVE NATIVE SOIL CONDITIONS OR AS SELECTED FILL BLANKET OF SELECTED GRANULAR INSTRUCTED BY THE ENGINEER MATERIAL, COMPLYING TO 3.2 AND COMPACTED TO 90% MOD AASHTO (SABS 1200 LB) TRENCH SUPPORT (IF ANY) VOLUME OF PIPE TO BE DEDUCTED IF D > 200 -BEDDING CRADLE OF SELECTED -GRANULAR MATERIAL, COMPLYING TO 3.1 AND COMPACTED TO 90% MOD. AASHTO DENSITY. (SABS 1200 LB COMPACTION FRACTION FROM 0.0 TO 0.25) 20-50mm LOOSE SANDY MATERIAL TO -BED RIGID OR FLEXIBLE SEWER PIPE U24 BIDDEM RAP AROUND BEDDING -AND OVERLAP BY MIN 300mm MIN 200 MAIN FILL 19mm CRUSHED -STONE PLACED & COMPACTED LEVEL REQUIRED TO OBTAIN SPECIFIED -BEDDING CRADLE THICKNESS 450mm HARD FILL PIONEER LAYER (DUMP ROCK)-WITH 100mm MAX. AGGREGATE SIZE. TO BE COMPACTED WITH A VIBRATING ROLLER UNTIL SETTLEMENT OF <10MM IS ACHIEVED

**DETAIL F3:** BEDDING FOR POOR NATIVE SOIL FOUNDING CONDITIONS: PIPES LOCATED BELOW THE WATER TABLE / IN WATERCOURSES


THE SURFACE TO BE REPLACED SHALL BE EQUAL TO AND SHALL MATCH THE EXISTING ROAD / GROUND SURFACE COMPACTED AND STABILISED WITH 2.5% CEMENT TO A MINIMUM DENSITY OF 93% MOD. AASTHO, IN ROAD CROSSINGS OR AS SPECIFIED BY THE ENGINEER MAIN FILL FROM EXCAVATED MATERIAL COMPACTED TO 93% MOD. AASHTO DENSITY IN ROAD CONCRETE ENCASING RESERVES (CLASS 20/19) D = DIAMETER X = MINIMUM OF 125mm PRECAST CONCRETE BLOCK V-SHAPED ON – UPPER SURFACE (AID TO ALIGNMENT ONLY) COMPRESSIBLE MATERIAL (SOFTBOARD OR SIMILAR)

DETAIL C1: CONCRETE ENCASEMENT / ROAD CROSSING: COVER < 450mm

SCALE 1:15



SCALE 1:15




DETAIL C3: ROAD CROSSING: COVER > 800mm

SCALE 1:15

THE ROAD SURFACE TO BE REPLACED SHALL BE EQUAL TO AND SHALL MATCH THE EXISTING ROAD SURFACE SUB-BASE SELECTED LAYER - MIN. CBR 15% UPPER SUBGRADE MIN. CBR 7% LOWER SUBGRADE CONCRETE CRADLE -D = DIAMETER (CLASS 15/19) X = MINIMUM OF 100mm PRECAST CONCRETE BLOCK V-SHAPED ON — COMPRESSIBLE MATERIAL (SOFTBOARD OR SIMILAR)

**DETAIL C2:** ROAD CROSSING: COVER 450 - 800mm

SCALE 1:15



CITY E	NGINE	ER / CLIEN	ΙΤ	REG. I	NO.	DATE
F	REVISIO	V CODES		su	ITABILITY C	ODES
T0, T1, T2. 0, 1, 2	:	BEFORE TENI FOR TENDER CONSTRUCTI AS-BUILT		FAC : FOI	FORMATION NCE CONTROL EVIEW ONSTRUCTION	
		E	RAWING	REVISION		
DATE	INITIAL	NO./CODE		REVISION DESCRIPTION		
		HEREOF MAY	OCCUR	T AND NO USE WITHOUT THE IG ENGINEERS	WRITTEN CO	

APPROVED BY COUNCIL / CLIENT



gistration no. 1998/000185/07 isit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137





NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON


DRAWING TITLE

TYPICAL SEWER TRENCH DETAILS

APPROVED BY BVi JL REYNDERS 2020300701 20/10/2025 DATE ENGINEER/TECHNOLOGIST REG. NO. AS SHOWN @ A1 DJ COETZEE SCALE DRAWN DJ COETZEE CHECKED JL REYNDERS SUITABILITY STATUS REV. NO T0 **ISSUED FOR TENDER** PROJECT NO. - ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO. 35431-BCN-ZZZ-00-DR-CIV-133-TS-001








SCALE 1:25


SECTION ELEVATION ALONG


**CENTER OF INTERNAL SEWER** 

SCALE 1:25

150mm THICK CONCRETE FLOOR SLAB (CLASS 25/19) FOR MANHOLES UP TO 3.0m DEEP










- a) CUT 100mm dia. HOLE THROUGH EXISTING PIPE. SPECIAL CARE MUST BE TAKEN TO PREVENT DEBRIS FROM FALLING INTO THE EXISTING PIPE.
- b) FIX SADDLE TO EXISTING PIPE WITH PROSTRUCT 617 EPOXY, OR OTHER SIMILAR APPROVED + STRAPPING
- 110 mm dia. JUNCTION TO HOUSE CONNECTION D = DIAMETER OF EXISTING

FIXING DETAILS OF SADDLE ON **EXISTING MAIN SEWER** 




PAINT MARKER ON COVER SLAB OF MAIN SEWER

SCALE 1:10

**DETAIL M3:** 

TYPICAL PLAN VIEW OF A GRIT-TRAP MANHOLE SCALE 1:25




R	RECOMMENDED MANHOLE SIZES						
MANHOLE SIZE	MANHOLE SIZE RECOMMENDED PIPE SIZE RANGE						
1000mm Ø	100 - 350mm	UP TO 2.0m					
1200mm Ø	350 - 500mm	2.1 - 3.0m					
1500mm Ø	500 - 800mm	3.1 - 4.0m					
1800mm Ø	>800mm	>4.0m					

# NOTES:

- . CONCRETE FOR MANHOLES MUST BE OF DOLOMITIC ORIGIN.
- 2. FLEXIBLE uPVC PIPES TO SANS 1601 1994: PIPES TO BE CLASS 400, HEAVY DUTY STRUCTURED WALL IN LENGTHS OF 6m MAX. AND EACH PIPE FITTED WITH INTEGRAL CUFF JOINTS. CUFF JOINTS TO USE A RUBBER COMPRESSION SEAL IN THE 2 nd TROUGH FROM THE SPIGOT END.
- FLEXIBLE JOINTS TO SANS 1601: 1994 AMENDED: ALL NON STANDARD PIPE SECTIONS TO BE JOINED WITH DOUBLE & KIMBERLEY/REPAIR COUPLINGS
- I. FIELD TESTS: a) AIR TESTS ACCORDING TO CLAUSE 7.2 OF SANS 1200 LD MUST BE CARRIED OUT BETWEEN MANHOLES DURING THE FOLLOWING PHASES OF CONSTRUCTION:
- i) AFTER THE PIPES HAVE BEEN LAID.
- ii) AFTER THE INITIAL BACKFILLING HAS BEEN COMPLETED. b) THE AIR TEST IS ONLY AN INDICATION OF ACCEPTANCE OF A COMPLETED PORTION OF THE LINE AND IN ANY DISPUTE ARISING THE OUTCOME OF A
- WATER TEST WILL BE BINDING. I. TRENCHES: a) EXCAVATION AND BACKFILLING OF TRENCHES TO COMPLY WITH SANS 1200 DB.
- b) BEDDING OF PIPES TO COMPLY WITH SANS 1200 LB FOR FLEXIBLE PIPES.
- c) TRENCHES DEEPER THAN 2.0m TO BE EXCAVATED IN V-SHAPE FOR TOP 1.5m AS
- SAFETY PRECAUTION, ONLY ON INSTRUCTION OF THE ENGINEER AS DETERMINED ON SITE AND BY THE IN-SITU MATERIAL.
- d) SEWERS TO BE PROTECTED AT ROAD CROSSINGS AS SHOWN ON THE TYPICAL PLAN FOR PIPE BEDDING. e) TRENCHES TO BE PROTECTED FROM STORMWATER INFLOW.
- f) OVER EXCAVATION MAY ONLY BE FILLED AFTER APPROVAL BY THE ENGINEER
- WITH GRADE 20/19 CONCRETE OR SUITABLE MATERIAL AS DIRECTED BY THE ENGINEER.

# MANHOLES AND FITTINGS:

- a) ALL CONCRETE, BENCHING AND SEALERS SHALL COMPLY WITH SANS 1200 GA OR SANS 1200 LD AS APPLICABLE.
- b) PRECAST CONCRETE SECTIONS TO COMPLY WITH SANS 1294.
- c) CONCRETE MANHOLE SECTIONS MUST BE FIXED WITH AN EPOXY SEALER SUCH
- AS EPIDERMIX 344 OR PRO-STRUCT 687 OR SIMILAR APPROVED. d) CLASSES OF CONCRETE:
- i) PRECAST CONCRETE SECTIONS 30/19.
- ii) BEDDING CRADLE 15/19.
- iii) ALL OTHER CONCRETE 25/19.
- e) CHANNELING:
- Ø ≤ 300mm: CLAY / DOLOMITIC CONCRETE / NUTEC CEMENT
- Ø > 300mm: IN-SITU CAST DOLOMITIC CONCRETE
- f) STEP IRONS SHALL NOT BE INSTALLED IN MANHOLES. g) FREEBOARD: MIN. 150mm FOR OUTFALL SEWERS OR IN RURAL AREAS.
- h) BENCHING: BENCHING TO BE SEALED WITH A 20mm CHEMICAL RESISTANT MORTAR SUCH AS FONDU CEMENT OR SIMILAR APPROVED.
- CLEANING: THE MANHOLE IN TOTAL, BUT THE CHANNELS IN PARTICULAR, MUST BE RUBBED AND CLEANED OUT PROPERLY TO A SMOOTH FINISH BEFORE THE MANHOLE WILL BE INSPECTED FOR APPROVAL.



NOTES / LEGEND



 ENGINEERING
 PROCUREMENT
 MANAGEMENT egistration no. 1998/000185/07 Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137




NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON


DRAWING TITLE


TYPICAL SEWER MANHOLE DETAILS

APPROVED BY BVi JL REYNDERS 2020300701 20/10/2025 ENGINEER/TECHNOLOGIST REG. NO. DATE AS SHOWN @ A1 SCALE DRAWN DJ COETZEE DJ COETZEE CHECKED JL REYNDERS SUITABILITY STATUS REV. NO. T0 ISSUED FOR TENDER PROJECT NO. - ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.

35431-BCN-ZZZ-00-DR-CIV-133-TS-002







# GALVANIZED STEEL JUBILEE CLIPS AND COVER WITH ANTI-CORROSION DENSO TAPE. STEP 2: WRAP ENTIRE SADDLE, JUBILEE CLIPS AND PIPE WITH DENSO TAPE FOR THE WHOLE LENGTH OF THE SADDLE 110 mm dia. JUNCTION TO HOUSE CONNECTION STEP 1: CUT A HOLE FOR THE JUNCTION, THEN FASTEN A GALVANIZED STEEL JUBILEE CLIPS AND SADDLE (BOTH SIDES) HDPE MAIN SEWER PIPE UPVC SADDLE D = DIAMETER OF MAIN SEWER (VARIES)

FIXING DETAILS FOR SADDLES

a) TRACE ELLIPSE OF SADDLE JUNCTION OPENING

b) CUT ELLIPSE HOLE THROUGH HDPE MAIN PIPE.


SPECIAL CARE MUST BE TAKEN TO PREVENT DEBRIS

c) FIX uPVC SADDLE TO THE HDPE MAIN PIPE WITH


FROM FALLING INTO THE MAIN PIPE.

ONTO THE MAIN HDPE PIPE.


FIXING DETAILS OF uPVC SADDLE
ON HDPE MAIN SEWER




TYPICAL DETAIL OF RODDING EYE
AT FUTURE HOUSE CONNECTIONS ON THE ERF SEWER LINE



TYPICAL DETAIL OF RODDING EYE
AT THE HEAD OF THE ERF SEWER LINE
N.T.S.



CONNECTION OF ERF SEWER COLLECTOR
TO MAIN SEWER
N.T.S.



SHORT FUTURE CONNECTIONS:
1.0m PIPE + 1 x JUNCTION + 1 x END CAP + 1 x MARKER
LONG FUTURE CONNECTION:
1.5M PIPE + 1 x JUNCTION + 1 x END CAP + 1 x MARKER
SHORT CONNECTION:
1.25m PIPE + 1 x JUNCTION
LONG CONNECTION:

0.5m PIPE + 1 x JUNCTION + 1 x END CAP + 1 x MARKER

ALL PIPEWORK BEDDING AND BLANKET TO COMPLY WITH SANS

1.8m PIPE + 1 x JUNCTION

SHORT SHORT FUTURE CONNECTION:

NOTES / LEGEND

APPROVED BY COUNCIL / CLIENT

CITY ENGINEER / CLIENT REG. NO. DATE

REVISION CODES

A,B,C...: BEFORE TENDER
TO, T1, T2...: FOR TENDER
0, 1, 2...: CONSTRUCTION
Z : AS-BUILT

DRAWING REVISION

DATE INITIAL NO./CODE REVISION

REVISION DESCRIPTION

COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS



• ENGINEERING • PROCUREMENT • MANAGEMENT

Registration no. 1998/000185/07

Visit or contact us online at www.bvigroup.co.za

Free State - Bloemfontein - (051) 447 2137




NALA LOCAL MUNICIPALITY:
THE REFURBISHMENT OF SEWER
PUMP STATION AND ERADICATION
OF 250 BUCKETS IN EXT. 12 & 13 IN
WESSELSBRON

DRAWING TITLE

TYPICAL SEWER ERF CONNECTION DETAILS

	APPROVED BY BVi					
JL REYNDER:	S 	2020300701		10/2025		
ENGINEER/TECHNOLOGIST REG. NO. DAT				ATE		
SCALE	AS SHOWN @ A1	A1 <b>DRAWN</b> DJ COETZ				
DESIGNED	DJ COETZEE	CHECKED	JL REYNDERS			
	SUITABILITY S	TATUS		REV. NO		
ISSUED FOR TENDER						
PLAN NUMBER						
PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.						

PROJECT NO. - ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO 35431-BCN-ZZZ-00-DR-CIV-133-TS-003



**DETAIL R6:** DETAIL OF MANHOLE LID WITH LOCKING DEVICE

LENGTH TO BE DETERMINED ON SITE

- ALL PIPES TO BE FLUSH WITH

MANHOLE WITH HIGH INLET RAMP TYPE

TYPE 2L OR 2R

35-56 BEND

TYPE 3L OR 3R

57-79 BEND

TYPE S

0-10 STRAIGHT

TYPE 1L OR 1R

11-34 BEND

PLAIN JUNCTION 45°

TYPE 4L OR 4R

80-90 BEND


TYPE 5L


0-10 JUNCTION


TYPE 5R

0-10 JUNCTION

11-34 JUNCTION







NEW HEAVY DUTY CONCRETE MANHOLE COVER AND LOCKABLE LID

EXISTING REDUCING -

MANHOLE COVER SLAB AND REDUCING SLABS TO BE

REMOVED AND DISPOSED.


TO BE REPLACED WITH NEW MANHOLE RINGS TO MATCH THE BASE RING SIZE AND A NEW MANHOLE COVER SLAB OF EQUAL DIAMETER.

(ROCLA OR SIMILAR)

DETAIL R7:

TYPICAL DETAIL FOR REPLACEMENT OF

REDUCING MANHOLES



USING HDPE LINED MANHOLE COMPONENTS SCALE 1:25


1:12.5 (8% CEMENT) SOILCRETE AROUND MANHOLE COVER IN RURAL AND UNPAVED AREAS,

SECTIONS (TO SUIT BASE MANHOLE RING DIAMETER)


EXISTING PRECAST CONCRETE BASE SECTIONS


- SEE MANHOLE RING JOINT DETAIL

WELL COMPACTED AND FINISHED











NOTES / LEGEND

APPROVED BY COUNCIL / CLIENT

DRAWING REVISION

REG. NO.

ASB : AS-BUILT

DATE

: ISSUED FOR INFORMATION

FAC : FOR ACCEPTANCE CONTROL

IFC : ISSUED FOR CONSTRUCTION

IFR : ISSUED FOR REVIEW

REVISION DESCRIPTION

CITY ENGINEER / CLIENT

DATE INITIAL NO./CODE

T0, T1, T2...

0, 1, 2...

REVISION CODES

BEFORE TENDER

FOR TENDER

AS-BUILT

CONSTRUCTION



NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON

DRAWING TITLE

# ADDITIONAL SEWER MANHOLE DETAILS


	APPROVI	ED BY BVI			
JL REYNDERS 2020300701 20/10/					
ENGINEER/TECHNOLOGIST REG. NO. DATE					
SCALE AS SHOWN @ A1 DRAWN DJ COETZEE			ZEE		
DESIGNED DJ COETZEE CHECKED JL REYNDERS					
	SUITABILITY ST	ATUS		REV. NO.	
ISSUED FOR TENDER T					
PLAN NUMBER					
PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.					
35431-BCN-ZZZ-00-DR-CIV-133-TS-004					

TYPICAL MANHOLE CHANNEL DETAILS


35-56 JUNCTION

57-79 JUNCTION

80-90 JUNCTION



MANHOLE WITH HIGH INLET VERTICAL DROP TYPE




90 DOUBLE JUNCTION

90 DOUBLE HOUSE CONNECTION

90 SINGLE HOUSE CONNECTION

NOTES: 1. DRAWING TO BE READ IN CONJUNCTION WITH DRAWING NO. 35431-BCN-ZZZ-00-DR-CIV-133-TS-002




		I
ITEM NO.	DESCRIPTION	NO. OF
S1	110mmØ PAN CONNECTOR	1
S2	110mmØ uPVC VENT HORN BEND WITH INSPECTION EYE AND 50mmØ VENT ON HEEL	1
S3	50mmØ uPVC VENTILATION PIPE WITH ONE-WAY VENTILATION VALVE, FIXED WITH APPROVED GLUE (100mm MAX. LENGTH)	1
S4	110mmØ uPVC DISTANCE PIECE (LENGTH TO SUIT)	1
S5	110x50mmØ uPVC JUNCTION	1
S6	110mmØ uPVC 90° BEND	1
<b>S</b> 7	50mmØ uPVC DISTANCE PIECE (LENGTH TO SUIT)	1
S8	50mmØ uPVC 90° BEND	2
S9	50mmØ uPVC DISTANCE PIECE (LENGTH TO SUIT)	1
S10	50mmØ uPVC DOWNPIPE (LENGTH TO SUIT)	1
S11	50mmØ P-TRAP	1
S12	VAAL SANITARYWARE 4.5-LITRE PORCELAIN PAN WITH SEAT AND COVER	1
S13	6-LITRE SISO POLYPROPYLENE TOP-FLUSH CISTERN WITH LID	1

WATER SUPPLY FITTING SCHEDULE				
ITEM NO.	DESCRIPTION	NO. OF		
W1	1/2"Ø TO 20mmØ PLASSON MALE ADAPTOR	1		
W2	1/2"Ø BALL VALVE WITH HANDLE TO SANS 226, CLASS 2	1		
W3	1/2"Ø GALVANIZED STEEL DISTANCE PIECE TO SANS 62 (LENGTH TO SUIT)	1		
W4	1/2"Ø GALVANIZED STEEL T-PIECE TO SANS 62	1		
W5	1/2"Ø GALVANIZED STEEL DISTANCE PIECE TO SANS 62 (LENGTH TO SUIT)	1		
W6	CONCRETE WASH TROUGH (ROCLA OR SIMILAR APPROVED)	1		
W7	15mm PLASTIC TAP	1		

# NOTES:

- 1. FLOOR: THE FLOOR MUST BE A 150mm THICK CONCRETE RAFT FOUNDATION (20MPa/19mm).
  THE TOP OF SLAB MUST BE 75mm ABOVE THE NGL
  AT THE HIGHEST POINT.
- 2. WALLS: A 250µ DAMP PROOF COURSE MUST BE PROVIDED UNDER ALL EXTERNAL WALLS.
- 3. DOORS: THE DOOR AND DOOR FRAME MUST BE PAINTED WITH 1 COAT OF UNDERCOAT AND 1 COAT OF ENAMEL PAINT IN ADDITION TO THE FACTORY PAINTED RED-OXIDE.
- 4. ROOF: THE MINIMUM ROOF SLOPE IS 5.0°. PURLIN BEAMS MUST BE POSITIONED AS SHOWN IN SECTION-B. PURLINS MUST BE S.A.P. GRADE V5 PURLIN BEAMS. GALVANIZED STEEL WIRE MUST BE TAKEN UP ON EITHER SIDE OF THE PURLIN BEAM AND TWISTED TOGETHER, SO AS NOT TO HAVE ANY SLACK, AND MUST BE FIXED WITH A 75mm ROOF SCREW, COMPLETE WITH A BONDED WASHER.
- 5. ALL BOLTS, NUTS, BRACKETS, ETC. MUST BE CORROSION PROTECTED TO THE SATISFACTION OF THE ENGINEER.
- 6. MINIMUM COVER TO MESH REINFORCEMENT IS



APPROVED BY COUNCIL / CLIENT

NOTES / LEGEND

COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS



egistration no. 1998/000185/07 Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137




NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON


DRAWING TITLE


TYPICAL TOILET TOP STRUCTURE DETAILS


	APPROVI	ED BY BVi			
JL REYNDER	S	2020300701	20/	10/2025	
ENGINEER/TECHNOLOGIST REG. NO. DATE					
SCALE AS SHOWN @ A1 DRAWN DJ COETZ				ZEE	
DESIGNED DJ COETZEE CHECKED JL REYNDERS				ERS	
	SUITABILITY ST	ATUS		REV. NO.	
ISSUED FOR TENDER					
PLAN NUMBER					
PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.					

35431-BCN-ZZZ-00-DR-CIV-133-TS-005









MIN 150mm FREE BOARD

SELECTED FILL AROUND MANHOLE IN LAYERS NOT EXCEEDING 150mm COMPACTED TO 90% MOD AASHTO DENSITY

PRECAST CONCRETE SECTIONS

SEWER RISING MAIN DIAMETER AS PER LAYOUT DRAWING

JOINT DETAIL

COVER STARTER RING

200mm THICK CONCRETE FLOOR SLAB

- 250 STARTER RING


- MESH REF. 193


HEAVY DUTY CONCRETE MANHOLE COVER — AND LOCKABLE LID (ROCLA OR SIMILAR)


SECTION ELEVATION ALONG CENTRE OF

SEWER RISING MAIN AIR VALVE CHAMBER

SCALE 1:25








6 x 20 mm FLAT BAR 5

/-- "SEWER" LETTERS INDENTED IN CONCRETE



APPROVED BY COUNCIL / CLIENT CITY ENGINEER / CLIENT REG. NO. DATE SUITABILITY CODES REVISION CODES : ISSUED FOR INFORMATION BEFORE TENDER FAC : FOR ACCEPTANCE CONTROL T0, T1, T2... FOR TENDER IFR : ISSUED FOR REVIEW CONSTRUCTION 0, 1, 2... IFC : ISSUED FOR CONSTRUCTION AS-BUILT ASB : AS-BUILT DRAWING REVISION DATE INITIAL NO./CODE REVISION DESCRIPTION

NOTES / LEGEND

COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF



gistration no. 1998/000185/07 Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137



NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON


PROJECT NAME


DRAWING TITLE

TYPICAL SEWER **RISING MAIN DETAILS:** RISING MAIN OUTLET MANHOLE & AIR VALVE CHAMBER

APPROVED BY BVI						
				_		
JL REYNDER	S	2020300701	20/1	10/2025		
ENGINEER/TECHNOLOGIST REG. NO. DA						
SCALE AS SHOWN @ A1 DRAWN DJ COET						
DESIGNED DJ COETZEE CHECKED JL REYND				ERS		
	SUITABILITY ST	ATUS		REV. NO.		
ISSUED FOR TENDER						
PLAN NUMBER						
PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.						

35431-BCN-ZZZ-00-DR-CIV-133-TS-009





AIR VALVE CHAMBER - PIPEWORK AND FITTING SCHEDULE (PN10)

DESCRIPTION NLINE FLANGED HYDRANT TEE. DIAMETER TO SUIT PIPE DIAMETER.

FLANGED REDUCING SPECIAL, ONE END FLANGED TO SUIT REDUCING TEE

DN50mm ND FLANGED WATERWORKS PATTERNS RESILIENT SEAL GATE VALVE TO SANS 664 WITH HAND WHEEL, NON-RISING SPINDLE AND


DN50mm GMS SCREWED BOSS FLANGE DRILLED TO SANS 1123: 1000/3

I50mm BERMAD MODEL C50-C, VENT-O-MAT MODEL RGXII OR EQUIVALENT APPROVED COMBINATION AIR VALVE (SEE QR-CODE TABLE)

FLANGE ADAPTOR TO SUIT PIPE MATERIAL AND DIAMETER

(SEE FITTINGS TABLE ON THIS DRAWING)


OCKWISE CLOSING, CLASS 10



AIR VALVE CHAMBER


FITTINGS TABLE

PIPE TEE DESCRIPTION




DETAIL R6: DETAIL OF MANHOLE LID WITH LOCKING DEVICE

SCALE 1:10



SPIGOT & SOCKET PIPE TYPICAL THRUST BLOCK INSTALLATION

N.T.S.




-----

SECTION E-E

CROSS ANCHORED TO TRENCH WALLS


HORIZONTAL BEND


KIKIKIKIKIKIKIKIKI




2. KEY ANCHOR BLOCK INTO BASE OF TRENCH A MINIMUM DEPTH OF 250

3. KEEP CONCRETE CLEAR OF ALL BOLTS, NUTS AND PIPE JOINTS.





NOTE: FOR THRUST BLOCK SIZES FOR REDUCERS REFER TO NOTE 12.



	MUM BLC		
FOR	VERTICA TEST PR 0 kPa (SE	RESSURE	OF
	CONCRE	TE VOLU	JME (m3)
PIPE DN	11.25° BEND	22.5° BEND	45° BEND
100	Z	Z	0.3
150	N	0.3	0.6
200	0.2	0.5	1.1
225	0.3	0.6	1.4
250	0.3	0.7	2.5

300 0.4 1.1 3.8

375 0.7 1.8 5.8

## **GENERAL NOTES:**

- 1. CONCRETE IN ANCHOR BLOCKS TO BE CLASS 15/20. 2. CONCRETE ANCHOR BLOCKS SHALL BE CAST AGAINST UNDISTURBED NATURAL GROUND AS APPROVED BY THE ENGINEER OR IMPROVED
- GROUND USING SOILCRETE. 3. CONCRETE ANCHOR BLOCKS HAVE BEEN SIZED ON THE BASIS OF A PERMISSIBLE PASSING BEARING PRESSURE OF 146 kN/m2. IN THE EVENT THAT THIS BEARING PRESSURE IS CONSIDERED BY THE ENGINEER TO BE UNACHIEVABLE, THE DIMENSIONS OF X AND Y OF THE DIFFERENT THRUST BLOCK

TYPES SHALL BE ADJUSTED ACCORDINGLY, WITH OR

- WITHOUT SOIL IMPROVEMENT USING SOILCRETE. 4. ANCHOR BLOCKS IN THE TABLE ARE DESIGNED FOR A TEST PRESSURE OF 1200 kPa (120m HEAD). ADJUST CONCRETE VOLUME TO SUIT ACTUAL TEST PRESSURE.
- 5. THE FOLLOWING BEARING PRESSURES ARE RECOMMENDED IN THE ABSENCE OF MORE RELIABLE GEOTECHNICAL DATA:


SOFT CLAY: 55 kN/m2 HARD CLAY: 100 kN/m2 FINE SAND: 150kN/m2 GRAVEL: 200kN/m2


ROCK: 500kN/m2 6. THE SHAPE AND DIMENSIONS OF CONCRETE BLOCKS SHOWN ARE DIAGRAMMATIC ONLY.


7. CONCRETE ANCHOR BLOCKS MUST BE PROVIDED

- FOR ALL SOCKET VALVES. 8. WHERE A GROUP OF PIPES AND FITTINGS WITH RESTRAINED JOINTS ARE USED, ANCHOR BLOCKS ARE REQUIRED ONLY ON ONE COMPONENT IN THE
- 9. WHERE MPVC RUBBER RING JOINTED PIPES ARE USED, THE NORMAL PRACTICE OF ANCHORING BENDS, TEES, END CAPS AND REDUCERS SHALL
- BE FOLLOWED. 10. UNLESS OTHERWISE SPECIFIED, CONCRETE ANCHORAGES ARE REQUIRED FOR ALL VALVES Ø200 AND ABOVE. THRUST AREA SHALL BE AS FOR END
- 11. VALVES Ø350 OR LARGER SHALL BE INSTALLED IN A VALVE CHAMBER. 12. REDUCERS TO HAVE A MINIMUM AREA FOR
- ANCHORS EQUAL TO DIFFERENCE IN CORRESPONDING AREA FOR END CAPS OF EACH DIAMETER OF REDUCER. 13. ANCHOR BLOCK REINFORCEMENT AS SPECIFIED IN
- DESIGN DRAWINGS. 14. ALL DIMENSIONS IN MILLIMETRES UNLESS

OTHERWISE SHOWN.







NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON

NOTES / LEGEND

APPROVED BY COUNCIL / CLIENT

COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF

REG. NO.

ASB : AS-BUILT

SUITABILITY CODES

FAC: FOR ACCEPTANCE CONTROL

: ISSUED FOR REVIEW

IFC : ISSUED FOR CONSTRUCTION

REVISION DESCRIPTION

: ISSUED FOR INFORMATION

DATE

CITY ENGINEER / CLIENT

DATE INITIAL NO./CODE

A,B,C...

T0, T1, T2...

0, 1, 2...

REVISION CODES

BEFORE TENDER

CONSTRUCTION


FOR TENDER


AS-BUILT

DRAWING TITLE


TYPICAL SEWER **RISING MAIN DETAILS:** THRUST BLOCKS

	APPROVED BY BVi					
JL REYNDER	S	2020300701	20/	10/2025		
ENGINEER/TECHNOLOGIST REG. NO. DATE						
SCALE	AS SHOWN @ A1	DRAWN	DJ COETZEE			
DESIGNED	SIGNED DJ COETZEE CHECKED JL REYNDERS			ERS		
	SUITABILITY ST	TATUS		REV. NO.		
ISSUED FOR TENDER						
PLAN NUMBER						
PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.						
35431-BCN-ZZZ-00-DR-CIV-133-TS-010						






TYPICAL CROSS ANCHORED TO FOUNDATION



TYPICAL PLAN VIEW OF A 1.0mØ GRIT-TRAP MANHOLE



SECTION ELEVATION ALONG CENTER OF A 1.0mØ GRIT-TRAP MANHOLE SCALE 1:20

HEAVY DUTY CONCRETE MANHOLE COVER AND LOCKABLE LID (ROCLA OR SIMILAR)

MPG TO BE LOWERED VERTICALLY INTO MANHOLE DURING INSTALLATION AND ROTATED TO ITS FINAL POSITION NEAR THE BOTTOM

OF THE MANHOLE. STEPS TO BE CUT OF NEAR THE BOTTOM OF THE MANHOLE IF

THEY ARE IN THE WAY.
ANY EXPOSED METAL MUST
BE TREATED WITH BITUMEN.

1:12.5 (8% CEMENT) SOILCRETE AROUND MANHOLE COVER IN

MANHOLE COVER TO BE REMOVED PRIOR

50mm WIDE, CLEARLY VISIBLE LINES TO BE PAINTED ON THE SIDES OF THE MANHOLE, 500mm ABOVE THE MPG

AND 1000mm HIGH, TO INDICATE THE POSITION/DIRECTION OF THE PIPES

IN CASE THE VIEW IS OBSCURED B

PRECAST MANHOLE RING

FOR MAINTENANCE TEAMS

HORIZONTAL GRATING

- CONCRETE BENCHING

CONCRETE FLOOR SLAB

(380mm HIGH)


- SEWER PIPE

38mM DEEP FIBREGLASS MOULDED


SUPPORTING LEGS OF THE MPG

TO INSTALLATION OF THE MPG AND REINSTATED ONCE THE MPG INSTALLATION IS COMPLETED


**RURAL AND UNPAVED AREAS** WELL COMPACTED AND FINISHED




TYPICAL PLAN VIEW OF A 1.25mØ GRIT-TRAP MANHOLE



SECTION ELEVATION ALONG CENTER OF A 1.25mØ GRIT-TRAP MANHOLE SCALE 1:20



**DETAIL GT3:** TYPICAL PLAN VIEW OF A 1.5mØ GRIT-TRAP MANHOLE SCALE 1:20



SECTION ELEVATION ALONG CENTER OF A 1.5mØ GRIT-TRAP MANHOLE

TYPICAL MANHOLE PROTECTION GRID

NOMINAL MPG SIZE

1250mm Ø

1500mm Ø

1800mm Ø

1950mm Ø

- CONCRETE FOR MANHOLES MUST BE OF DOLOMITIC ORIGIN.
  - FLEXIBLE uPVC PIPES TO SANS 1601 1994: PIPES TO BE CLASS 400, HEAVY DUTY STRUCTURED WALL IN LENGTHS OF 6m MAX. AND EACH PIPE FITTED WITH INTEGRAL CUFF JOINTS. CUFF JOINTS TO USE A RUBBER COMPRESSION SEAL IN THE 2 nd TROUGH FROM THE SPIGOT END.
  - FLEXIBLE JOINTS TO SANS 1601: 1994 AMENDED: ALL NON STANDARD PIPE SECTIONS TO BE JOINED WITH DOUBLE & KIMBERLEY/REPAIR COUPLINGS

  - a) AIR TESTS ACCORDING TO CLAUSE 7.2 OF SANS 1200 LD MUST BE CARRIED OUT BETWEEN MANHOLES DURING THE FOLLOWING PHASES OF CONSTRUCTION:
  - i) AFTER THE PIPES HAVE BEEN LAID.
  - ii) AFTER THE INITIAL BACKFILLING HAS BEEN COMPLETED.
  - b) THE AIR TEST IS ONLY AN INDICATION OF ACCEPTANCE OF A COMPLETED PORTION OF THE LINE AND IN ANY DISPUTE ARISING THE OUTCOME OF A WATER TEST WILL BE BINDING.

## TRENCHES:

- a) EXCAVATION AND BACKFILLING OF TRENCHES TO COMPLY WITH SANS
- b) BEDDING OF PIPES TO COMPLY WITH SANS 1200 LB FOR FLEXIBLE
- c) TRENCHES DEEPER THAN 2.0m TO BE EXCAVATED IN V-SHAPE FOR TOP 1.5m AS SAFETY PRECAUTION, ONLY ON INSTRUCTION OF THE ENGINEER AS DETERMINED ON SITE AND BY THE IN-SITU MATERIAL.
- d) SEWERS TO BE PROTECTED AT ROAD CROSSINGS AS SHOWN ON THE TYPICAL PLAN FOR PIPE BEDDING.
- e) TRENCHES TO BE PROTECTED FROM STORMWATER INFLOW.
- f) OVER EXCAVATION MAY ONLY BE FILLED AFTER APPROVAL BY THE ENGINEER WITH GRADE 20/19 CONCRETE OR SUITABLE MATERIAL AS

### DIRECTED BY THE ENGINEER. MANHOLES AND FITTINGS:

- a) ALL CONCRETE, BENCHING AND SEALERS SHALL COMPLY WITH SANS
- 1200 GA OR SANS 1200 LD AS APPLICABLE.
- b) PRECAST CONCRETE SECTIONS TO COMPLY WITH SANS 1294. c) CONCRETE MANHOLE SECTIONS MUST BE FIXED WITH AN EPOXY SEALER SUCH AS EPIDERMIX 344 OR PRO-STRUCT 687 OR SIMILAR
- APPROVED. d) CLASSES OF CONCRETE:
- i) PRECAST CONCRETE SECTIONS 30/19. ii) BEDDING CRADLE - 15/19.
- iii) ALL OTHER CONCRETE 25/19.

ALL MANHOLE JOINTS TO BE SEALED -WITH 200mm "DENSO" SEALOSTRIP OR APPROVED EQUIVALENT WATER PROOFING MEMBRANE

JOINT SEALED WITH 'EXPANDITE -

BUTYL 300' WITH ROOT INHIBITOR OR EQUIVALENT

- e) CHANNELING:
- Ø ≤ 300mm: CLAY / DOLOMITIC CONCRETE / NUTEC CEMENT

**DETAIL OF MANHOLE** 

PRECAST RING JOINT

- Ø > 300mm: IN-SITU CAST DOLOMITIC CONCRETE f) STEP IRONS SHALL NOT BE INSTALLED IN MANHOLES.
- g) FREEBOARD: MIN. 150mm FOR OUTFALL SEWERS OR IN RURAL AREAS. h) BENCHING: BENCHING TO BE SEALED WITH A 20mm CHEMICAL
- RESISTANT MORTAR SUCH AS FONDU CEMENT OR SIMILAR CLEANING: THE MANHOLE IN TOTAL, BUT THE CHANNELS IN PARTICULAR,
- MUST BE RUBBED AND CLEANED OUT PROPERLY TO A SMOOTH FINISH BEFORE THE MANHOLE WILL BE INSPECTED FOR APPROVAL.

REC	OMMENDED MANHOL	E SIZES
MANHOLE SIZE	RECOMMENDED PIPE SIZE RANGE	RECOMMENDED MANHOLE DEPTH RANGE
1000mm Ø	100 - 350mm	UP TO 2.0m
1200mm Ø	350 - 500mm	2.1 - 3.0m
1500mm Ø	500 - 800mm	3.1 - 4.0m
1900mm Ø	>900mm	>1 0m

ALL MANHOLE JOINTS TO BE SEALED WITH 200mm "DENSO" SEALOSTRIP OR APPROVED EQUIVALENT WATER

MANHOLE RINGS TO BE CLEANED

AND PRIMED PRIOR TO SEALING



NOTES / LEGEND

APPROVED BY COUNCIL / CLIENT

REG. NO.

ASB : AS-BUILT

REVISION DESCRIPTION

SUITABILITY CODES

FAC : FOR ACCEPTANCE CONTROL

: ISSUED FOR REVIEW

IFC : ISSUED FOR CONSTRUCTION

: ISSUED FOR INFORMATION

DATE

CITY ENGINEER / CLIENT

DATE INITIAL NO./CODE

T0, T1, T2...

0, 1, 2...

REVISION CODES

BEFORE TENDER

CONSTRUCTION

FOR TENDER

AS-BUILT

 ENGINEERING
 PROCUREMENT
 MANAGEMENT gistration no. 1998/000185/07

Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137 CLIENT



NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON

DRAWING TITLE

TYPICAL GRIT-TRAP (GT) MANHOLE AND MANHOLE PROTECTION GRID (MPG) DETAILS

APPROVED BY BVi JL REYNDERS 2020300701 20/10/2025 DATE ENGINEER/TECHNOLOGIST REG. NO. AS SHOWN @ A1 DJ COETZEE SCALE DRAWN DESIGNED DJ COETZEE CHECKED JL REYNDERS SUITABILITY STATUS REV. NO. T0 **ISSUED FOR TENDER** PROJECT NO. - ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO.

35431-BCN-ZZZ-00-DR-CIV-133-TS-011

- 200x400mm ACCESS HATCH FOR MAINTENANCE TEAMS 38mm DEEP FIBREGLASS MOULDED HORIZONTAL GRATING SUPPORTING LEGS OF THE MPG -


> TYPICAL MANHOLE PROTECTION GRID (MPG) 3D VIEW

> > N.T.S.


# TYPICAL MANHOLE PROTECTION GRID (MPG) INSTALLATION DETAIL INTO MANHOLE

# THE ELECTRICAL CABLE EXPOSING AND PROTECTION PROCESS DURING EXCAVATIONS

**EXPOSE ELECTRICAL CABLES** - After all cables have been detected, identified and marked, and before any trench excavations take place, the contractor must carefully excavate cross-cut trenches by hand at 5.0m intervals perpendicular to the direction of the new services that are being installed, to expose all the electrical cables along the service route. After all cables are exposed, the wayleaves process should be followed, as per the Wayleaves Notes on




CREATE WORK SPACE AROUND EXPOSED CABLES - Once the wayleaves application has been approved, the contractor must excavate around the cables by hand to create work space for the cable supports. IMPORTANT NOTE: If any cable joints are uncovered, the MLM Electrical Department must be contacted immediately to arrange for a shut-off of the electricity before any further work takes place.




# **CROSS SECTION**

INSTALL SUPPORT BEAMS - After the contractor has created work space around the cables, support beams must be installed at 5.0m intervals or as dictated by the site conditions. The beams must have a minimum support length of 0.5m on each side and must be pegged into the ground to stabilize and secure them in place. The beams should be made of 2 X 250x75x20x2,5mm channel sections welded together and should be placed on lintels, as per the sketch below.




**STRAP AND TENSION** - After the support beams are secured in place, a hand gear winch with a nylon/kevlar strap should be fixed onto the support beam for each cable that is to be supported. Each winch and strap must be able to handle a minimum of 500kg. Each electrical cable must then be wrapped with a rubber band at every support point to protect the cable. Thereafter, a kevlar/nylon sling must be placed around the rubber band, hooked to the winch strap and tensioned to ensure the cable is fully supported. Alternative methods can also be used to secure the cable in place, but should be submitted to the engineer for review and approval before being used.




# THE ELECTRICAL CABLE EXPOSING AND PROTECTION PROCESS DURING EXCAVATIONS (CONTINUED)


**ARC FLASH PROTECTION** - To protect the contractor from possible hazardous arc flashes, arc flash protection measures must be used to isolate the electrical cables from any persons working in the trenches. The specific arc flash protection measures that are taken can be determined by the contractor, but must be signed off by a professionally registered engineer. Some examples are provided in the steps below as guidance.



ARC FLASH PROTECTION BEFORE TRENCH EXCAVATION - Arc flash protection measures can be placed before **STEP** the main excavations take place. This method is recommended, as it has the added benefit of providing additional protection of the electrical cables during excavation. The proposed method, as per the sketch below, is to create a protection of the electrical cables during excavation. The proposed method, as per the sketch below, is to create a plywood/ shutterboard channel that is placed around the electrical cables and fixed to the support beams to serve as a temporary cable trench and provide a barrier between the work area and the electrical cables.



TRENCH EXCAVATION - After all electrical cables have been securely supported, the contractor can commence with trench excavations up to the levels required for the new services to be installed.



**ARC FLASH PROTECTION AFTER TRENCH EXCAVATION** - Alternatively, the contractor may opt to place arc flash protection after trench excavations have been completed, before workers start working in the trench. The sketch below shows an example using a plywood/ shutterboard sheet that is braced and placed to isolate the electrical cables from the shows an example using a plywood/ shutterboard sheet that is braced and placed to isolate the electrical cables from the work area. The specific arc flash protection measures that are taken can be determined by the contractor, but must be signed off by a professionally registered engineer.




TABLE 1: SUPPORT INTERVALS RECEIVING SUPPORT INTERVAL PIT WIDTH > 5.0m 5.0m 6.0m 4.0m - 5.0m 7.0m 3.0m - 4.0m 8.0m 2.0m - 3.0m

## **WAYLEAVES NOTES:**

- . Once the contractor has completed the cross-cut excavations and exposed the electrical cables, the contractor should take photos to document all the cables that were encountered
- The contractor should then send a request to the MLM surveyor (with 1 week's notice) to record the coordinates and levels of the electrical cables, or the contractor can use their own registered surveyor for this.
- 3. The contractor should also send the photos and surveyed electrical cables to the engineer
- 4. A wayleave application should then be submitted to the MLM Electrical Dept.
- 5. The cross-cut excavations should then be backfilled to protect the services, until the wayleave application has been approved.

< 2.0m 10.0m

> CITY ENGINEER / CLIENT REG. NO. DATE ISSUED FOR INFORMATION : FOR ACCEPTANCE CONTROL T0, T1, T2.. FOR TENDER : ISSUED FOR REVIEW CONSTRUCTION 0, 1, 2... : ISSUED FOR CONSTRUCTION AS-BUILT ASB : AS-BUILT DATE INITIAL NO./CODE REVISION DESCRIPTION

APPROVED BY COUNCIL / CLIENT

COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT O



Visit or contact us online at www.bvigroup.co.za





NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON


DRAWING TITLE

TYPICAL ELECTRICAL CABLE EXPOSING AND PROTECTION **METHODOLOGY** 

APPROVED BY BVi JL REYNDERS DATE ENGINEER/TECHNOLOGIST AS SHOWN @ A1 DJ COETZEE SCALE DJ COETZEE JL REYNDERS T0 ISSUED FOR TENDER PROJECT NO. - ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DR. CODE - PHASE - SEQ. NO. 35431-BCN-ZZZ-00-DR-CIV-133-TS-012







SYMBOL	DESCRIPTION
<b>●2W</b>	2WAY-LIGHT SWITCH MOUNTED AT 1400mm AFFL UNLESS STATED OTHERWISE.
●1L	1L LIGHT SWITCH MOUNTED AT 1400mm AFFL UNLESS STATED OTHERWISE.
●ROT	IP65 ROTARY WEATHERPROOF LIGHT SWITCH MOUNTED AT 1400mm AFFL.
<b>O</b> DN	16A DAY/NIGHT SWITCH MOUNTED INSIDE CLEAR LID BOX
<b>A</b>	16A SWITCHED SOCKET OUTLET WITH 1 X SANS 164-1 AND 2 X SANS 164-2 SOCKETS WALL MOUNTED AT HEIGHT INDICATED.
ST	60A DP STOVE ISOLATOR COMPLETE WITH OUTLET BOX AND CONNECTION AND STOVE COUPLER
<b>⊚</b> G	60A DP GEYESER ISOLATOR COMPLETE WITH OUTLET BOX
	LIGHTNING PROTECTION DOWN CONDUCTOR POINT COMPLETE
<b>∠</b> w⊤	WEATHER TIGHT 16A SWITCHED SOCKET OUTLET WITH 1 X SANS 164-1 AND 2 X SANS 164-2 SOCKETS WALL MOUNTED AT HEIGHT INDICATED COMPLETE WITH IP65 OUTLET BOX
•	EQUIPMENT MOTOR CONNECTION COMPLETE WITH WEATHERPROOF ISOLATOR BOX 63A 3P ISOLATORS


-	
SYMBOL	DESCRIPTION
NEW TYPE A LUMINAIRE	20W VAPOURPROOF LED LUMINAIRE AS PER SPECIFICATIONS
B	15W LED BULHEAD LUMINAIRE AS PER SPECIFICATIONS
C	40W LED FLOODLIGHT LUMINAIRE AS PER SPECIFICATIONS COMPLETE WITH POLE AND MCB

NOTES / LEGEND	APPROVED BY O	COUNCIL / CLIENT	DATE	INITIAL N	NO./CODE	REVISION DESCRIPTION	
	CITY ENGINEER / CLIENT	REG. NO. DATE					-
	REVISION CODES	SUITABILITY CODES					1
	A,B,C : BEFORE TENDER T0, T1, T2 : FOR TENDER 0, 1, 2 : CONSTRUCTION Z : AS-BUILT	IFI : ISSUED FOR INFORMATION FAC : FOR ACCEPTANCE CONTROL IFR : ISSUED FOR REVIEW IFC : ISSUED FOR CONSTRUCTION ASB : AS-BUILT				IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION FUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS	





	APPROVE	D BY BVi		PROJECT NAME								
				NALA LOCAL MUNICIPALITY: THE REFURBISHMENT OF SEWER PUMP STATION AND ERADICATION OF 250 BUCKETS IN EXT. 12 & 13 IN WESSELSBRON								
				DRAWING TITLE	SUITABILITY STATUS	REV. NO.						
HARMSE		201570312	20/10/2025	ELECTRICAL BUILDING LAYOUTS	ISSUED FOR TENDER	ТО						
GINEER/TE	CHNOLOGIST	REG. NO.	DATE	PLAN NUMBER								
CALE	1:100 @ A1	DRAWN	D COETZEE	PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE -	DR. CODE - PHASE - SEQ. NO	D.						
SIGNED	P HARMSE	CHECKED	P HARMSE	35431-BCN-ZZZ-00-DR-EL0	C-311-TS-002	2						








NOTES / LEGEND	APPROVED BY COUNCIL / CLIENT DATE	E INITIAL NO./CODE	REVISION DESCRIPTION	CLIENT			APPROVE	ED BY BVi		PROJECT NAME	
	CITY ENGINEER / CLIENT REG. NO. DATE  REVISION CODES  SUITABILITY CODES  A,B,C: BEFORE TENDER  FAC: FOR ACCEPTANCE CONTROL				CESA  Consulting Engineers South Africa  YEARS EST 1967	P HARMSE ENGINEER/TE	CHNOLOGIST	201570312 REG. NO.		NALA LOCAL MUNICIPALITY: THE OF SEWER PUMP STATION AND EF BUCKETS IN EXT. 12 & 13 IN W DRAWING TITLE  LUMINAIRE SPECIFICATIONS	RADICATION OF 250
	T0. T1. T2 : FOR TENDER			Y. A. A. Y. A. Y.	ENGINEERING PROCURENTAL MANAGEMENT					PLAN NUMBER	
	0, 1, 2 : CONSTRUCTION Z : AS-BUILT   IFR : ISSUED FOR REVIEW   IFC : ISSUED FOR CONSTRUCTION	COPYRIGHT VESTS	IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION		• ENGINEERING • PROCUREMENT • MANAGEMENT Registration no. 1998/000185/07	SCALE	1:100 @ A1	DRAWN	D COETZEE	PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE -	- DR. CODE - PHASE - SEQ. NO.
	ASB : AS-BUILT	THEREOF MAY OCC	UR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS	ACOTSOI PULA	Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137	DESIGNED	P HARMSE	CHECKED	P HARMSE	35431-BCN-ZZZ-00-DR-EL0	C-311-TS-003

Genlux

Approved supplier

MOUNTING	MATERIAL	SECTIONS	EQUIPMENT	CABLE ENTRY	ACCESS	COLOUR		RATINGS		HINGES/HAND	DLES	NORMAL SECT	ION	EMERGENCY SE	ECTION	UPS SECTION	
SEMI RECESSED	1.6MM 3CR12	INCOMER	СВІ	TOP	TOP	DOOR	WHITE	NORMAL	63A 240V	LOCKABLE	PADLOCKABLE	FED FROM	KIOSK	FED FROM	-	FED FROM	_
SURFACE	1.6MM MILD STEEL	NORMAL	SCHNEIDER	воттом	FRONT	FACEPLATE	PER SECTION	EMERGENCY	-	DOOR LOCK TYPE	LEVER LOCK	CABLE SIZE/CORES	-	CABLE SIZE/CORES	-	CABLE SIZE/CORES	-
FLOOR STANDING	GALVANIZED	EMERGENCY	LOVATO	SIDES	SIDES	SURROUND	WHITE	UPS	-			BUSBAR RATING	63A	BUSBAR RATING	-	BUSBAR RATING	-
KIOSK	POWDER COATED	UPS		REAR	REAR	BACKTRAY	GALV			FACEPLATE LOCK	1/4 TURN ALAN	FAULT LEVEL	6KA	FAULT LEVEL	-	FAULT LEVEL	-
WEATHERPROOF	COMPOSITE						•		•	HINGES	T- HINGES	CASCADED	YES/NO	CASCADED	-	CASCADED	-
									SUPPLY VOLTAGE	240V +-10%	SUPPLY VOLTAGE	-	SUPPLY VOLTAGE	-			
SUB DB-GUARD HOUSE								COLOUR	WHITE	COLOUR	-	COLOUR	_				



# PANEL LAYOUT

NOTES AND EQUIPMENT LIST DB TO BE MANUFACTURED FROM 1.6mm MILD STEEL, POWDERCOATED WHITE, WALL MOUNT RECESSED WITH WALL PAN.

- EQUIPMENT LIST:

  1. 3 X 22mm DIA AD22-22VM PILOT LIGHTS (RED,YELLOW,BLUE)

  2. 3 x 420006 10 x 35mm gG 6A FUSES AND 6 X 485101 32A 10 X 38mm PMX FUSE HOLDERS

  3. 1 X CBI 63A 2P 6kA MCB QF2(13)

  4. 2 X CBI 10A 2P 6kA MCB QF2(13)


  5. 3 X CBI 20A 2P 6kA MCB QF2(13)


  6. 1 X CBI EARTH LEAKAGE 63A 1P+N QF17C

  7. 4 X THINGES


  8. 8 X 1 THIN LOCKS

- 8. 8 X 1 TURN LOCKS 9. 2 X LEVER LOCKS







NOTES / LEGEND	APPROVED BY COUNCIL / CLIENT DA	TE INITIAL NO./CODE REVISION DESCRIPTION	CLIENT		APPROVED BY BVi		PROJECT NAME	
				CESA  Consulting Engineers South Africa  Inga. Iso 9001 Registered O15			NALA LOCAL MUNICIPALITY: TH OF SEWER PUMP STATION AND E BUCKETS IN EXT. 12 & 13 IN	<b>ERADICATION OF 250</b>
	CITY ENGINEER / CLIENT REG. NO. DATE  REVISION CODES SUITABILITY CODES			YEARS			SCHEMATIC LAYOUTS	ISSUED FOR
	A,B,C : BEFORE TENDER T0, T1, T2 : FOR TENDER			€ST 1967	P HARMSE 201570312  ENGINEER/TECHNOLOGIST REG. NO.	20/10/2025 DATE	PLAN NUMBER	TENDER
	0, 1, 2 : CONSTRUCTION	COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS	AGOTSO! PULAL	• ENGINEERING • PROCUREMENT • MANAGEMENT  Registration no. 1998/000185/07  Visit or contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137	SCALE NOT TO SCALE DRAWN  DESIGNED P HARMSE CHECKED	D COETZEE	PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - RO. 35431-BCN-ZZZ-00-DR-E	DLE - DR. CODE - PHASE - SEQ. NO.



			CESA Consulting Engineers South Africa Iso 9001 Registered O15				OF SEWER PUMP STATION AND ERA BUCKETS IN EXT. 12 & 13 IN WE	
CITY ENGINEER / CLIENT REG. NO. DATE  REVISION CODES  SUITABILITY CODES  A,B,C : BEFORE TENDER  THE SUITABILITY CODES  FOR ACCOUNTS OF A CONTROL			byi 50 YEARS EST 1967	P HARMSE	201570312 REG. NO.	20/10/2025 DATE	SCHEMATIC LAYOUTS	ISSUED FOR TENDER TO
T0, T1, T2 : FOR TENDER  FAC : FOR ACCEPTANCE CONTROL  IFR : ISSUED FOR REVIEW  —			• ENGINEERING • PROCUREMENT • MANAGEMENT		1.200		PLAN NUMBER	
0, 1, 2 : CONSTRUCTION	COPYRIGHT VESTS IN THIS DOCUMENT AND NO USE OR REPRODUCTION OR DUPLICATION	Registrati	ration no. 1998/000185/07	SCALE NOT TO SCALE	DRAWN	D COETZEE	PROJECT NO ORIGIN - SYSTEM - LOCATION - TYPE - ROLE - DI	R. CODE - PHASE - SEQ. NO.
ASB : AS-BUILT	THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS	Visit or co	contact us online at www.bvigroup.co.za Free State - Bloemfontein - (051) 447 2137	<b>DESIGNED</b> P HARMSE	CHECKED	P HARMSE	35431-BCN-ZZZ-00-DR-ELC	-312-TS-002





Free State - Bloemfontein - (051) 447 2137

DESIGNED

P HARMSE


CHECKED


P HARMSE

Visit or contact us online at www.bvigroup.co.za

ASB : AS-BUILT

THEREOF MAY OCCUR WITHOUT THE WRITTEN CONSENT OF BVI CONSULTING ENGINEERS





DOCUMENTATION TO BE ISSUED TO THE ENGINEER

Geotechnical report

Fill material test results

Concrete mix designs

Paint specification

Bolt torque confirmation

STEEL STRUCTURE

WATERPROOFING

ABBREVIATIONS:

EXP.

C.E.

RWDP.

S/BED

Compaction test results Soil poisoning certificate

150x150x150mm cube test results

Structural steel material guarantee

Waterproofing 10 year material guarantee

Waterproofing 10 year installation

U.N.O = UNLESS NOTED OTHERWISE

= SURFACE BED

= TOP OF CONCRETE = BOTTOM OF CONCRETE

= INVERT LEVEL

= RODDING EYE

= CLEANING EYE

= ANGLE IRON

= THICK

PL OR PLT = PLATE

= INSPECTION EYE

= RAIN WATER DOWN PIPE

= UNIVERSAL BEAM (I-SECTION)

= UNIVERSAL COLUMN (H-SECTION)

= COLD-FORMED LIPPED CHANNEL

= PARALLEL FLANGE CHANNEL

= CIRCULAR HOLLOW SECTION = SQUARE HOLLOW SECTION

= TAPERED FLANGE CHANNEL = RECTANGULAR HOLLOW SECTION

= COLUMN = BEAM

Roof sheeting material guarantee

Roof sheeting installation guarantee

Workshop drawings (SANS 1200H 5.1.2 refers).

Qualified welders certificate must be provided

ITC certified roof sign off for timber / LFS roofs

= UNLESS STATED OTHERWISE

= REINFORCED CONCRETE

= STRUCTURAL SLAB LEVEL = FINISHED FLOOR LEVEL = FINISHED / FINAL LEVEL

= RETAINING (EXAMPLE: RETAINING WALLS)

= EXPANSION (EXAMPLE: EXPANSION BOLTS)

SANAS certificate to be provided to confirm reinforcement compliance

Site survey

EARTHWORKS

CONCRETE



REVISION:

DATE

bfn@bvifs.co.za

DATE

