

ENGINEERING SERVICES DEPARTMENT					
SPECIFICATION SHEET FOR INSTRUMENT AIR PRESSURE REGULATOR PCV 1708				PAGE	1 of 3
Project	PTFE Filter Destruction Demonstration Facility	Unit Tag Number	PCV 1708		
Datasheet Document No.	ENS-NWPVR-SPE-24027	Revision	1		
GENERAL INFORMATION					
Description	The pressure regulator PCV 1708 will be installed on the instrument air supply line to the air-driven diaphragm pump P83156 in the PTFE Filter Destruction Demonstration Facility.				
Plant Location	Necsa, Pelindaba, North-West Province.				
Equipment Location	PTFE Filter Destruction Demonstration Facility - Inside Laboratory 131, Building V-H2.				
Safety Classification	Non-classified (N) and Non-classified (C).				
Quality Classification	Non-classified (N) and Non-classified (C).				
Process Fluid	Instrument air grade ISO 8573-1:2010 [3:4:1]				
Fluid State	Gas				
P&ID Number	ENS-NWPVR-PID-24014 ^[4]				
Line Number	15-17-AICX-087				
Design Temperature [°C]	100				
Design Pressure [kPa(g)]	1965				
OPERATING CONDITIONS OF PROCESS FLUID					
FLUID PROPERTIES	UNITS	MINIMUM	NORMAL	MAXIMUM	REFERENCES
Molecular Weight	kg/kmol	-	28,88	-	Note 2
Operating Temperature	°C	-2,6	20	40	[2]
Operating Pressure (upstream)	kPa(g)	100	500	750	Table 4 of [3]
Density (@ min., normal, and max. for both operating pressure and temperature.)	kg/m ³	2,09	6,98	10,78	Note 3
Viscosity (@ min., normal, and max. for operating temperature.)	cP	1,75 x 10 ⁻⁵	1,88 x 10 ⁻⁵	2,6 x 10 ⁻⁵	Table 2-363 of [1]
Compressibility Factor	Z	0,997	0,999	0,999	Table 2-165 of [1]
Specific Heat Ratio (Cp/Cv)	-	-	1,416	-	Table 2-200 of [1]
Thermal Conductivity	W/m.K	0,024	0,026	0,030	Table 2-363 of [1]

ENGINEERING SERVICES DEPARTMENT					 necsa <small>We're in your world.</small> South African Nuclear Energy Corporation SOC, Limited
SPECIFICATION SHEET FOR INSTRUMENT AIR PRESSURE REGULATOR PCV 1708					
					2 of 3
CONTROL INFORMATION					
VALVE SIZING INFO. & SPECIFICATION	UNITS	MINIMUM	NORMAL	MAXIMUM	REFERENCE
Valve Inlet Pressure	kPa(g)	100	500	750	-
Valve Outlet Pressure = Regulator Setpoint Pressure	kPa(g)	-	Note 1	-	-
Maximum Differential Pressure Allowed Across Pressure Regulator	kPa	-	-	650	-
Critical Flow	-	-	No	-	-
Volumetric flow rate (@ 20 °C and 500 kPa(g))	m ³ /h	-	18,75	-	Table 4 of [3]
P _c - Critical Pressure	kPa(a)	-	3790	-	Table 2-164, page 2-139 [1]
Required Measured Range (upstream)	kPa(g)	0	-	850	-
Required Measured Range (downstream)	kPa(g)	0	-	850	-
Fail Action	-	N/A			-
Seat Leakage Class	-	Supplier to advise			-
Maximum Shut - Off Differential Pressure	kPa	750			-
VALVE MECHANICAL REQUIREMENTS					
MATERIAL OF CONSTRUCTION					
Body	Bellows	Spring	Seat	Disk and STEM	
Carbon Steel	Supplier To Advise	NA	Steel (Supplier To Advise)	Carbon Steel	
Bonnet/Cap	Type	Wetted parts	Non-wetted parts		
Carbon Steel	Two-Stage	Carbon Steel	Carbon Steel		
PROCESS CONNECTIONS					
	Flange Spec.	Flange Rating	Pipe Size (NB)		
Inlet	CS, ASTM A105, ASME B16.5 (Supplier To Advise On Alternatives)	Class 1500	15		
Outlet	CS, ASTM A105, ASME B16.5 (Supplier To Advise On Alternatives)	Class 1500	15		
Valve rating	Class 1500				
VALVE INSTRUMENTATION REQUIREMENTS					
PRESSURE INDICATING INSTRUMENTS	LOCAL	REMOTE	RECORDING		
	Yes ^{Note 4}	Not required.	Not required.		

ENGINEERING SERVICES DEPARTMENT		 <small>we're in your world</small> South African Nuclear Energy Corporation SOC Limited	
SPECIFICATION SHEET FOR INSTRUMENT AIR PRESSURE REGULATOR PCV 1708		PAGE	3 of 3
REFERENCE DRAWINGS / DOCUMENTS			
[1] Perry, R. H., & Green, D. W. (1997). Perry's Chemical Engineers Handbook 7th Edition. McGraw-Hill Company.			
[2] SHEQ-2011-REP-01017, 2011 : Pelindaba Site, Site Description.			
[3] ENS-NWPVR-REP-24004: Pipe Diameter Verification Report (NW PlasGas Demonstration Facility)			
[4] ENS-NWPVR-PIP-24014: P&ID for Compressed Air Supply to Lab 150 and Lab 131			
NOTES			
1) The actual pressure set-point for the regulator will be determined by the operating requirements of the air-driven diaphragm pump P83156. This value will only become available once the pump is selected. However, the pressure regulator valve PCV1708 must be able regulate the pressure of the instrument air within the pressure regulating range of 100 to 750 kPa(g).			
2) Molecular weight of air is estimated from molar composition of 78% N ₂ and 22% O ₂ in air.			
3) The minimum density is calculated using the maximum operating temperature and minimum operating pressure of the instrument air. The maximum density is calculated using maximum operating pressure and minimum operating temperature of the instrument air. The normal density is calculated using normal operating temperature and the normal operating of the instrument air.			
4) The pressure regulator must be supplied with a local pressure indicator upstream and downstream of the regulator. The local pressure indicators must provide a pressure read-out range of 0 to 850 kPa(g).			
	NAME	SIGNATURE & DATE	
Compiled by	L Dlamini (Process Engineer)		
Process	B Khumalo (Senior Process Engineer)		
Mechanical	S Masango (Mechanical Engineer)		
Mechanical	S. Mngoma (Chief Mechanical Engineer)		
Instrumentation	G. Manuel (Chief C&I Engineer)		
Electrical	W. Van Den Berg (Chief Electrical Engineer)		
Approved by	K. Moodley (Chief Process Engineer)		

This document is the property of Necsa and shall not be used, reproduced, transmitted or disclosed without prior written permission

NED-SHEQ-TEM-11008 R1

RESTRICTED