Site: Bellvile	
Date: 06-06-	

Tender Clarification Query Sl

No	Reference	Description
1	Electrical	What are the electrical battery limits?
2	Security	Will transnet provide site security for the duration of construction and installation?
3	Electrical	Flow meter: - Can we propose a flow meter that is not Elster Kent R1000? - What is the size of this pipe? - Flow meter installaton - Inlet to separator pit (4') or outlet to Municipal Sewer?
4	Electrical	Hazardous zone rating: Why is this area classified as Class 1, Zone 2? Is it not mostly waste oil and moderate amounts of Diesel?
5	Civil	Bund wall that is required - Is it simply increasing the current bund wall height or constructing an entire new bund wall outside of the current one?
6	Civil	Should we quote for cleanup and disposal of waste as well?
7	Civil	Should we quote for rebuilding all damaged sumps?

heet – Bellville
Response: Transnet
From the point of control, including the mains breaker/isolator.
We have security on site , but as Per NEC , sceuring of site camp , materials on site , etc remains the responsibility of the bidder.
Any Flow Meter brand is acceptable , as long as they are of same specification and can meet the required operational requirements
That is correct
If , based on your system design the current bund setup be sufficient , it does not need to be done. How you choose to size/construct the bund wall should it be required, should be based on which is most practicable
Yes
If you still require these as part of your system design.