

 Eskom	Scope of Work	Grootvlei Power Station
---	----------------------	--------------------------------

Title: **Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station**

Unique Identifier: **GVL/0883**

Alternative Reference Number: **N/A**

Area of Applicability: **Grootvlei Power Station**





Functional Area: **Engineering**

Revision: **1**

Total Pages: **46**

Next Review Date: **N/A**

Disclosure Classification: **CONTROLLED DISCLOSURE**

Compiled by	Support	Functional Responsibility	Authorised by
		 PP	 pp
PA Letsoenyo Auxiliary Engineering System Engineer	Thabo Mokoena Materials Manager	Menelisi Mkhabela Auxiliary Engineering Manager	TJ Montja Engineering Manager
Date: 2026/05/06	Date:	Date: 07/05/2026	Date: 08/05/2026

CONTENTS	PAGE
1. INTRODUCTION	3
2. SUPPORTING CLAUSES.....	3
2.1 SCOPE	3
2.1.1 Purpose	3
2.1.2 Applicability.....	3
2.2 NORMATIVE/INFORMATIVE REFERENCES.....	3
2.2.1 Normative	3
2.2.2 Informative.....	3
2.3 DEFINITIONS.....	4
2.3.1 Disclosure Classification	4
2.4 ABBREVIATIONS.....	4
2.5 ROLES AND RESPONSIBILITIES.....	5
2.6 PROCESS FOR MONITORING	5
2.7 RELATED/SUPPORTING DOCUMENTS.....	5
3. SCOPE OF WORK.....	5
3.1 WORKS INFORMATION.....	5
4. AUTHORISATION.....	6
5. REVISIONS	6
6. DEVELOPMENT TEAM	7
7. ACKNOWLEDGEMENTS	7
APPENDIX A - TECHNICAL SPECIFICATIONS & QUANTITIES.....	8

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

1. INTRODUCTION

Grootvlei Power Station is a coal-fired power station located in Grootvlei, Mpumalanga, South Africa. The station is made up of six units, with three units which are currently in service (Units is Unit (1-3) and three units which are on cold reserve (Units is unit (4-6). The three units generate approximately 585 MW to the Eskom national grid.

Grootvlei Power Station intends to establish a long-term contract for the supply and delivery of critical, strategic, and operational spares. This is to support production by ensuring the availability of critical spares, which in turn will ensure quicker return times during downtimes. The station requires an uninterrupted supply and delivery of Bearings, housings, sleeves, and couplings as and when required for a period of 5 years.

2. SUPPORTING CLAUSES

2.1 SCOPE

2.1.1 Purpose

The purpose of this scope of work is to give technical specifications and requirements for the supply and delivery of Bearings, housings, sleeves and couplings as and when required at Grootvlei PS.

2.1.2 Applicability

This document shall apply to Grootvlei Power Station.

2.2 NORMATIVE/INFORMATIVE REFERENCES

Parties using this document shall apply the most recent edition of the documents listed in the following paragraphs.

2.2.1 Normative

[1] ISO 9001 Quality Management Systems

2.2.2 Informative

[2] 240-44175038 Control of Non-conforming Outputs Procedure

[3] 240-39012269 Control of Quality Control Plans and Associated Data Books

[4] 32-727 Safety, Health, Environment and Quality (SHEQ) Policy

[5] 32-1034 Eskom Procurement and Supply Chain Management Procedure

[6] 240-106365693 Standard for the External Corrosion Protection of Plant Equipment Associated Piping with Coating

[7] 240-86973501 Engineering Drawing Standard – Common Requirements

[8] National Key Point Act, 1980 (Act No. 102 of 1980)

[9] 240-62044728 Eskom Standard Conditions of Tender

[10] 32-726 Contract and Contractor Management Standard

[11] 240-105658000 Eskom Supplier Quality Management: Specification

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

[12] Occupational Health and Safety Act, 1993 (Act No. 85 of 1993)

[13] 36-681 Generation Plant Safety Regulations

2.3 DEFINITIONS

Definition	Description
Client	Eskom Holdings SOC Ltd, Grootvlei Power Station, or representatives/staff of Eskom Holdings SOC Ltd or Grootvlei Power Station.
Service Provider	The supplier company who receives purchase order(s) from the Client to execute this SOW.
Service Manager	The Client representative nominated in this SOW who will be the primary point of contact of the Client for the Service Provider.

2.3.1 Disclosure Classification

Controlled disclosure: controlled disclosure to external parties (either enforced by law, or discretionary).

2.4 ABBREVIATIONS

Abbreviation	Description
AS	Authorised Supervisor (PSR)
CM	Corrective Maintenance
DE	Drive End
FME	Foreign Material Exclusion
HP	Hold Point
ISO	International Standardisation Organisation
KKS	Kraftwerk-kennzeichensystem (plant labelling code system used in Eskom Power Stations)
NDE	Non-drive end
NDT	Non-destructive Testing
NPSH	Net Positive Suction Head
OEM	Original Equipment Manufacturer
OHS	Occupational Health and Safety
PM	Preventative Maintenance
PO	Purchase Order
PQR	Procedure Qualification Record
PSR	Plant Safety Regulations
PSV	Pressure Sustaining Valve
PTW	Permit to Work
RAMS	Risk Assessment and Method Statement

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Abbreviation	Description
RP	Responsible Person (PSR)
SOW	Scope of Work
WBS	Work Breakdown Structure
WP	Witness Point
WPS	Welding Procedure Specification

2.5 ROLES AND RESPONSIBILITIES

Compiler	The document compiler is responsible for ensuring that this document is up-to-date and that this document is not a duplication of an existing documentation, regarding the document's objectives and content
Functional Responsibility	The Functional Responsible Person shall determine if the document is fit for purpose before the document is submitted for authorisation.
Authoriser	The document authoriser is a duly delegated person with the responsibility to review the document for alignment to business strategy, policy, objectives and requirements. He/she shall authorise the release and application of the document

2.6 PROCESS FOR MONITORING

This SOW will be monitored for effectiveness through the QCPs which will be developed for each refurbished/and or supplied pump, agreed delivery times, the performance monitoring of the pollution dam pumps and adherence to the requirement stated in this scope of work.

2.7 Related/Supporting Documents

N/A

3. SCOPE OF WORK

3.1 WORKS INFORMATION

3.1.1 The contractor shall supply and delivery bearings, sleeves, locating rings, bearing blocks and accessories upon receiving an order. The technical specifications of the goods to be supplied and delivered As and When required are listed in appendix A:

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

3.1.1 The contractor shall ensure that the goods are correctly labelled as per order to allow easy identification of goods and for storage purposes.

3.1.1 The contractor shall package the goods in such a way they can be stored for extended periods of time without damages, and to allow easier packaging and storage at the employer's storage facility.

3.1.1 The contractor shall ensure that the ordered goods are packaged, secured and handled safely during transportation to Grootvlei Power Station. The Employer's representative will not accept goods which are damaged. The contractor shall be liable for any goods that are damaged due to poor handling.

3.1.1 The contractor shall have and ensure a storage facility that is clean and neat. The storage facility shall be free of moisture, dust ingress and corrosion. The Employer reserves the right to inspect the storage facility where goods are stored at the contractor's storage facility.

3.1.1 The delivered goods shall be inspected by the employer's representative upon delivery. The goods will be inspected for their condition, quality, quantity and specifications against the order (this may include measurements of dimensions). Goods which are of poor quality or incorrect specifications will not be accepted by the employer's representative and shall be returned back to the contractor/supplier.

3.1.1 The supplier/contractor shall submit the following documentation as application to the goods ordered:

- Installation and maintenance manuals/Installation guides
- Data book's/sheets
- Material certificates.
- Factory acceptance tests where applicable
- Quality Control Plan/Checklist

4. AUTHORISATION

This document has been seen and accepted by:

Name & Surname	Designation
Pitso Letsoenyo	System Engineer
Vusani Mutenda	System Engineer
Moddy Mashiloane	Document Management
Thabo Mokoena	Materials Management Manager
Thabo Montja	Engineering Middle Manager

5. REVISIONS

Date	Rev.	Compiler	Remarks
March 2026	1	PA. Letsoenyo	The scope of work for tendering

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

6. DEVELOPMENT TEAM

The following people were involved in the development of this document:

- Pitso Letsoenyo
- Vusani Mutenda

7. ACKNOWLEDGEMENTS

N/A

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

APPENDIX A - TECHNICAL SPECIFICATIONS & QUANTITIES

Item	Full Description	Material Number	Unit of Measure	Quantity
1	ASSEMBLY: TYPE: PLUMMER BLOCK; APPLICATION: SPARGO 500 DIAMETER X 600 LEFT HAND TWO ROLL ASH CRUSHER; COMPRISING: HOUSING SSN 524/GB3, BEARING SKF.23224 CCM33; DRAWING NO: 8492 REV 0; CAT NO. LINATEX BIN NUMBER 416-095	34688	EA	11
2	BEARING, BALL: MODEL NO: M/P 4INX5IN; REFERENCE NO: 29; TYPE HOFFMAN ONLY, FOR MATHER AND PLATT MEDIVANE AUXILIARY COOLING WATER PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	240406	EA	11
3	BEARING, BALL: ROW: DOUBLE; TYPE PROPELLER SHAFT FRONT; FOR 4 IN SPARLING WATER METER WITH ALL S/STEEL INTERNALS, WITH ELECTRICAL TRANSMITTING HEADS FOR REMOTE INTEGRATORS, BESTOBELL; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32121	EA	5
4	BEARING, BALL: STYLE: DOUBLE SEAL; INSIDE DIAMETER: 5 MM; OUTSIDE DIAMETER: 16 MM; WIDTH: 5 MM; SUPPL P/N: 625B; REFERENCE NO: A/FRME HOF CS0; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30222	EA	5
5	BEARING, BALL: STYLE: DOUBLE SHIELD; SUPPL P/N: 6007-2Z; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30337	EA	5
6	BEARING, BALL: STYLE: SHIELD; SUPPL P/N: 6220-Z; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30178	EA	5
7	BEARING, BALL: SUPPL P/N: 0071+45100072; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31149	EA	5
8	BEARING, BALL: SUPPL P/N: 1200NR; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30336	EA	5
9	BEARING, BALL: SUPPL P/N: 1206; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30412	EA	5
10	BEARING, BALL: SUPPL P/N: 2216C2; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30126	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

11	BEARING, BALL; SUPPL P/N: 3205A; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30340	EA	5
12	BEARING, BALL; SUPPL P/N: 3206A; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30284	EA	5
13	BEARING, BALL; SUPPL P/N: 3310A; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30554	EA	5
14	BEARING, BALL; SUPPL P/N: 3317AM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30341	EA	5
15	BEARING, BALL; SUPPL P/N: 53042; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32617	EA	5
16	BEARING, BALL; SUPPL P/N: 6236C3; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30197	EA	5
17	BEARING, BALL; SUPPL P/N: 6310-Z/CH; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32135	EA	5
18	BEARING, BALL; SUPPL P/N: 901110-0045; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32126	EA	11
19	BEARING, BALL; SUPPL P/N: AMS8; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32691	EA	5
20	BEARING, BALL; SUPPL P/N: EE5-2Z; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30177	EA	5
21	BEARING, BALL; SUPPL P/N: MJT4EC2; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32710	EA	5
22	BEARING, BALL; SUPPL P/N: QJM1 3-4LOC; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30319	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 10 of 46

23	BEARING, BALL; SUPPL P/N: QJM2LOC; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30555	EA	5
24	BEARING, BALL; SUPPL P/N: R&M MT+MB13; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30362	EA	5
25	BEARING, BALL; SUPPL P/N: RLS14; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29890	EA	5
26	BEARING, BALL; SUPPL P/N: RLS32; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29897	EA	5
27	BEARING, BALL; TYPE: ANGULAR CONTACT; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 120 MM; WIDTH: 29 MM; ROW: SINGLE; SUPPL P/N: 7311BECB; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, THRUST BALL, CONTROL OIL PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	229488	EA	5
28	BEARING, BALL; TYPE: ANGULAR CONTACT; INSIDE DIAMETER: 65 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 33 MM; ROW: SINGLE; SUPPL P/N: 7313 BECB; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, M5 (INT) X M6 (EXT), SKF 7313 BG THRUST TIMECH/BOOST/P, 4300 RPM (OIL); VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	229484	EA	5
29	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 1-1/4 IN; OUTSIDE DIAMETER: 2-3/4 IN; WIDTH: 11/16 IN; ROW: SINGLE; SUPPL P/N: ALS10; REFERENCE NO: ALS 10; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32683	EA	5
30	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 120 MM; OUTSIDE DIAMETER: 180 MM; WIDTH: 28 MM; ROW: SINGLE; SUPPL P/N: 6024; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30125	EA	5
31	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 20 MM; OUTSIDE DIAMETER: 47 MM; WIDTH: 14 MM; ROW: SINGLE; SUPPL P/N: 7204B; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32673	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

32	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 20 MM; OUTSIDE DIAMETER: 52 MM; WIDTH: 15 MM; ROW: SINGLE; CAGE MATERIAL: STL; SUPPL P/N: 6304; ITEM MUST BE ORIGINAL PACKED; IBI 14788; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29956	EA	7
33	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 2-1/2 IN; OUTSIDE DIAMETER: 3-7/8 IN; WIDTH: 11/16 IN; ROW: SINGLE; SUPPL P/N: XLJ2 1/2; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30169	EA	5
34	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: 6405; ITEM MUST BE ORIGINAL PACKED. SKF BRAND ONLY. NO OTHER BRANDS ACCEPTABLE; DUTY: HEAVY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30270	EA	11
35	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 72 MM; WIDTH: 19 MM; ROW: SINGLE; SUPPL P/N: 6306; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29940	EA	11
36	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 72 MM; WIDTH: 19 MM; ROW: SINGLE; SUPPL P/N: 7306B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29919	EA	5
37	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: 7307B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30281	EA	5
38	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 34.9 MM; ROW: DOUBLE; SUPPL P/N: 3307A; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30407	EA	7
39	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 34.9 MM; ROW: DOUBLE; SUPPL P/N: 3307AC3; REFERENCE NO: 3307; DUTY: EXTRA LIGHT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30361	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 12 of 46

40	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 25 MM; ROW: SINGLE; SUPPL P/N: 6309C3; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29841	EA	5
41	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 25 MM; ROW: SINGLE; SUPPL P/N: 7309B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29922	EA	5
42	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 120 MM; WIDTH: 49.2 MM; ROW: DOUBLE; SUPPL P/N: 3311A; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30410	EA	5
43	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 120 MM; WIDTH: 49.2 MM; ROW: DOUBLE; SUPPL P/N: 3311AC3; FOR USE WITH SFP GLAND SEALING WATER PUMP. NO OTHER BRANDS ACCEPTABLE; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32008	EA	5
44	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 60 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 31 MM; ROW: SINGLE; SUPPL P/N: 7312B; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30182	EA	5
45	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 65 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 33 MM; ROW: SINGLE; SUPPL P/N: 7313B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30157	EA	15
46	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 78 IN; OUTSIDE DIAMETER: 2 IN; WIDTH: 9/16 IN; ROW: SINGLE; SUPPL P/N: ALS7; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32681	EA	5
47	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 35 MM; ROW: SINGLE; SUPPL P/N: 7314B; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29925	EA	5
48	BEARING, BALL; TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 63.5 MM; ROW: DOUBLE; SUPPL P/N: 3314A; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT	30561	EA	7

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: GVL/0883
 1
 Page: 13 of 46

	THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
49	BEARING, BALL: TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 26 MM; ROW: SINGLE; SUPPL P/N: 7216B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	145	EA	5
50	BEARING, BALL: TYPE: ANGULAR CONTACT; STYLE: OPEN; INSIDE DIAMETER: 95 MM; OUTSIDE DIAMETER: 170 MM; WIDTH: 32 MM; ROW: SINGLE; REFERENCE NO: 7219B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32674	EA	5
51	BEARING, BALL: TYPE: CONRAD; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 14 MM; ROW: SINGLE; REFERENCE NO: 901110-0069; FOR CARRIAGE ASSEMBLY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31517	EA	5
52	BEARING, BALL: TYPE: CONRAD; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 18 MM; ROW: SINGLE; REFERENCE NO: 901110-0049; FOR CARRIAGE ASSEMBLY; BOILER SOOTBLOWERS CONSUMABLE SPARES; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31518	EA	5
53	BEARING, BALL: TYPE: CONRAD; STYLE: DOUBLE SHIELD; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 14 MM; ROW: SINGLE; SUPPL P/N: 6007-ZZ; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31521	EA	5
54	BEARING, BALL: TYPE: CONRAD; STYLE: DOUBLE SHIELD; INSIDE DIAMETER: 60 MM; OUTSIDE DIAMETER: 110 MM; WIDTH: 22 MM; ROW: SINGLE; SUPPL P/N: 6212C3; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30571	EA	5
55	BEARING, BALL: TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 101.6 MM; OUTSIDE DIAMETER: 142.88 MM; WIDTH: 22.23 MM; ROW: SINGLE; SUPPL P/N: XLJ4EC3; SOLE SOURCE: CLYDE BERGEMANN AFRICA PTY LTD; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29819	EA	5
56	BEARING, BALL: TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 105 MM; OUTSIDE DIAMETER: 225 MM; WIDTH: 49 MM; ROW: SINGLE; SUPPL P/N: 6321; FOR LAWRENCE SCOTT PA FAN MOTORS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30217	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 14 of 46

57	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 114.3 MM; OUTSIDE DIAMETER: 203.2 MM; WIDTH: 33.34 MM; ROW: SINGLE; SUPPL P/N: RLS36; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30276	EA	5
58	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 12.7 MM; OUTSIDE DIAMETER: 33.34 MM; WIDTH: 9.53 MM; ROW: SINGLE; SUPPL P/N: RLS4; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30418	EA	5
59	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 1-5/8 IN; OUTSIDE DIAMETER: 3-1/2 IN; WIDTH: 3/4 IN; ROW: SINGLE; SUPPL P/N: RLS13; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29888	EA	5
60	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 17 MM; ROW: SINGLE; REFERENCE NO: 901110-0052; FOR LANCE DRIVE; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31522	EA	5
61	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 25.4 MM; OUTSIDE DIAMETER: 63.5 MM; WIDTH: 19.05 MM; ROW: SINGLE; SUPPL P/N: RMS8; SOLE SOURCE: CLYDE BERGEMANN AFRICA PTY LTD; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29882	EA	5
62	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 38.1 MM; OUTSIDE DIAMETER: 95.25 MM; WIDTH: 23.81 MM; ROW: SINGLE; SUPPL P/N: RMS12; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29887	EA	5
63	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 18 MM; ROW: SINGLE; SUPPL P/N: 6208C3; PACKED IN SIGLES AND CORROSION PROTECTED* CAMDEN: SKF BRAND ONLY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30163	EA	6
64	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: SINGLE; SUPPL P/N: 6308; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29840	EA	7
65	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 110 MM; WIDTH: 44 MM; ROW: DOUBLE; SUPPL P/N: 5310ND; USED ON SAND	31379	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

	FILTER PUMP IN WATER TREATMENT PLANT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
66	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 20 MM; ROW: SINGLE; SUPPL P/N: 6210; REFERENCE NO: 6210; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29829	EA	5
67	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 50.8 MM; OUTSIDE DIAMETER: 114.3 MM; WIDTH: 26.9 MM; ROW: SINGLE; SUPPL P/N: RMS16; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	73	EA	5
68	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 57.15 MM; OUTSIDE DIAMETER: 114.3 MM; WIDTH: 22.23 MM; ROW: SINGLE; SUPPL P/N: RLS18; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29893	EA	9
69	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 60 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 31 MM; ROW: SINGLE; SUPPL P/N: 6312; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30269	EA	7
70	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 75 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 37 MM; ROW: SINGLE; SUPPL P/N: 6315; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29835	EA	5
71	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 76 MM; OUTSIDE DIAMETER: 178 MM; WIDTH: 40 MM; ROW: SINGLE; SUPPL P/N: 901110-0062; FOR SHAFT ASSEMBLY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31523	EA	5
72	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 85 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 28 MM; ROW: SINGLE; SUPPL P/N: 6217; DUTY: EXTRA LIGHT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29844	EA	5
73	BEARING, BALL; TYPE: CONRAD; STYLE: OPEN; INSIDE DIAMETER: 9.53 MM; OUTSIDE DIAMETER: 22.23 MM; WIDTH: 5.56 MM; ROW: SINGLE; SUPPL P/N: EE3; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29898	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 16 of 46

74	BEARING, BALL; TYPE: CONRAD; STYLE: SHIELD; INSIDE DIAMETER: 120 MM; OUTSIDE DIAMETER: 180 MM; WIDTH: 28 MM; ROW: SINGLE; REFERENCE NO: 901110-0016; FOR CARRIAGE ASSEMBLY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	31519	EA	5
75	BEARING, BALL; TYPE: CONRAD; STYLE: SHIELD; INSIDE DIAMETER: 20 MM; OUTSIDE DIAMETER: 42 MM; WIDTH: 12 MM; ROW: SINGLE; SUPPL P/N: 6004-Z; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30380	EA	5
76	BEARING, BALL; TYPE: DEEP GROOVE; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 17 MM; ROW: SINGLE; SUPPL P/N: 6305; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, DC OIL PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	229490	EA	6
77	BEARING, BALL; TYPE: DEEP GROOVE; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 72 MM; WIDTH: 19 MM; ROW: SINGLE; SUPPL P/N: 6306; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, STATOR COOLANT PUMPS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	229492	EA	7
78	BEARING, BALL; TYPE: DEEP GROOVE; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: 6307; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, AC OIL PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	229491	EA	5
79	BEARING, BALL; TYPE: DEEP GROOVE; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: SINGLE; SUPPL P/N: 6308; DRAWING NO: FAG6308 REV 1; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, T/BOOSTER PUMP, 9000 RPM (OIL); VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	229487	EA	5
80	BEARING, BALL; TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 10 MM; OUTSIDE DIAMETER: 26 MM; WIDTH: 8 MM; ROW: SINGLE; SUPPL P/N: 6000-2RS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30476	EA	5
81	BEARING, BALL; TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 12 MM; OUTSIDE DIAMETER: 28 MM; WIDTH: 8 MM; ROW: SINGLE; SUPPL P/N: 6001-2RS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30477	EA	5
82	BEARING, BALL; TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 22.23 MM; OUTSIDE DIAMETER: 57.15 MM; WIDTH: 17.46 MM; ROW: SINGLE; SUPPL P/N: RMS7;	30277	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

83	SUPPLIER NOTE: THE ITEM MUST BE ORIGINAL PACKED, SEALED AND CLEARLY MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). BEARING, BALL: TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 17 MM; ROW: SINGLE; SUPPL P/N: 6305-2RS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30385	EA	5
84	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 25.4 MM; OUTSIDE DIAMETER: 57.15 MM; WIDTH: 15.88 MM; ROW: SINGLE; SUPPL P/N: RLS8; SOLE SOURCE: CLYDE BERGEMANN AFRICA PTY LTD; SUPPLIER NOTE: THE ITEM MUST BE ORIGINAL PACKED, SEALED AND CLEARLY MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30273	EA	5
85	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 18 MM; ROW: SINGLE; SUPPL P/N: 6208-2RS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30484	EA	5
86	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: DOUBLE SEAL; INSIDE DIAMETER: 5/8 IN; OUTSIDE DIAMETER: 1-9/16 IN; WIDTH: 7/16 IN; ROW: SINGLE; SUPPL P/N: RLS5-2RSC2; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30128	EA	5
87	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: DOUBLE SHIELD; INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 35 MM; ROW: SINGLE; SUPPL P/N: 6314-2ZC3; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29857	EA	9
88	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 17 MM; OUTSIDE DIAMETER: 47 MM; WIDTH: 14 MM; ROW: SINGLE; SUPPL P/N: 6303; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29827	EA	5
89	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 17 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 17 MM; ROW: SINGLE; SUPPL P/N: 6403; NOTE: ITEM MUST BE ORIGINAL PACKED; DUTY: HEAVY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30379	EA	5
90	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 52 MM; WIDTH: 15 MM; ROW: SINGLE; SUPPL P/N: 6205; NOTE: ITEM MUST BE	29957	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

	ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
91	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 3/4 IN; OUTSIDE DIAMETER: 7-1/2 IN; WIDTH: 1-9/16 IN; ROW: SINGLE; SUPPL P/N: RMS26; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32661	EA	5
92	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 16 MM; ROW: SINGLE; SUPPL P/N: 6206; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30291	EA	5
93	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: SINGLE; SUPPL P/N: 6406C3; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32564	EA	5
94	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 85 MM; WIDTH: 19 MM; ROW: SINGLE; SUPPL P/N: 6209; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30395	EA	5
95	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 5 IN; OUTSIDE DIAMETER: 10 IN; WIDTH: 2 IN; ROW: SINGLE; SUPPL P/N: RMS40; DUTY: MEDIUM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30160	EA	5
96	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 120 MM; WIDTH: 29 MM; ROW: SINGLE; SUPPL P/N: 6311; ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30268	EA	5
97	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 65 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 33 MM; ROW: SINGLE; CAGE MATERIAL: STL; MANUF P/N: 6313-C3; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30991	EA	10
98	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 35 MM; ROW: SINGLE; SUPPL P/N: 6314; ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	84	EA	5
99	BEARING, BALL: TYPE: DEEP GROOVE; STYLE: OPEN; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 170 MM; WIDTH: 39 MM; ROW: SINGLE; SUPPL P/N: 6316; DUTY: MEDIUM;	69	EA	7

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

	VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
100	BEARING, BALL; TYPE: DEEP GROOVE; STYLE: SHIELD; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: 6307-Z; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29954	EA	5
101	BEARING, BALL; TYPE: DEEP GROOVE; STYLE: SHIELD; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 18 MM; ROW: SINGLE; SUPPL P/N: 6208Z; NOTE: ITEM MUST BE ORIGINAL PACKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29854	EA	5
102	BEARING, BALL; TYPE: HIGH SPEED; OUTSIDE DIAMETER: 9-1/2 IN; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	34850	EA	5
103	BEARING, BALL; TYPE: OPEN, STANDARD; SUPPL P/N: 6316; REFER MATERIAL NUMBER 000069; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	400269	EA	5
104	BEARING, BALL; TYPE: RADIAL CONTACT; STYLE: OPEN; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: SINGLE; SUPPL P/N: 6406C3; SKF BRAND ONLY, NO OTHER BRANDS ACCEPTABLE; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30271	EA	5
105	BEARING, BALL; TYPE: SELF ALIGNING; STYLE: OPEN; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: DOUBLE; SUPPL P/N: 1308; REFERENCE NO: 1308; HOFF U340; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29910	EA	5
106	BEARING, BALL; TYPE: SPHERICAL; STYLE: OPEN; INSIDE DIAMETER: 75 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 25 MM; ROW: DOUBLE; SUPPL P/N: 1215K; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30295	EA	5
107	BEARING, BALL; TYPE: TURNTABLES; STYLE: SLEWING RING; INSIDE DIAMETER: 959 MM; OUTSIDE DIAMETER: 1,111 M; WIDTH: 90 MM; ROW: SINGLE; REFERENCE NO: HE18; INSIDE DIAMETER LOWER RING: 986MM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	661835	EA	5
108	BEARING, CAM FOLLOWER; SUPPL P/N: KR26	30154	EA	5
109	BEARING, FLANGE BLOCK; ROLLING ELEMENT: BALL; INSIDE DIAMETER: 45 MM; SHAPE: SQ; BLOCK SIZE: SQ 137 X THK 10 MM; BOLT MOUNTING: 4; BOLT DIAMETER: M14; HOUSING MATERIAL: CI; SUPPL P/N: UCF209; DUTY LIGHT	217225	EA	280

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

110	BEARING, FLANGE BLOCK: ROLLING ELEMENT: BALL; INSIDE DIAMETER: 60 MM; SHAPE: SQ; BLOCK SIZE: WD 177 X THK 50 MM; BOLT MOUNTING: 4; BOLT DIAMETER: M19; HOUSING MATERIAL: CI; REFERENCE NO: UCF 212-60; DUTY LIGHT	31298	EA	5
111	BEARING, FLANGE BLOCK: SUPPL P/N: 725208	34847	EA	5
112	BEARING, PILLOW BLOCK: INSIDE DIAMETER: 185 MM; BOLT MOUNTING: 2; BOLT DIAMETER: M24; BLOCK SIZE: 350 MM; MANUF P/N: SN 522-619; USED IN ASH PLANT; THE BLOCK MUST BE COMPLETE WITH U-LOCK SEALS	565157	EA	6
113	BEARING, PILLOW BLOCK: INSIDE DIAMETER: 185 MM; BOLT MOUNTING: 2; MANUF P/N: SN 524-620	560969	EA	13
114	BEARING, PILLOW BLOCK: INSIDE DIAMETER: 4-1/2 IN.; BOLT MOUNTING: 4; BOLT DIAMETER: M20; BLOCK SIZE: WD 220 X LG 419.1 X HT 238.1 MM; SHAFT HEIGHT: 120.65 MM; ROLLING ELEMENT: SPHERICAL; HOUSING MATERIAL: CI; SUPPL P/N: AMEP5408YF	219366	EA	5
115	BEARING, PILLOW BLOCK: INSIDE DIAMETER: 93 MM; BOLT MOUNTING: 2; BOLT DIAMETER: 21 MM; BLOCK SIZE: WD 120 X LG 313 X HT 175 MM; SHAFT HEIGHT: 95 MM; ROLLING ELEMENT: ROLLER CYLINDRICAL; HOUSING MATERIAL: CI; SUPPL P/N: SNA516-613; HOUSING, WITH ADAPTER SLEEVE: DUTY: HEAVY	34982	EA	5
116	BEARING, ROLLER: INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: NSK307; CONSUMABLES FOR TURBINE/AUXILIARY PLANT, CW BOOSTER PUMP	229493	EA	7
117	BEARING, ROLLER: INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 35 MM; ROW: SINGLE; BORE SHAPE: CYLINDRICAL; CAGE MATERIAL: STL; MANUF P/N: NU314WC3; NU314WC3; FOR USE ON SECONDRY COOLING SYSTEM	244257	EA	5
118	BEARING, ROLLER: MODEL NO: M/P 4INX5IN; REFERENCE NO: 30; FOR MATHER AND PLATT MEDIVANE AUXILIARY COOLING WATER PUMP	240407	EA	10
119	BEARING, ROLLER: SUPPL P/N: 22319CCCC3	32671	EA	5
120	BEARING, ROLLER: SUPPL P/N: 22326CC3	30082	EA	5
121	BEARING, ROLLER: SUPPL P/N: N219	29967	EA	5
122	BEARING, ROLLER: SUPPL P/N: N311	29870	EA	5
123	BEARING, ROLLER: SUPPL P/N: NUJ202	30351	EA	5
124	BEARING, ROLLER: SUPPL P/N: NUJ207K	30350	EA	5
125	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 110 MM; OUTSIDE DIAMETER: 200 MM; WIDTH: 35 MM; ROW: SINGLE; SUPPL P/N: N222C3	30347	EA	5
126	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 13 MM; OUTSIDE DIAMETER: 33.4 MM; WIDTH: 9.8 MM; ROW: SINGLE; SUPPL P/N: LRJA1-2	30066	EA	5
127	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 130 MM; OUTSIDE DIAMETER: 280 MM; WIDTH: 58 MM; ROW: SINGLE; SUPPL P/N: NU326	30097	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

128	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 15.88 MM; OUTSIDE DIAMETER: 39.69 MM; WIDTH: 11.11 MM; ROW: SINGLE; SUPPL P/N: CRL5; NOTE: ITEM MUST BE ORIGINAL PACKED	30065	EA	5
129	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 52 MM; WIDTH: 15 MM; ROW: SINGLE; REFERENCE NO: N205 STD; N205	30244	EA	6
130	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 16 MM; ROW: SINGLE; SUPPL P/N: N206; REFERENCE NO: ETPV2	29867	EA	5
131	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 30 MM; OUTSIDE DIAMETER: 62 MM; WIDTH: 16 MM; ROW: SINGLE; SUPPL P/N: NU206	30132	EA	5
132	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 80 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: N307; SKF BRAND ONLY, NO OTHER BRANDS ACCEPTABLE	30246	EA	9
133	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 4 IN; OUTSIDE DIAMETER: 8-1/2 IN; WIDTH: 1-3/4 IN; ROW: SINGLE; SUPPL P/N: CRM32	30074	EA	5
134	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: SINGLE; SUPPL P/N: N308	30434	EA	5
135	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 4-1/2 IN; OUTSIDE DIAMETER: 9-3/8 IN; WIDTH: 2 IN; ROW: SINGLE; SUPPL P/N: CRM36	30433	EA	5
136	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 4-1/4 IN; OUTSIDE DIAMETER: 8-3/4 IN; WIDTH: 1-3/4 IN; ROW: SINGLE; SUPPL P/N: CRM34	30440	EA	5
137	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 44.45 MM; OUTSIDE DIAMETER: 107.95 MM; WIDTH: 26.99 MM; ROW: SINGLE; SUPPL P/N: CRM14	30238	EA	5
138	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 25 MM; ROW: SINGLE; SUPPL P/N: NU309EC; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, TIMECH/BOOST/P/P, 7500 RPM (OIL)	229485	EA	5
139	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 110 MM; WIDTH: 27 MM; ROW: SINGLE; SUPPL P/N: N310	30436	EA	5
140	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 20 MM; ROW: SINGLE; SUPPL P/N: N210	29868	EA	5
141	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 90 MM; WIDTH: 23 MM; ROW: DOUBLE; CAGE MATERIAL: STL; SUPPL P/N: 22210KEJW3C3	661842	EA	9
142	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 50.8 MM; OUTSIDE DIAMETER: 114.3 MM; WIDTH: 26.99 MM; ROW: SINGLE; SUPPL P/N: CRM16	30240	EA	5
143	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 21 MM; ROW: SINGLE; SUPPL P/N: N211	29869	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 22 of 46

144	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 120 MM; WIDTH: 29 MM; ROW: SINGLE; SUPPL P/N: N311; CONSUMABLES FOR TURBINE AND AUXILIARY PLANT, CONTROL OIL PUMP	229489	EA	5
145	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 60 MM; OUTSIDE DIAMETER: 110 MM; WIDTH: 22 MM; ROW: SINGLE; SUPPL P/N: N212	29871	EA	5
146	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 60 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 31 MM; ROW: SINGLE; SUPPL P/N: N312	29872	EA	5
147	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 65 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 33 MM; ROW: SINGLE; SUPPL P/N: N313; NOTE - ITEM MUST BE ORIGINAL PACKED	30247	EA	6
148	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 65 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 33 MM; ROW: SINGLE; SUPPL P/N: N313C3	30348	EA	11
149	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 75 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 37 MM; ROW: SINGLE; SUPPL P/N: N315STD; NOTE: ITEM MUST BE ORIGINAL PACKED	29873	EA	5
150	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 170 MM; WIDTH: 39 MM; ROW: SINGLE; SUPPL P/N: NU316	30525	EA	5
151	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 85 MM; OUTSIDE DIAMETER: 180 MM; WIDTH: 41 MM; ROW: SINGLE; SUPPL P/N: N317; TWO LIPS ON INNER, PLAIN OUTER, NOTE: ITEM MUST BE ORIGINAL PACKED	30519	EA	5
152	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 88.9 MM; OUTSIDE DIAMETER: 165.1 MM; WIDTH: 28.58 MM; ROW: SINGLE; SUPPL P/N: CRL28	30069	EA	5
153	BEARING, ROLLER: TYPE: CYLINDRICAL; INSIDE DIAMETER: 90 MM; OUTSIDE DIAMETER: 190 MM; WIDTH: 43 MM; ROW: SINGLE; SUPPL P/N: N318; NOTE - ITEM MUST BE ORIGINAL PACKED	30076	EA	5
154	BEARING, ROLLER: TYPE: NEEDLE; INSIDE DIAMETER: 12 MM; OUTSIDE DIAMETER: 24 MM; WIDTH: 13 MM; ROW: SINGLE; OEM P/N: 5360-207, OEM: GE STEAM POWER SERVICE; 5160-207, OEM: GE STEAM POWER SERVICE; REFERENCE NO.: NA4901	30100	EA	5
155	BEARING, ROLLER: TYPE: NEEDLE; INSIDE DIAMETER: 12 MM; OUTSIDE DIAMETER: 25 MM; WIDTH: 10.5 MM; ROW: SINGLE; SUPPL P/N: KC1211NRD	30224	EA	5
156	BEARING, ROLLER: TYPE: NEEDLE; INSIDE DIAMETER: 15 MM; OUTSIDE DIAMETER: 35 MM; WIDTH: 14 MM; ROW: SINGLE; OEM P/N: 5160-290, OEM: GE STEAM POWER SERVICE; 5360-290, OEM: GE STEAM POWER SERVICE; REFERENCE NO.: NA2202-2RS	30104	EA	5
157	BEARING, ROLLER: TYPE: NEEDLE; SUPPL P/N: HK 1816	30102	EA	5
158	BEARING, ROLLER: TYPE: NEEDLE; SUPPL P/N: NA2100	30352	EA	5
159	BEARING, ROLLER: TYPE: NEEDLE; SUPPL P/N: NAF40X55X17	30153	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 23 of 46

160	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 200 MM; WIDTH: 69.8 MM; ROW: DOUBLE; SUPPL P/N: 23222CCKW33	225579	EA	10
161	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 110 MM; OUTSIDE DIAMETER: 200 MM; WIDTH: 53 MM; ROW: DOUBLE; SUPPL P/N: 22222CCK-STD	30259	EA	17
162	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 115 MM; OUTSIDE DIAMETER: 230 MM; WIDTH: 80 MM; ROW: DOUBLE; SUPPL P/N: 23226CCKW33	225580	EA	5
163	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 120 MM; OUTSIDE DIAMETER: 215 MM; WIDTH: 76 MM; ROW: DOUBLE; SUPPL P/N: 23224CC3; CYLINDRICAL BORE; NOTE: THE REFERENCE NUMBER MUST BE CAST AND NOT ENGRAVED ON BEARING AND ORIGINAL PACKED	30058	EA	11
164	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 160 MM; OUTSIDE DIAMETER: 290 MM; WIDTH: 104 MM; ROW: SINGLE; MODEL NO: 23232 CCK-W33; NOTE: ITEM MUST BE ORIGINAL PACKED	30016	EA	11
165	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 25 MM; ROW: DOUBLE; SUPPL P/N: 22211CCKC3C3	31148	EA	11
166	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 29 MM; ROW: DOUBLE; SUPPL P/N: 21311EK	225878	EA	5
167	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 120 MM; WIDTH: 43 MM; ROW: DOUBLE; SUPPL P/N: 22311CC	30356	EA	5
168	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 60 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 46 MM; ROW: DOUBLE; SUPPL P/N: 22312C; REFERENCE NO: 22312	30445	EA	5
169	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 75 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 31 MM; ROW: DOUBLE; SUPPL P/N: 22215CK; SKF BRAND ONLY, NO OTHER BRANDS ACCEPTABLE	30451	EA	72
170	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 170 MM; WIDTH: 58 MM; ROW: DOUBLE; SUPPL P/N: 22316C; FOR USE ON SULZER SFP BOOSTER PUMP TYPE NPTX(D)48-25, SKF BRAND ONLY, NO OTHER BRANDS ACCEPTABLE	30447	EA	5
171	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 170 MM; WIDTH: 58 MM; ROW: DOUBLE; SUPPL P/N: 22316EC3; REFERENCE NO: 22316E	30357	EA	5
172	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 90 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 40 MM; ROW: DOUBLE; BORE SHAPE: TAPER; SUPPL P/N: 22218CKC3	30452	EA	57
173	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 90 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 40 MM; ROW: SINGLE; SUPPL P/N: 22218CCKW3C3; FEEDER END STATION	32040	EA	43
174	BEARING, ROLLER: TYPE: SELF ALIGNING; INSIDE DIAMETER: 90 MM; OUTSIDE DIAMETER: 180 MM; WIDTH: 60.3 MM; ROW: DOUBLE; SUPPL P/N: 23220CCKW33	225578	EA	16

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 24 of 46

175	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 130 MM; OUTSIDE DIAMETER: 200 MM; WIDTH: 52 MM; ROW: DOUBLE; SUPPL P/N: 22224EK; TAPER; FOR USE ON ASH PLANT	237853	EA	54
176	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 85 MM; WIDTH: 23 MM; ROW: DOUBLE; BORE SHAPE: TAPER; SUPPL P/N: 22209CCKC3	31758	EA	7
177	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 75 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 31 MM; ROW: DOUBLE; REFERENCE NO: 22215CCKC3; THE REFERENCE NUMBER MUST BE CAST AND NOT ENGRAVED ON BEARING, ITEM MUST BE ORIGINAL PACKED	30257	EA	15
178	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 75 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 55 MM; ROW: DOUBLE; REFERENCE NO: 22315CCKW33; 22315CCKW33C3; ITEM TO BE BOXED OR WRAPPED IN GREASE CLOTH	31999	EA	6
179	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 140 MM; WIDTH: 33 MM; ROW: DOUBLE; SUPPL P/N: 22216CCKC3; NOTE - THE REFERENCE NUMBER MUST BE CAST AND NOT ENGRAVED ON AND ORIGINAL PACKED	30201	EA	9
180	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 52.4 MM; ROW: DOUBLE; SUPPL P/N: 23218CCKW33; CONVEYOR PELLOW BLOCK; TO BE SUPPLIED WITH ADAPTOR SLEEVE	225662	EA	7
181	BEARING, ROLLER: TYPE: SELF ALIGNING; SPHERICAL; INSIDE DIAMETER: 85 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 36 MM; ROW: DOUBLE; BORE SHAPE: TAPER; SUPPL P/N: 22217CCKW33C3; LUBRICATION GROOVE AND THREE HOLES IN OUTER RING	29975	EA	18
182	BEARING, ROLLER: TYPE: SPHERICAL RADIAL; INSIDE DIAMETER: 160 MM; OUTSIDE DIAMETER: 340 MM; WIDTH: 114 MM; ROW: DOUBLE; OEM P/N: 22332C/C3; USED ON MCW PUMP 1-4 AND R GEARBOX FOR THE INPUT SHAFT; STRAIGHT BORE	597984	EA	7
183	BEARING, ROLLER: TYPE: SPHERICAL; INSIDE DIAMETER: 240 MM; OUTSIDE DIAMETER: 440 MM; WIDTH: 120 MM; ROW: DOUBLE; OEM P/N: 22248C; USED ON MCW PUMP GEAR BOX 1-4 AND R OUTPUT BEARING SHAFT; SELF ALIGNING	597983	EA	5
184	BEARING, ROLLER: TYPE: SPHERICAL; INSIDE DIAMETER: 320 MM; OUTSIDE DIAMETER: 540 MM; WIDTH: 176 MM; ROW: DOUBLE; SPECIFICATION: 23164CC3; SUPPL P/N: 23164CC3	30205	EA	5
185	BEARING, ROLLER: TYPE: TAPER CONE/CUP; INSIDE DIAMETER: 98.43 MM; OUTSIDE DIAMETER: 168 MM; WIDTH: 41.28 MM; ROW: SINGLE; SUPPL P/N: 685; REFERENCE NO: TIM 865	29807	EA	5
186	BEARING, ROLLER: TYPE: TAPER; INSIDE DIAMETER: 120 MM; OUTSIDE DIAMETER: 215 MM; WIDTH: 74.22 MM; ROW: DOUBLE; BORE SHAPE: SPHERICAL; STYLE: SELF ALIGNING; SUPPL P/N: 23224CCKC3; COMPLETE WITH ADAPTOR SLEEVE 82324	242109	EA	38

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

187	BEARING, ROLLER: TYPE: TAPER; INSIDE DIAMETER: 133.35 MM; OUTSIDE DIAMETER: 234.95 MM; WIDTH: 114.3 MM; ROW: DOUBLE; SUPPL P/N: K95528 - K95927; FOR USE ON ASH PUMPS; CONSISTING OF 2 X K95528 AND 1 X K95927D OUTER CONE	240151	EA	5
188	BEARING, ROLLER: TYPE: TAPER; INSIDE DIAMETER: 190 MM; OUTSIDE DIAMETER: 340 MM; WIDTH: 92 MM; ROW: DOUBLE; OEM P/N: 22238 C/C3; USED ON MCW PUMP GEARBOX 1-4 AND R INPUT BEARING SHAFT; NON LOCATED	597985	EA	5
189	BEARING, ROLLER: TYPE: TAPER; INSIDE DIAMETER: 35 MM; OUTSIDE DIAMETER: 72 MM; WIDTH: 18.25 MM; SUPPL P/N: 30207; CONSUMABLES FOR TURBINE/AUXILIARY PLANT, BID/STEAM OP/GEAR	229482	EA	6
190	BEARING, ROLLER: TYPE: TAPER; INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 110 MM; WIDTH: 24 MM; ROW: SINGLE; SUPPL P/N: 30211A; USED ON ROLLWAY	31862	EA	5
191	BEARING, ROLLER: TYPE: TAPER; INSIDE DIAMETER: 67 MM; OUTSIDE DIAMETER: 125 MM; STYLE: SPLIT; DRAWING NO: BP8004/0 REV 1; I.D. PRE-MACHINED, O.D. +0.02 MM -0.00 MM; FOR MAIN TURBINE GOVERNOR DRIVE WITHIN FRONT PEDESTAL UNIT; WHITE METAL BONDING, 100% ADHESION, BONDING/POROSITY CERTIFICATE TO BE SUPPLIED AT DELIVERY OF EACH BEARING; MATERIAL: METAL WHITE 84; RATING: 3000 RPM	252867	EA	7
192	BEARING, ROLLER: TYPE: TAPER; SUPPL P/N: 30311	30541	EA	5
193	BEARING, ROLLER: TYPE: TAPER; SUPPL P/N: 32217J2; FOR ORBIT PUMP TYPE 8001 (CI EN8HCP) CAPACITY 55M3/HR BY 6 BAR AND 700RPM, ITEM TO BE PACKED AGAINST RUST AND DAMAGE	32007	EA	5
194	BEARING, ROLLER: TYPE: TAPER; SUPPL P/N: 5475+95927D	30543	EA	5
195	BEARING, ROLLER: TYPE: TAPER; SUPPL P/N: 71450+71750	30358	EA	5
196	BEARING, ROLLER: WIDTH: 175 MM; DRAWING NO: Z1292/13 REV 1; FOR AIR HEATERS, MAIN DRIVE SHAFT, BOILERS 2, 3 & 4, LG 500MM	247226	EA	5
197	BEARING, SLEEVE: INSIDE DIAMETER: 105 MM; OUTSIDE DIAMETER: 210 MM; LENGTH: 195 MM	34471	EA	5
198	BEARING, SLEEVE: TYPE: ADAPTER; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 70 MM; LENGTH: 42 MM; MATERIAL: STL; REFERENCE NO: H310; COMPLETE WITH LOCK NUT	661831	EA	5
199	BEARING, SLEEVE: TYPE: BUSH; INSIDE DIAMETER: 193 MM; OUTSIDE DIAMETER: 223 MM; LENGTH: 229 MM; SUPPL P/N: C/279795; TUF, VISCONITE	33490	EA	5
200	BEARING, SLEEVE: TYPE: BUSH; INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 32 MM; LENGTH: 38 MM; MATERIAL: BRZ; SUPPL P/N: 901118-0049; FOR CAM/ARM ASSEMBLY, BOILER SOOTBLOWERS CONSUMABLE SPARES	31524	EA	5
201	BEARING, SLEEVE: TYPE: CYLINDRICAL SPLIT JOURNAL; INSIDE DIAMETER: 152.4 MM; MATERIAL: WHITE METAL 90 BS.1463 GR.300WA; DRAWING NO. BS.1463 GR300 WA REV.1;	252714	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 26 of 46

	REQUIRED FOR EFP MOTOR, UNIT 2, WHITE METAL BONDING 100% ADHESION, BONDING & POROSITY CERTIFICATE TO BE SUPPLIED WITH EACH BEARING AT DELIVERY			
202	BEARING, SLEEVE: TYPE: ID FAN NDE; MATERIAL: METAL; DRAWING NO: D2894 REV 1; REQUIRED FOR USE ON ID FANS, BOILERS 1, 5 AND 6, 9-1/2 IN SAFL STANDARD, REMETAL	247949	EA	5
203	BEARING, SLEEVE: TYPE: ID FAN, DE; MATERIAL: METAL; DRAWING NO: D2893 REV 1; REQUIRED FOR USE ON ID FANS, BOILERS 1, 5 AND 6, 9-1/2 IN SAFL STANDARD, REMETAL	247948	EA	7
204	BEARING, SLEEVE: TYPE: ID FAN; INSIDE DIAMETER: 241.6 MM; OUTSIDE DIAMETER: 285.8 MM; LENGTH: 228.6 MM; MATERIAL: WHITE METAL; SIZE: 9-1/2 IN	650176	EA	8
205	BEARING, SLEEVE: TYPE: JOURNAL THRUST; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 150 MM; LENGTH: 100 MM; MATERIAL: WHITE METAL; FOR USE ON HIGH LIFT PUMP MOTOR	33697	EA	5
206	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 201 MM; LENGTH: 110 MM; MATERIAL: STL BABBITTED; MODEL NO: HCD6N/8; REFERENCE NO: 2LM3572/01; SPLIT IN HALVES, 100MM TOP AND BOTTOM DRIVE END GEC MOTOR, FRAME SIZE: IK5605, USED AT UNIT 6 B EFP	32243	EA	5
207	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 108 MM; OUTSIDE DIAMETER: 203 MM; LENGTH: 110 MM; MATERIAL: STL BABBITTED; MODEL NO: HCD6N/8; TOP AND BOTTOM NDE GEC MTR	32242	EA	5
208	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 114.32 MM; OUTSIDE DIAMETER: 158.75 MM; MATERIAL: WHITE METAL 90; FOR USE ON UNIT 1 EFP MOTOR (2350 KW, 6.6 KV, 2 POLE), PEDESTAL MOUNTED, DRIVE AND NON DRIVE END, CARRYING CAPACITY OF 3600 KG	240271	EA	5
209	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 320 MM; OUTSIDE DIAMETER: 484 MM; LENGTH: 265 MM; MATERIAL: STL/WHITE METAL; SUPPL P/N: ST73300; NO 01	33620	EA	6
210	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 100 MM; LENGTH: 45 MM; MATERIAL: STL BABBITTED; FOR USE ON GOVERNOR DRIVE GEARBOX ON M.A.N. BROWN BOVERI 200 MW TURBINE	33672	EA	5
211	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 80 MM; OUTSIDE DIAMETER: 105 MM; LENGTH: 75 MM; MATERIAL: STL BABBITTED; SUPPL P/N: 1301-1-310-2-14; FOR USE ON MAIN OIL PUMP ON M.A.N. BROWN BOVERI 200MW TURBINE	33693	EA	5
212	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 84 MM; OUTSIDE DIAMETER: 117 MM; LENGTH: 110 MM; MATERIAL: STL BABBITTED; SUPPL P/N: 423; MODEL NO: HCD6N/8; REFERENCE NO: 2-211-141601; COMPLETE WITH BOTTOM AND TOP DRIVE END HALVES, FOR USE WITH KSB PUMP, RE-METAL CERTIFICATE TO BE SUBMITTED ON DELIVERY	34026	EA	5
213	BEARING, SLEEVE: TYPE: JOURNAL; INSIDE DIAMETER: 85 MM; OUTSIDE DIAMETER: 117 MM; LENGTH: 110 MM; MATERIAL: STL BABBITTED; MODEL NO: HCD6N/8; REFERENCE NO:	34025	EA	10

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: GVL/0883
 1
 Page: 27 of 46

	119-903-017-026; 319-319A; DE COMPLETE WITH TOP AND BOTTOM DRIVE END HALVES, FOR 50 PCT KSB PUMP			
214	BEARING, SLEEVE: TYPE: SPHERICAL; INSIDE DIAMETER: 44.5 MM; OUTSIDE DIAMETER: 71.5 MM; LENGTH: 38 MM; MATERIAL: STL; REFERENCE NO: GEZ112ES; SPLIT, FOR IP STOP VALVE, ROD END	33486	EA	5
215	BEARING, SLEEVE: TYPE: SPLIT; INSIDE DIAMETER: 110 MM; MATERIAL: WHITE METAL 90; DRAWING NO: BS 1463 GR30 0 WA REV 1; REFERENCE NO: BP8057/110; REQUIRED FOR EFF MOTOR, UNIT 1, DESIGN MODIFICATION TO FLOOD LUBE DE & NDE BEARING SLEEVE - BP8057 TO MNF INCLUDING FLOOD OIL, WHITE METAL BONDING 100% ADHESI ON, BONDING & POROSITY CERTIFICATE TO BE SUPPLIED AT DELIVERY OF EACH BEARING	252715	EA	5
216	BEARING, SLEEVE: TYPE: TURBINE; INSIDE DIAMETER: 318 MM; MATERIAL: WHITE METAL 84; SPECIFICATION: GGSS0526 MAY 2001; REFERENCE NO: C42.49200-5802 0; COMPLETE PRE-MACHINED ID. GROUP 4920, ITEM 001	253523	EA	5
217	BEARING, THRUST: INSIDE DIAMETER: 200 MM; OUTSIDE DIAMETER: 419 MM; WIDTH: 100 MM; MATERIAL: STL; DRAWING NO: Z260 REV 1; FOR USE ON AIR HEATERS, BOILERS 2, 3/4, SUPPORT	226694	EA	8
218	BEARING, THRUST: ROLLING ELEMENT: BALL; INSIDE DIAMETER: 17 MM; OUTSIDE DIAMETER: 35 MM; WIDTH: 12 MM; STYLE: OPEN; SUPPL P/N: 51203; FOR LATHE IN WORKSHOP	233616	EA	5
219	BEARING, THRUST: ROLLING ELEMENT: BALL; INSIDE DIAMETER: 20 MM; OUTSIDE DIAMETER: 35 MM; WIDTH: 10 MM; STYLE: OPEN; SUPPL P/N: 51104; FOR UNIT 4 CONDENSER LEVEL CONTROL VALVE: ROW SINGLE	29969	EA	5
220	BEARING, THRUST: ROLLING ELEMENT: BALL; INSIDE DIAMETER: 45 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 45 MM; SUPPL P/N: 3309C3; ROW DOUBLE	31840	EA	5
221	BEARING, THRUST: ROLLING ELEMENT: BALL; SUPPL P/N: 51126	30108	EA	5
222	BEARING, THRUST: ROLLING ELEMENT: BALL; SUPPL P/N: 51128	30193	EA	5
223	BEARING, THRUST: ROLLING ELEMENT: NEEDLE; INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 100 MM; WIDTH: 30 MM; HEIGHT: 18 MM; STYLE: OPEN; CONFIGURATION: WAFER; MATERIAL: STL; CAGE MATERIAL: STL; MANUF P/N: 5113-CENG-THB; SINGLE DIRECTION; 37.5 KILONEWTON; FOR USE ON ATTEMPERATOR SPRAY WATER VALVE REVOLVING NUT, IBI 5113	567975	EA	7
224	BEARING: TYPE: DRIVE END; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 180 MM; STYLE: TAPER SLEEVE; DRAWING NO: WF0 519 REV 0; UNIT 5 DE BEARING RACE; IBI 23122KC3	555674	EA	13

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 28 of 46

225	BEARING: TYPE: NON DRIVE END; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 170 MM; DRAWING NO: WF0 519 REV 0 ITEM 0; FOR USE ON UNIT 5 PA FAN; NON DRIVE END BEARING RACE: CW TAPER RACE: IBI 23022K3	552741	EA	15
226	BUSH, TAPER LOCK: BORE DIAMETER: 1 IN; SERIES: 2517; MATERIAL: STL; SUPPLIER NOTE: THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED	34930	EA	6
227	BUSH, TAPER LOCK: BORE DIAMETER: 100 MM; SERIES: 4535; MATERIAL: CS; FOR USE ON ASH PUMP	227260	EA	7
228	BUSH, TAPER LOCK: BORE DIAMETER: 120 MM; SERIES: 4535; MATERIAL: STL; REQUIRED FOR USE ON ASH PLANT; ASH PUMP DRIVE COUPLING	255963	EA	6
229	BUSH, TAPER LOCK: BORE DIAMETER: 125 MM; SERIES: 5050; MATERIAL: STL; SUPPLIER NOTE: THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED	46973	EA	5
230	BUSH, TAPER LOCK: BORE DIAMETER: 16 MM; SERIES: 1610; 37HX122D	46083	EA	5
231	BUSH, TAPER LOCK: BORE DIAMETER: 25 MM; SERIES: 1610; MATERIAL: STL	53486	EA	5
232	BUSH, TAPER LOCK: BORE DIAMETER: 28 MM; SERIES: 1610; MATERIAL: STL; SPECIFICATION: ISO 9001-2008; MANUF P/N: 1610-28	25434	EA	5
233	BUSH, TAPER LOCK: BORE DIAMETER: 32 MM; MATERIAL: STL; MODEL NO: 2517-32	240428	EA	5
234	BUSH, TAPER LOCK: BORE DIAMETER: 38 MM; SERIES: 2012; MATERIAL: STL	112866	EA	5
235	BUSH, TAPER LOCK: BORE DIAMETER: 38 MM; SERIES: 2517; MATERIAL: STL	113023	EA	6
236	BUSH, TAPER LOCK: BORE DIAMETER: 50 MM; SERIES: 2517; MATERIAL: STL	53488	EA	5
237	BUSH, TAPER LOCK: BORE DIAMETER: 60 MM; SERIES: 3020; MATERIAL: STL; SPECIFICATION: ISO 9001-2008; MANUF P/N: 3020-60; REFERENCE NO: 3020; KEYWAY: 18MM WIDTH, 4.4MM DEPTH, 108MM NOMINAL OD AT LARGE END OF TAPER	34244	EA	6
238	BUSH, TAPER LOCK: BORE DIAMETER: 80 MM; SERIES: 4535; MATERIAL: CS; FOR USE ON ASH PUMP	227259	EA	15
239	BUSH, TAPER LOCK: BORE DIAMETER: 95 MM; SERIES: 4545; MATERIAL: CARBON STEEL; 45X45X95; FOR USE ON ASH CRUSHERS	565621	EA	5
240	BUSH: APPLICATION: FINAL DRIVE; DGR 24DU16	36394	EA	5
241	BUSH: INSIDE DIAMETER: 100 MM; FOR USE ON ASH CRUSHER, 3535 X 24/4	227261	EA	6
242	BUSH: INSIDE DIAMETER: 11 MM; OUTSIDE DIAMETER: 13 MM; LENGTH: 20 MM; MATERIAL: RUBBER	113335	EA	5
243	BUSH: INSIDE DIAMETER: 13 MM; OUTSIDE DIAMETER: 22 MM; LENGTH: 19 MM; MATERIAL: RUBBER NATURAL; 12MM HOLE SIZE	112165	EA	5
244	BUSH: INSIDE DIAMETER: 13 MM; OUTSIDE DIAMETER: 25 MM; LENGTH: 29 MM; MATERIAL: PU; APPLICATION: COUPLING	112160	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page: GVL/0883 1 29 of 46

245	BUSH: INSIDE DIAMETER: 16 MM; OUTSIDE DIAMETER: 29 MM; LENGTH: 24 MM; MATERIAL: RUBBER NATURAL; APPLICATION: COUPLING	112149	EA	5
246	BUSH: INSIDE DIAMETER: 16 MM; OUTSIDE DIAMETER: 32 MM; LENGTH: 38 MM; MATERIAL: RUBBER	112147	EA	5
247	BUSH: INSIDE DIAMETER: 19 MM; OUTSIDE DIAMETER: 32 MM; LENGTH: 32 MM; MATERIAL: RUBBER	112159	EA	5
248	BUSH: INSIDE DIAMETER: 19 MM; OUTSIDE DIAMETER: 35 MM; LENGTH: 32 MM; MATERIAL: RUBBER	112152	EA	5
249	BUSH: INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 31 MM; LENGTH: 28 MM; APPLICATION: STEAM CONTROL; GM	34480	EA	5
250	BUSH: INSIDE DIAMETER: 25 MM; OUTSIDE DIAMETER: 32 MM; LENGTH: 32 MM; APPLICATION: STEAM CONTROL; GM	34479	EA	5
251	BUSH: INSIDE DIAMETER: 32 MM; OUTSIDE DIAMETER: 45 MM; LENGTH: 58 MM; MATERIAL: RUBBER	113296	EA	5
252	BUSH: INSIDE DIAMETER: 32 MM; OUTSIDE DIAMETER: 78 MM; LENGTH: 70 MM; MATERIAL: RUBBER	112158	EA	9
253	BUSH: INSIDE DIAMETER: 55 MM; OUTSIDE DIAMETER: 60 MM; LENGTH: 45 MM; ITEM 148	33643	EA	5
254	BUSH: INSIDE DIAMETER: 83 MM; OUTSIDE DIAMETER: 121 MM; LENGTH: 146 MM; MATERIAL: RUBBER	113295	EA	5
255	BUSH: OUTSIDE DIAMETER: 1-1/4 IN; MATERIAL: BRZ OILITE	36395	EA	5
256	BUSH: TYPE: GLACIER; INSIDE DIAMETER: 40 MM; OUTSIDE DIAMETER: 45 MM; LENGTH: 41 MM; MATERIAL: STL; APPLICATION: FD FAN; DRAWING NO: D2866 REV 1; BOILERS 1 TO 4 AND 6, OUTER VANE SPINDLE	247371	EA	5
257	BUSH: TYPE: SLEEVE; INSIDE DIAMETER: 112 MM; OUTSIDE DIAMETER: 132 MM; LENGTH: 227 MM; MATERIAL: STL	33609	EA	11
258	BUSHING: MATERIAL: 41055; SUPPL P/N: 0207080001; REFERENCE NO: 50566-000-01	243512	EA	7
259	CONE, BEARING: MANUF P/N: 748; AND ROLL; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	29808	EA	5
260	CONE, BEARING: MANUF P/N: 98350; AND ROLL; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30207	EA	5
261	CONE, BEARING: MANUF P/N: HH221449; AND ROLL; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30208	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: 1
 Page: 30 of 46
 GVL/0883

262	31257	EA	5	<p>CONE, BEARING: MANUF P/N: HH926744; AND ROLL; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
263	60268	EA	34	<p>COUPLING, SHAFT FLEXIBLE: BORE DIAMETER: 160 MM; TORQUE: 16 KNM; MATERIAL: STL; SPEED: 2500 RPM; SUPPL P/N: F5050; CENTRE CAP 24MM, COMPLETE WITH TWO TAPER LOCK BUSHES. INSIDE DIAMETER SIDE 1 = 110MM, SIDE 2 = 98MM; LG: 298MM; OD: 410MM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
264	25384	EA	5	<p>COUPLING, SHAFT FLEXIBLE: MATERIAL: NUPEX; 140-140MM TYPE H; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
265	25383	EA	5	<p>COUPLING, SHAFT FLEXIBLE: MATERIAL: NUPEX; 140-180MM TYPE H; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
266	25385	EA	5	<p>COUPLING, SHAFT FLEXIBLE: MATERIAL: NUPEX; 160-180MM TYPE H; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
267	25386	EA	5	<p>COUPLING, SHAFT FLEXIBLE: MATERIAL: NUPEX; 200-180MM TYPE H; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
268	25766	EA	5	<p>COUPLING, SHAFT FLEXIBLE: TAPER LOCK SERIES: 2517; BORE DIAMETER: 55 MM; MATERIAL: STL; REFERENCE NO: F80; COMPRISING OF: 2 X FLANGES; 1 X NATURAL RUBBER TYRE, 2 X BUSHES, SHAFT DIA 55.0MM; LG: 165MM; OD: 80MM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
269	609103	EA	5	<p>COUPLING, SHAFT FLEXIBLE: TYPE: ELASTIC; BORE DIAMETER: 19 MM; TORQUE: 70 NM; MATERIAL: CI; USED ON ELECTRICAL FEED PUMP (EFP) TANK MOTORS; AN ITEM DESIGNED TO ALLOW FOR SLIGHT MISALIGNMENT; CONNECTION TWO SHAFTS; LINEAR AND ANGULAR; TRANSMITTING ROTARY MOTION FROM THE DRIVER TO DRIVEN; SPIDEX 24/32; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).</p>
270	249246	EA	5	<p>COUPLING, SHAFT FLEXIBLE: TYPE: FLUID DRIVE; BORE DIAMETER: 150 X 241.3 MM; FOR BOILERS 2-4 LHR/ID FANS; CONNECTION 1 TO FAN VIA MULTI DISK; CONNECTION 2 TO MOTOR; QUALITY CONTROL CERTIFICATES TO BE SUBMITTED FOR EACH SPARE AND OR MATERIALS ON DELIVERY, IN ACCORDANCE WITH MANUFACTURER QUALITY CONTROL</p>

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

271	PROCEDURE; SIZE: 52 IN; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). COUPLING, SHAFT FLEXIBLE; TYPE: GRID (2090 T10); BORE DIAMETER: 85 X 60 MM; TORQUE: 2309 NM; MATERIAL: STL; SPEED: 1490 RPM; SPECIFICATION: 2090 T 10; HORIZONTAL SPIT; SERIES 2000; MAX DIA 215MM; MAX WIDTH 200MM; BORE MACHINING DEPTH TO BE THE SAME FOR BOTH BORE DIAMETERS; MOTOR SIDE/DRIVING SHAFT DIAMETER: 85 MM; GEARBOX SIDE/DRIVEN SHAFT DIAMETER: 60 MM; MAX COUPLING DIAMETER: 215 MM; MAX COUPLING WIDTH: 200 MM; BORE MACHINING DEPTH TO BE THE SAME FOR BOTH BORE DIAMETERS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	669433	EA	5	
272	COUPLING, SHAFT FLEXIBLE; TYPE: HEAVY DUTY; MATERIAL: STL; DRAWING NO: Z1294 REV 1; FOR AIR HEATER, SIZE 12 IN, FOR USE ON BOILERS 1 AND 6; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	234675	EA	9	
273	COUPLING, SHAFT FLEXIBLE; TYPE: RIGID DRIVE; BORE DIAMETER: 68 MM; MATERIAL: STL; REFERENCE NO: F80; 215 MM OUTSIDE DIAMETER, 70 MM LENGTH, CONSISTING OF TWO F80F MK3 FENAFLEX 2517 AND ONE FENAFLEX NAT RUBBER TYRE. FENAFLEX; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	26528	EA	5	
274	COUPLING, SHAFT FLEXIBLE; TYPE: TIRE; BORE DIAMETER: 80 MM; MATERIAL: RUBBER/STL; SUPPL P/N: F 80; FOR USE ON DEMIN PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	227250	EA	8	
275	COUPLING, SHAFT FLEXIBLE; TYPE: TIRE; MATERIAL: RUBBER/STL; SUPPL P/N: F 110; SIZE OD 110MM, FOR USE ON SERVICE WATER PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	227251	EA	7	
276	COUPLING, SHAFT FLEXIBLE; TYPE: TIRE; MATERIAL: RUBBER/STL; SUPPL P/N: F 140; SIZE OD 140MM, FOR USE ON ASH WATER RETURN PUMP, ASH AND SLUICE PUMPS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	227248	EA	12	
277	COUPLING, SHAFT FLEXIBLE; TYPE: TIRE; MATERIAL: RUBBER/STL; SUPPL P/N: F 60; FOR USE ON SEAL WATER PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	227338	EA	10	

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

278	COUPLING, SHAFT FLEXIBLE; TYPE: TIRE; MATERIAL: RUBBER/STL; SUPPL P/N: F 90; SIZE OD 90MM, FOR USE ON HOPPER COOLING PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	227249	EA	6
279	COUPLING, SHAFT FLEXIBLE; TYPE: TURBOFLEX 150 DBSE; BORE DIAMETER: 65-63.5 MM; MATERIAL: STL; MODEL NO: D142-6/2AH; 188MM OD X 307MM LG; FOR USE ON STEAM FEED PUMP BETWEEN GEARBOX AND BOOSTER PUMP; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	240427	EA	5
280	COUPLING, SHAFT FLEXIBLE; TYPE: TURBOFLEX 218 DBSE; MATERIAL: STL; MODEL NO: HBS1500-8; PILOT BORED, SIZE: 285MM OD X 472MM LG; FOR USE ON ELECTRIC FEED PUMP BETWEEN PUMP AND MOTOR; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	240424	EA	5
281	COUPLING, SHAFT FLEXIBLE; TYPE: TURBOFLEX 268 DBSE; BORE DIAMETER: 63.5 X 60 MM; MATERIAL: STL; MODEL NO: D102-6/2AH; 156MM OD X 459.3MM LG; FOR USE ON STEAM FEED PUMP BETWEEN PUMP AND GEARBOX; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	240426	EA	5
282	COUPLING, SHAFT FLEXIBLE; TYPE: TURBOFLEX 476 DBSE; BORE DIAMETER: 109.9 X 104.86 MM; MATERIAL: STL; MODEL NO: D232-6/2AH; 304MM OD X 774MM LG; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	240425	EA	5
283	COUPLING, SHAFT FLEXIBLE; TYPE: TURBOFLEX; BORE DIAMETER: 101 X 81 MM; MATERIAL: STL; MODEL NO: HBS1500-8; 276 MM OUTSIDE DIAMETER, 472 MM LENGTH, FOR USE ON 50PST KSB FEED PUMP HCD6N/8, ITEM TO BE PACKED AND PRESERVED AND CLEARLY MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	240298	EA	5
284	COUPLING, SHAFT HALF; TYPE: STD FLANGE; SUPPL P/N: F90B; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	26227	EA	39
285	COUPLING, SHAFT: BORE: 24 MM; MATERIAL: STL; WD 14 MM; FOR AIR HEATERS; BOILER 5 LUBE OIL PUMP	247230	EA	5
286	COUPLING, SHAFT: GRADE: 300WA; DRAWING NO: C2.301.006173 REV 1; FOR I.D.FANS; PROPSHAFT; BOILERS 1, 5/6	247252	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

287	COUPLING, SHAFT: MATERIAL: STL; DRAWING NO: 74/3176 REV 1; FD FAN, BOILERS 1-4/6; SIZE: DIA 2,14 M	247364	EA	6
288	COUPLING, SHAFT: TYPE: FENAFLEX COUPLING F140H WITH TYRE BUT WITHOUT TAPER-LOCK BUSHES; MANUF P/N: 562275	78434	EA	5
289	COUPLING, SHAFT: TYPE: FLUID DRIVE; MATERIAL: ALUMINIUM; SUPPL P/N: 422TVB; FOR USE AS CONVEYOR DRIVE, EACH TV TO INCORPORATE TORQUE LIMITING DELAY FEED CHAMBER WHICH SERVES TO FACILITATE AN EXTENDED TIME DELAYED TORQUE RISE, INCLUDING FIRST OIL FILLING, INPUT COUPLING BORED AND KEYS TO SUIT MOTOR SHAFT, OUTPUT HUB BORED AND KEYS TO SUIT GEARBOX INPUT SHAFT AND TWO FUSIBLE PLUGS	25333	EA	5
290	COUPLING, SHAFT: TYPE: TURBOFLEX; DRAWING NO: C3.354-006133 REV 1; REFERENCE NO: BD902201; FOR I.D.FANS; BOILERS 1, 5/6	247249	EA	7
291	COUPLING: SIZE: OD 400 X WD 230 MM; MATERIAL: STEEL; MODEL NO: 230 - 400; FOR USE ON CONVEYOR 21A AND 21B	226090	EA	6
292	COUPLING: TYPE: CONVEYOR; SIZE: 16 MM; MATERIAL: STAINLESS STEEL; GRADE: 316; CONNECTION 1 SIZE: 16 MM; FOR USE ON CONVEYOR PLANT. FLEXIBLE COUPLING	618873	EA	17
293	COUPLING: TYPE: CROWN PIN; SIZE: 80 MM; MATERIAL: STEEL; SPECIFICATION: EN19; CONNECTION 2: PULLEY; MANUF P/N: CP 120/8; USE ON CONVEYOR 25 A-B, 26 A-B; SOLID COUPLING SIZE 12 INCH GEARBOX AND THE DRIVE PULLEY; WITH THE PILOT HOLE THAT YOU CAN CUT TO A MINIMUM OF 45 MM TO 95 MM HOLE DIAMETER AND WITH EIGHT BOLTS	571211	EA	20
294	COUPLING: TYPE: FLUID DRIVE; SIZE: 487 MM; MATERIAL: ALUMINIUM; SUPPL P/N: 487TVVS HA/BR; 4 X 2MM NOZZLE; FOR FRONT TRANSFER CONVEYORS	211931	EA	7
295	COUPLING: TYPE: FLUID DRIVE; SIZE: OD 420 MM; MATERIAL: ALUMINIUM; SPECIFICATION: 366TVB; CONNECTION 1: GEARBOX; CONNECTION 2: MOTOR SHAFT; CONVEYOR	634184	EA	5
296	COUPLING: TYPE: FLUID DRIVE; SIZE: OD 420 MM; MATERIAL: ALUMINIUM; SUPPL P/N: 366T TVB	226011	EA	7
297	COUPLING: TYPE: PULL ON/OFF; SIZE: ID 410 X OD 430 X LG 180 MM; MATERIAL: MS; TO FIT 406 MM OD TUBE SIZE	57342	EA	5
298	COUPLING: TYPE: SAMPLING LINE; SIZE: 3-12.7 MM; MATERIAL: STAINLESS STEEL; CONNECTION 1 SIZE: 3 MM; CONNECTION 2 SIZE: 12.7 MM; OEM P/N: UCM-M0308N	610125	EA	5
299	COUPLING: TYPE: STUD; SUPPL P/N: 930711-9035; FOR USE ON SOOTBLOWER.	231934	EA	5
300	COVER: TYPE: BEARING END; DIMENSIONS: DIA 7-1/2 IN; MATERIAL: STL; APPLICATION: FD FANS/BOILERS 1-4/6; DRAWING NO: D3798 REV 1; SIROCCO	247370	EA	5
301	COVER: TYPE: BEARING NDE; SUPPL P/N: 44-2; MODEL NO: HPT32-25-4STG; FOR SULZER FEED PUMP	46379	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 34 of 46

302	COVER: TYPE: THRUST BEARING; MATERIAL: STL; SUPPL P/N: 2SA 1063P; MODEL NO: M/P8INX8INX24IN; REFERENCE NO: 24; FOR USE ON 100PCT CONDENSATE EXTRACTION PUMP	239955	EA	5
303	CUP, BEARING: TYPE: SGL; OUTSIDE DIAMETER: 150.09 MM; WIDTH: 36.51 MM; SUPPL P/N: 742; IBI 30852	29968	EA	5
304	CUP, BEARING: TYPE: SGL; OUTSIDE DIAMETER: 168.28 MM; WIDTH: 30.16 MM; SUPPL P/N: TIM 672; REFERENCE NO: 672; TAPERED ROLLER BEARING; IBI 30921	29802	EA	5
305	CUP, BEARING: TYPE: TAPER ROLLER; MANUF P/N: 98788	30143	EA	6
306	CUP, BEARING: TYPE: TAPER ROLLER; MANUF P/N: HH926710	31258	EA	5
307	HOUSING, BEARING UNIT: TYPE: PA FAN DE; BORE: 100 MM; MATERIAL: SS GR 42; BLOCK SIZE: WD 80 X LG 290 MM; BOLT MOUNTINGS: 4; BOLT DIAMETER: 20 MM; SHAPE: CYLINDRICAL; SURFACE TREATMENT: RED OXIDE; WFO 519 DE HOUSING; TYPE KBF; WFO OIL LUBRICATED PLUMBER BLOCK; FOR USE ON UNIT 5 PA FAN DE HOUSING C/W COVERS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	614159	EA	7
308	HOUSING, BEARING UNIT: TYPE: PA FAN NDE; BORE: 100 MM; MATERIAL: SS GR 42; BLOCK SIZE: WD 80 X LG 290 MM; BOLT MOUNTINGS: 4; BOLT DIAMETER: 20 MM; SHAPE: CYLINDRICAL; SURFACE TREATMENT: RED OXIDE; WFO 519 NDE HOUSING TYPE KAL; WFO OIL LUBRICATED PLUMBER BLOCK; FOR USE ON UNIT 5 PA FAN NDE BEARING HOUSING C/W; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	614155	EA	7
309	HOUSING, BEARING UNIT: TYPE: PILLW BLOCK; MATERIAL: CI; REFERENCE NO: SNA518; SIZE 140MM WD X 340MM LG X 195MM HT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	35016	EA	37
310	HOUSING, BEARING UNIT: TYPE: PILLW; BORE: 100 MM; MATERIAL: CI; BLOCK SIZE: DIA 100 MM; BOLT MOUNTINGS: 2; BOLT DIAMETER: M24; SUPPL P/N: SNA522/619; WITH TWO LABARYNTH SEALS; SHAFT HEIGHT: 125MM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225516	EA	15
311	HOUSING, BEARING UNIT: TYPE: PILLW; BORE: ID 100 MM; MATERIAL: CI; SUPPL P/N: SNH511; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225518	EA	5
312	HOUSING, BEARING UNIT: TYPE: PILLW; BORE: ID 150 MM; MATERIAL: CI; SUPPL P/N: SNA517; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225514	EA	14

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page: GVL/0883 1 35 of 46

313	HOUSING, BEARING UNIT: TYPE: PILLOW; BORE: ID 160 MM; MATERIAL: CI; SUPPL P/N: SNA515; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225511	EA	35
314	HOUSING, BEARING UNIT: TYPE: PILLOW; BORE: ID 180 MM; MATERIAL: CI; SUPPL P/N: SNH520; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225515	EA	14
315	HOUSING, BEARING UNIT: TYPE: PILLOW; BORE: ID 230 MM; MATERIAL: CI; SUPPL P/N: SNH526; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225517	EA	6
316	HOUSING, BEARING UNIT: TYPE: PILLOW; BORE: ID 290 MM; MATERIAL: CI; SUPPL P/N: SNH532; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	225547	EA	9
317	HOUSING, MECHANICAL DRIVE: TYPE: AIR SEAL; DIMENSIONS: OD 400 X WD 65 MM; MATERIAL: CI; APPLICATION: MILL LOADING ARM UNIT 1-4/6; C/W BOLTS AND NUTS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	243210	EA	5
318	INSERT, FLEXIBLE COUPLING: TYPE: FLEXIBLE COUPLING; SIZE: 38 MM; MATERIAL: POLYMER; FOR USE AT CONVEYOR PLANT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	618874	EA	5
319	LINER: TYPE: BEARING DE; DIMENSIONS: ID 105 X OD 186 X TH 60 MM; MATERIAL: STL; APPLICATION: FEED PUMP; MODEL NO: HPT32-25-4STG; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	34508	EA	5
320	LINER: TYPE: BEARING NDE; DIMENSIONS: ID 95 X OD 122 X THK 60 MM; MATERIAL: STL; APPLICATION: FEED PUMP; MODEL NO: HPT32-25-4STG; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	34509	EA	5
321	PULLEY, V BELT: BELT TYPE: 22N; SPC; OUTSIDE DIAMETER: 315 MM; GROOVES: 8; MATERIAL: CAST IRON; TAPER LOCK SERIES: 4040; PULLEY TO BE BALANCED	528684	EA	5
322	PULLEY, V BELT: BELT TYPE: 22N; SPC; OUTSIDE DIAMETER: 355 MM; GROOVES: 8; MATERIAL: CAST IRON; TAPER LOCK SERIES: 4545; PULLEY TO BE DYNAMIC BALANCED	528682	EA	7
323	PULLEY, V BELT: BELT TYPE: SPB; BORE: 108 MM; OUTSIDE DIAMETER: 315 MM; GROOVES: 3; MATERIAL: STEEL; TAPER LOCK SERIES: 3020; 3020 SERIES; FOR USE AT EFFLUENT PLANT	584215	EA	10

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

324	PULLEY, V BELT: BELT TYPE: SPC; OUTSIDE DIAMETER: 1.045 M; GROOVES: 5; MATERIAL: STL; FOR USE ON ASH CRUSHER FLY WHEEL; BELT CLASS: SPC9000	227255	EA	5
325	PULLEY, V BELT: BELT TYPE: SPC; OUTSIDE DIAMETER: 210 MM; GROOVES: 5; MATERIAL: STL; FOR USE ON ASH CRUSHERS MOTOR; BELT CLASS: SPC9000	227254	EA	15
326	PULLEY, V BELT: BELT TYPE: SPC; OUTSIDE DIAMETER: 240 MM; GROOVES: 8; MATERIAL: STL; FOR USE ON ASH PUMP; BELT CLASS: SPC6700	227258	EA	5
327	PULLEY, V BELT: BELT TYPE: SPC; OUTSIDE DIAMETER: 630 MM; GROOVES: 8; MATERIAL: CI; TAPER LOCK SERIES: 6050; WIDTH 213 MM; WD 8.213 MM	253161	EA	22
328	PULLEY, V BELT: BORE: 120 MM; OUTSIDE DIAMETER: 277 MM; GROOVES: 8; MATERIAL: CI; PITCH DIAMETER: 265 MM; SLURRY PUMPS	27267	EA	5
329	PULLEY, V BELT: BORE: 120 MM; OUTSIDE DIAMETER: 312 MM; GROOVES: 8; MATERIAL: CI; PITCH DIAMETER: 300 MM; SLURRY PUMPS	27268	EA	5
330	PULLEY, V BELT: BORE: 120 MM; OUTSIDE DIAMETER: 347 MM; GROOVES: 8; MATERIAL: CI; PITCH DIAMETER: 335 MM; SLURRY PUMPS	27269	EA	7
331	PULLEY, V BELT: BORE: 120 MM; OUTSIDE DIAMETER: 367 MM; GROOVES: 8; MATERIAL: CI; PITCH DIAMETER: 355 MM; SLURRY PUMPS	27270	EA	5
332	PULLEY, V BELT: BORE: 120 MM; OUTSIDE DIAMETER: 387 MM; GROOVES: 8; MATERIAL: CI; PITCH DIAMETER: 375 MM; SLURRY PUMPS	27271	EA	5
333	PULLEY: TYPE: IDLER; DIAMETER: 150 MM; MATERIAL: RUBBER; GROOVE: 1; WIDTH: 1250 MM; SPECIFICATION: BP1150; TO BE USED AT CONVEYOR BELT, STORAGE: INDOORS	621054	EA	11
334	PULLEY: TYPE: SPC; DIAMETER: 310 MM; MATERIAL: CAST STEEL; GROOVE: 8; WIDTH: 213 MM; 300MM SPC WEDGE BELT PULLEY; FOR USE ON PUMPS	565626	EA	13
335	RETAINER: TYPE: BEARING; SUPPL P/N: 323452-1122; SOOTBLOWERS, FOR ITEM 111 LANCE DRIVE ASSEMBLY	231965	EA	5
336	RETAINER: TYPE: SEAL; DIMENSIONS: ID 92 X OD 200 MM; MATERIAL: ASTM A36; SUPPL P/N: 033-047-01; FOR USE ON MIGI RAPPER, BOOT; MATERIAL 5 MM HOT ROLL PLATE	232795	EA	5
337	RING: TYPE: COUPLING; INSIDE DIAMETER: 230 MM; OUTSIDE DIAMETER: 250 MM; WIDTH: 25 MM; MATERIAL: RUBBER; TO FIT 219MM OD PIPING; JOHNSON VIKING CP	26665	EA	5
338	RING: TYPE: NDE BEARING; INSIDE DIAMETER: 160 MM; OUTSIDE DIAMETER: 170 MM; WIDTH: 8 MM; MATERIAL: MILD STEEL; APPLICATION: PA FAN	528710	EA	5
339	SCRAPER: BELT: TYPE: HEAD PULLEY; DIMENSIONS: 150 MM; MATERIAL: RUBBER/STL; REFERENCE NO: 1/E901TW1050; FOR 1050MM CONVEYOR, CW P/U; BLADES; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	231596	EA	20
340	SEAL, LABYRINTH: APPLICATION: BOILER 5; DRAWING NO: QR208-85 REV 1; FOR USE ON INNER AIR HEATER	226647	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 37 of 46

341	SEAL, LABYRINTH: DIMENSIONS: DIA 505 X THK 51 MM; APPLICATION: HP TURBINE DIAPHRAGMS 2/7; OEM P/N: 2940-080, OEM: GE STEAM POWER SERVICE; DRAWING NO: E42.29450-7024 REV 1; (8) SEGMENTS	247183	EA	5
342	SEAL, LABYRINTH: DIMENSIONS: DIA 610 X THK 51 MM; APPLICATION: HP TURBINE DIAPHRAGMS 8/9; DRAWING NO: E42.29450-7025 REV 1; GROUP NO.2 940, IN 8 SEGMENTS	247184	EA	5
343	SEAL, LABYRINTH: DIMENSIONS: DIA 680 X THK 47 MM; APPLICATION: HP TURBINE DIAPHRAGMS 10/11; OEM P/N: 2940-100, OEM: GE STEAM POWER SERVICE; DRAWING NO: E42.29450-8019 REV 1; (8) SEGMENTS	247181	EA	5
344	SEAL, LABYRINTH: DIMENSIONS: DIA 760 X THK 55 MM; APPLICATION: HP TURBINE DIAPHRAGMS 12/13; OEM P/N: 2940-110, OEM: GE STEAM POWER SERVICE; DRAWING NO: E42.29450-8020 REV 1; (8) SEGMENTS; FOR MORE INFORMATION CONTACT W.BOTHA ON 0177798812	247182	EA	5
345	SEAL, LABYRINTH: DIMENSIONS: DIA 900 X THK 45 MM; APPLICATION: HP TURBINE DIAPHRAGMS 17/18; DRAWING NO: E42.29450-8008 REV 1; GROUP NO .2940, I.D.WITH 3 MM UNDERSIZE, RING IN 8 SEGMENTS	247187	EA	5
346	SEAL, LABYRINTH: TYPE: GLAND; DIMENSIONS: DIA 400 X THK 53 MM; APPLICATION: HP TURBINE; DRAWING NO: E42.29450-5019 REV 1; GROUP NO.2 940, IN 6 SEGMENTS	247151	EA	5
347	SEAL, LABYRINTH: TYPE: GLAND; DIMENSIONS: DIA 400 X THK 54 MM; APPLICATION: HP TURBINE; DRAWING NO: E42.29450-5011 REV 1; GROUP NO.2 940, IN 6 SEGMENTS	247152	EA	5
348	SEAL, LABYRINTH: TYPE: GLAND; DIMENSIONS: DIA 450 X THK 59 MM; APPLICATION: HP TURBINE; DRAWING NO: E42.29450-6015 REV 1; GROUP NO.2 940, IN 6 SEGMENTS	247149	EA	5
349	SEAL, LABYRINTH: TYPE: GLAND; DIMENSIONS: DIA 680 X THK 57 MM; APPLICATION: HP TURBINE; DRAWING NO: E42.29450-8018 REV 1; GROUP NO.2 940, IN 8 SEGMENTS	247150	EA	5
350	SEAL, LABYRINTH: TYPE: RING; DIMENSIONS: DIA 400 X THK 39 MM; DRAWING NO: E42.29450 - 5026 REV 1; REQUIRED FOR HP GLAND, GROUP 2940, IN 6 SEGMENTS	241387	EA	5
351	SEAL, LABYRINTH: TYPE: RING; DIMENSIONS: DIA 850 X THK 55 MM; APPLICATION: HP TURBINE DIAPHRAGMS 14/15; OEM P/N: 2940-120, OEM: GE STEAM POWER SERVICE; DRAWING NO: E42.29450-8021 REV 1; (8) SEGMENTS	247186	EA	5
352	SEAL, LABYRINTH: TYPE: RING; MATERIAL: RUBBER; SUPPL P/N: 328; WATER FLINGER, REQUIRED FOR 50PCT EFP, PREVENT WATER INGRESS	240274	EA	5
353	SEAL, OIL: TYPE: BEARING; DRAWING NO: 100 WIDE RANGE 5290 REV 1; REQUIRED FOR USE ON PA FANS; OIL LEVEL GAUGE; BOILERS 1 TO 4 & 6	247386	EA	5
354	SEAL, RING: INSIDE DIAMETER: 115 MM; MATERIAL: RUBBER; APPLICATION: BEARING; SUPPL P/N: TSN526A	225523	EA	5
355	SEAL, RING: INSIDE DIAMETER: 140 MM; MATERIAL: RUBBER; APPLICATION: BEARING; SUPPL P/N: TSN532A	225524	EA	9

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 38 of 46

356	SEAL, RING: INSIDE DIAMETER: 65 MM; MATERIAL: RUBBER; APPLICATION: BEARING; SUPPL P/N: TSN515A	225519	EA	8
357	SEAL, RING: INSIDE DIAMETER: 80 MM; MATERIAL: RUBBER; APPLICATION: BEARING; SUPPL P/N: TSN518A	225546	EA	5
358	SEAL, RING: INSIDE DIAMETER: 90 MM; MATERIAL: RUBBER; APPLICATION: BEARING; SUPPL P/N: TSN520A	225521	EA	7
359	SEAL, RING: OUTSIDE DIAMETER: 260 MM; THICKNESS: 47 MM; DRAWING NO: E42.29450-0002 REV 1; REQUIRED FOR BFPT SHAFT REAR GLAND, GROUP 2940, IN 6 SEGMENTS	240951	EA	5
360	SEAL, RING: OUTSIDE DIAMETER: 320 MM; THICKNESS: 59 MM; DRAWING NO: E42.29450-30 REV 1; REQUIRED FOR BFPT SHAFT FRONT GLAND, GROUP 2940, IN 6 SEGMENTS	240949	EA	5
361	SEAL, RING: TYPE: BEARING; INSIDE DIAMETER: 100 MM; MATERIAL: RUBBER; SUPPL P/N: TSN522A	225522	EA	5
362	SEAL, RING: TYPE: BFPT SHAFT REAR GLAND; OUTSIDE DIAMETER: 320 MM; THICKNESS: 47 MM; DRAWING NO: E42.29450-0002 REV 1; GROUP 2940, IN 6 SEGMENTS	240950	EA	5
363	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 110 MM; THICKNESS: 12 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256249	EA	5
364	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 105 MM; OUTSIDE DIAMETER: 120 MM; THICKNESS: 13 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256250	EA	5
365	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 110 MM; OUTSIDE DIAMETER: 120 MM; THICKNESS: 13 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256251	EA	5
366	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 155 MM; OUTSIDE DIAMETER: 165 MM; THICKNESS: 6 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256254	EA	5
367	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 32 MM; OUTSIDE DIAMETER: 48 MM; THICKNESS: 10 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256248	EA	13
368	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 32 MM; OUTSIDE DIAMETER: 48 MM; THICKNESS: 8 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256247	EA	31
369	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 70 MM; OUTSIDE DIAMETER: 80 MM; THICKNESS: 12 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256253	EA	13
370	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 90 MM; OUTSIDE DIAMETER: 100 MM; THICKNESS: 100 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256252	EA	5
371	SEAL, RING: TYPE: PRESSURE; INSIDE DIAMETER: 95 MM; OUTSIDE DIAMETER: 105 MM; THICKNESS: 12 MM; MATERIAL: GRAPHITE; APPLICATION: VALVE	256255	EA	5
372	SEAL, RING: TYPE: TRACK; REFERENCE NO: ITEM 4; FOR 8.5E BALL MILL ROTATING THROAT ASSEMBLY	230414	EA	110

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

373	SEAL, RING; TYPE: V RING; INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 76 MM; THICKNESS: 6 MM; MATERIAL: RUBBER; REFERENCE NO: TSNA511A; TYPE CAP, FOR USE WITH PLUMMER BLOCK HOUSING	97618	EA	5
374	SEAL, RING; TYPE: V RING; INSIDE DIAMETER: 68 MM; OUTSIDE DIAMETER: 110 MM; THICKNESS: 6 MM; MATERIAL: RUBBER; APPLICATION: PLUMMER BLOCK; SUPPL P/N: TSNA517A	98974	EA	5
375	SEAL, RING; TYPE: WELDED; FOR 250NB RP64	102277	EA	5
376	SEAL; DIMENSIONS: OD 30 X WD 1,1 MM; MATERIAL: GLASS FIBER; TADPOLE; 30M ROLL WITH 60MM TAIL	238630	EA	23
377	SEAL; MATERIAL: VITON; APPLICATION: CARTRIDGE VALVE; SPECIFICATION: 297992-26; MANUF P/N: 5161-368; 202-00-003; DRAWING NO: NG50 REV 1; B42.51600-0187 REV 0; REFERENCE NO: SZ50015187; SET, (4) DIA 34.52 X THK 3.53, (3) DIA 20.29 X 2.62; NG16; HYDRAULIC; SIZE RANGE: IMPERIAL	244700	EA	5
378	SEAL; TYPE: BEARING; DIMENSIONS: WD 120 X LG 150 X THK 12 MM; MATERIAL: VITON A; APPLICATION: PA FAN; REFERENCE NO: WFO 519; DE VITON SEAL NON SPLIT	528689	EA	5
379	SEAL; TYPE: DOUBLE LIP, PREFORMED; DIMENSIONS: ID 355 X OD 375 X THK 48 MM; MATERIAL: GRAPHITE GR NUCLEAR; APPLICATION: TURBINE PLANT UNITS 2/4 FINAL STEAM INLET STRAINERS; 45 DEGREE ANGLE	244220	EA	7
380	SEAL; TYPE: SEALING; DIMENSIONS: ID 184 X OD 203 X HT 47 MM; MATERIAL: 4130/42; APPLICATION: VALVE; SUPPL P/N: 021305001; REFERENCE NO: 50566-000-01	243502	EA	7
381	SEAL; TYPE: SET; DIMENSIONS: 19.2 X 3 MM; MATERIAL: VITON; APPLICATION: CARTRIDGE VALVE; OEM P/N: 7161-248, OEM: GE STEAM POWER SERVICE; 5161-367, OEM: GE STEAM POWER SERVICE; DRAWING NO: A42.71600-0164 REV 0; B42.51600-0187 REV 0; NG50 REV 1; REFERENCE NO: SZ50013433; SZ50013214; 2 WAY SET NG 16; HP ESV SERVO MOTOR	244699	EA	5
382	SEAL; TYPE: SHAFT; DIMENSIONS: DIA 54 MM; MATERIAL: KLINGERITE; APPLICATION: AIR FAN UNITS 1/2/3/4/6; DRAWING NO: F29.026.036/1 REV 1; UNITS 1, 2, 3, 4 AND 6	247292	EA	5
383	SEAL; TYPE: SHAFT; DIMENSIONS: ID 75 X OD 190 X THK 3 MM; MATERIAL: KLINGERITE; APPLICATION: AIR FAN; DRAWING NO: A1.244.1000-03 REV 1; UNIT 5	247290	EA	5
384	SEAL; TYPE: TAPER; DIMENSIONS: ID (40 X 105) X LG 190 MM; MATERIAL: RUBBER; APPLICATION: BOOT; FOR USE ON PRECIPITATORS, MIGI RAPPER	234041	EA	5
385	SEAL; TYPE: THROAT; APPLICATION: AIR HEATER; 1 SET = 32	102264	EA	5
386	SEAL; TYPE: VALVE; MATERIAL: POLYMER; EPDM; APPLICATION: CEMENCO VON ROLL T1-T2 BUTTERFLY VALVES DN 1400/180 KPA UNIT 1-6	255089	M	5
387	SEAT, BEARING; DIMENSIONS: ID 515 X OD 635 X THK 60 MM; MATERIAL: CAST IRON; TYPE: SPHERICAL; MANUF P/N: M949; DRAWING NO: Z560 REV 0; FOR USE ON AIR HEATER SUPPORT BEARING	563339	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 40 of 46

388	SEAT, BEARING; DIMENSIONS: ID 60 X OD 82 X THK 8 MM; MATERIAL: STL; SUPPL P/N: U308; FOR USE ON MEDIUM TYPE DOUBLE THRUST BALL BEARING; WITH SPHERED HOUSING WASHERS; 5 RINGS PER SET	19005	EA	5
389	SET: APPLICATION: COUPLING; MATERIAL: STL; DRAWING NO: C3.014.006208 REV 0 ITEM 0; REFERENCE NO: STH 2110 LEF	552752	EA	5
390	SHAFT, PROPELLER; TYPE: DRIVE; LENGTH: 2.002 M; CONNECTION 1: COUPLING; CONNECTION 2: 2 KEYS; APPLICATION: BUFFALO FEEDER; SPECIFICATION: 521-1382-02; SUPPL P/N: 52-1614-1S; DRAWING NO: 52-A1614 -1S REV 1; CONSISTS OF: DRIVE END HOUSING 30-45-032, NON DRIVE END HOUSING 45-361-4A	255010	EA	8
391	SHAFT; TYPE: JOCKEY PULLEY; LENGTH: 640 MM; MATERIAL: EN57; END 1 SIZE: 100 MM; END 2 SIZE: 100 MM; DRAWING NO: 0.19/46390 REV 0; FOR USE ON ASH PUMPS AT ASH PLANT	563343	EA	8
392	SHAFT; TYPE: PULLEY DRIVE; LENGTH: 870 MM; MATERIAL: EN57; END 1 SIZE: 80 MM; END 2 SIZE: 80 MM; DRAWING NO: 0.19/46388 REV 0; FOR USE ON ASH PUMP BOTTOM DRIVE PULLEY	563341	EA	9
393	SLEEVE, ADAPTOR; LENGTH: 110 MM; MATERIAL: STL; SUPPL P/N: H3124; FOR USE ON ASH PLANT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	237855	EA	47
394	SLEEVE, ADAPTOR; MATERIAL: STL; SUPPL P/N: H318; SIZE 80MM; FOR USE ON ASH PLANT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	237856	EA	9
395	SLEEVE, ADAPTOR; SUPPL P/N: AHX2324; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30173	EA	5
396	SLEEVE, ADAPTOR; TYPE: BEARING; MATERIAL: STL; SUPPL P/N: HE317; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30049	EA	6
397	SLEEVE, ADAPTOR; TYPE: BEARING; SHAFT SIZE: 100 MM; LENGTH: 63 MM; MATERIAL: STEEL; SUPPL P/N: HE222; 115 MM OD; 83.3 TAPER PER METER IN MM; 1:12 ON DIA, 4 INCH BORE DIAMETER IMPERIAL SHAFT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30034	EA	9
398	SLEEVE, ADAPTOR; TYPE: BEARING; SHAFT SIZE: 100 MM; LENGTH: 77 MM; MATERIAL: STEEL; SUPPL P/N: H322; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; SIZE 116.5 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING	30305	EA	30

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

	THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).			
399	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 100 MM; LENGTH: 77 MM; MATERIAL: STEEL; SUPPL P/N: HE322; SIZE 145 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30213	EA	5
400	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 110 MM; MATERIAL: STEEL; SUPPL P/N: 3124; REFERENCE NO: 1028-721; 83.3 TAPER PER METRE IN MM 1:12 ON DIA 50 MM BORE DIA; SIZE 125 MM OD X 90 MM HT; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32090	EA	5
401	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 114 MM; LENGTH: 93 MM; MATERIAL: STEEL; SUPPL P/N: HE3126; 134 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30175	EA	5
402	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 115 MM; LENGTH: 92 MM; MATERIAL: STEEL; SUPPL P/N: H3126; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; SIZE 165 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30307	EA	5
403	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 127 MM; LENGTH: 97 MM; MATERIAL: STEEL; SUPPL P/N: HE3128; SIZE 145 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30174	EA	5
404	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 140 MM; LENGTH: 118 MM; MATERIAL: STEEL; SUPPL P/N: HE3132; SIZE 166 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30214	EA	5
405	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 140 MM; LENGTH: 119 MM; MATERIAL: STEEL; SUPPL P/N: H3132; 210 MM OD; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PACKED AND MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30309	EA	11
406	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 25 MM; LENGTH: 27 MM; MATERIAL: STEEL; SUPPL P/N: H206; REFERENCE NO: H206; 32 MM OD; 83.3 TAPER PER METRE IN MM 1:12 ON DIA; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30221	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

407	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 30 MM; LENGTH: 29 MM; MATERIAL: STEEL; SUPPL P/N: H207; REFERENCE NO: H207; 37 MM OD; 83.3 TAPER PER METRE IN MM, 1:12 ON DIA; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30134	EA	5
408	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 38 MM; LENGTH: 37 MM; MATERIAL: STEEL; SUPPL P/N: HE209; OD 46 MM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30210	EA	5
409	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 40 MM; LENGTH: 33 MM; MATERIAL: STEEL; REFERENCE NO: H209; 83.3 TAPER PER METRE IN MM 1:12 SIZE 48 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30335	EA	7
410	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 40 MM; LENGTH: 39 MM; MATERIAL: STEEL; SUPPL P/N: H309; 47 MM OD, 45 MM OUTSIDE DIAMETER; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	32096	EA	5
411	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 45 MM; LENGTH: 50 MM; MATERIAL: STEEL; REFERENCE NO: AJX2310; 55 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30035	EA	5
412	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 50 MM; LENGTH: 37 MM; MATERIAL: STEEL; SUPPL P/N: H211; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; SIZE 56.5 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30299	EA	5
413	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 50 MM; LENGTH: 45 MM; MATERIAL: STEEL; SUPPL P/N: H311; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30043	EA	5
414	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 50 MM; LENGTH: 54 MM; MATERIAL: STEEL; SUPPL P/N: AHX2311; 60 MM OD; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30297	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 43 of 46

415	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 63 MM; MATERIAL: STEEL; SUPPL P/N: HE215; SIZE 77 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30231	EA	5
416	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 63.5 MM; LENGTH: 55 MM; MATERIAL: STEEL; SUPPL P/N: HE315; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30046	EA	5
417	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 65 MM; LENGTH: 55 MM; MATERIAL: STEEL; SUPPL P/N: H315; 98 MM OD; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; CAMDEN SKF BRAND ONLY; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30304	EA	56
418	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 70 MM; LENGTH: 59 MM; MATERIAL: STEEL; SUPPL P/N: H316; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PACKED AND MARKED; SIZE 83 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30140	EA	6
419	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 75 MM; LENGTH: 63 MM; MATERIAL: STEEL; SUPPL P/N: H317; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; SIZE 110 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30048	EA	12
420	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 77 MM; LENGTH: 55 MM; MATERIAL: STEEL; SUPPL P/N: HE217; REFERENCE NO: HE 217; 85 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30032	EA	5
421	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 80 MM; LENGTH: 65 MM; MATERIAL: STEEL; SUPPL P/N: H318; OD 90 MM; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30141	EA	22
422	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 83 MM; LENGTH: 65 MM; MATERIAL: STEEL; REFERENCE NO: HE318; SIZE 94 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30142	EA	15
423	SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 89 MM; LENGTH: 58 MM; MATERIAL: STEEL; SUPPL P/N: HE220; 83.3 TAPER PER METRE IN MM 1:2 ON DIAMETER; 105 MM OD, 165	30033	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
GVL/0883 1 44 of 46

424	MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE). SLEEVE, ADAPTOR: TYPE: BEARING; SHAFT SIZE: 90 MM; LENGTH: 71 MM; MATERIAL: STEEL; SUPPL P/N: H320; SUPPLIER NOTE - THE ITEM MUST BE ORIGINAL PROTECTIVE PACKED AND MARKED; SIZE 130 MM OD; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	30050	EA	13		
425	SLEEVE, COUPLING: TYPE: CONVEYOR; DIMENSIONS: LG 543 MM; MATERIAL: EN8; MANUF P/N: E601023BIBSL/01; BRAKE DRUM SLEEVE; FOR USE ON CONVEYOR 24A-C FLUID COUPLING	569012	EA	5		
426	SLEEVE, SHAFT: TYPE: PA FAN BEARING; INSIDE DIAMETER: 100 MM; OUTSIDE DIAMETER: 145 MM; LENGTH: 10 MM; MATERIAL: STEEL; GRADE: 300WA SABS	606806	EA	5		
427	SLEEVE, SHAFT: TYPE: PUMP; INSIDE DIAMETER: 114 MM; OUTSIDE DIAMETER: 130 MM; LENGTH: 261 MM; MATERIAL: SS GR 316 WC COATED; SUPPL P/N: EN 25 MG; FOR USE ON SLURRY PUMPS IN THE ASH PLANT	240153	EA	40		
428	SLEEVE, SHAFT: TYPE: PUMP; INSIDE DIAMETER: 135 MM; OUTSIDE DIAMETER: 142 MM; LENGTH: 125 MM; MATERIAL: STL; REFERENCE NO: AHX2328	30040	EA	5		
429	SLEEVE: TYPE: BEARING; SUPPL P/N: HE211	30211	EA	5		
430	SLEEVE: TYPE: BEARING; SUPPL P/N: HE2311	30036	EA	5		
431	SLEEVE: TYPE: PUMP DE; SUPPL P/N: 14348P-1; MODEL NO: M/P 4INX5IN; REFERENCE NO: 21; FOR MATHER AND PLATT MEDIVANE AUXILIARY COOLING WATER PUMP	240402	EA	5		
432	SLEEVE: TYPE: PUMP FE; SUPPL P/N: 14348P-1; MODEL NO: M/P 4INX5IN; REFERENCE NO: 22; FOR MATHER AND PLATT MEDIVANE AUXILIARY COOLING WATER PUMP	240403	EA	5		
433	SLEEVE: TYPE: SEAL; DIMENSIONS: ID 300 MM; MATERIAL: RUBBER NATURAL; APPLICATION: KNIFE GATE VALVE IN ASH LINES; SUPPL P/N: SKG-W203-015-0078; REFERENCE NO: P0300CMP-MSR-R	257022	EA	5		
434	SLEEVE: TYPE: SHRINK ADHESIVE; DIMENSIONS: DIA 10 MM X 1 M; REFERENCE NO: CFM0400; GLOBE ELECTRIC	135168	EA	5		
435	SLEEVE: TYPE: THROTTLING; DIMENSIONS: ID 99 X OD 108 X LG 130 MM; MATERIAL: STL; MODEL NO: HCD6N/8; REFERENCE NO: 210; 119-903-017-012; FOR KSB 50PCT BOILER FEED PUMP	47492	EA	5		
436	SPRING: TYPE: SEALING; DIMENSIONS: 5 MM; SUPPL P/N: 917	110524	EA	5		
437	SPRING: TYPE: SEALING; DIMENSIONS: 5 MM; SUPPL P/N: 918	110525	EA	5		
438	STRIP: TYPE: SEALING; DRAWING NO: F42.39453-5801 REV 1; REQUIRED FOR USE ON L P DIAPHRAGMS 16 TO 21; GROUP 3750; 8 PIECE; ITEM 932	253522	M	5		

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

Unique Revision: Page:
 GVL/0883 1 45 of 46

439	STRIP: TYPE: SEALING; WIDTH: 12 MM; THICKNESS: 0.5 MM; MATERIAL: STL; REQUIRED FOR USE ON TURBINE H.P.DIAPHRAGMS 2 TO 15; GROUP NO.3350; ITEM NO 911	247191	M	5
440	STRIP: TYPE: SEALING; WIDTH: 14 MM; LENGTH: 1 M; THICKNESS: 0.5 MM; MATERIAL: STEEL; APPLICATION: ONE SET RINGS: 16 TO 21; GROUP 3750; ITEM 931	253521	M	5
441	TAPE, THREAD: TYPE: SEALING; WIDTH: 10 MM; MATERIAL: PTFE; COLOR: WHITE; REFERENCE NO: PTFE; WITHOUT DISPENSER; THK 0.075 MM	16853	EA	884
442	TROLLEY: TYPE: BALL BEARING ROLLERS; CAPACITY: 50 KG; MANUF P/N: CTBR/620; A COMPLETE SET OF FESTOON TROLLEYS USED ON THE TRIPPER CARS; (FESTOON DIAMOND RAIL TROLLEY BRACKETS); GALVANISED CASTING SIDE SEALED BALL BEARING ROLLERS; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	528690	EA	268
443	WASHER, SEALING: INSIDE DIAMETER: 21 MM; OUTSIDE DIAMETER: 31 MM; THICKNESS: 4 MM; MATERIAL: RUBBER	94581	EA	5
444	WASHER, SEALING: INSIDE DIAMETER: 47 MM; OUTSIDE DIAMETER: 60 MM; THICKNESS: 9.5 MM; MATERIAL: RUBBER	94593	EA	5
445	WASHER, SEALING: INSIDE DIAMETER: 50 MM; OUTSIDE DIAMETER: 90 MM; THICKNESS: 5 MM; MATERIAL: RUBBER	101818	EA	5
446	WASHER, SEALING: NOMINAL SIZE: 15 MM; INSIDE DIAMETER: 16 MM; OUTSIDE DIAMETER: 20 MM; THICKNESS: 1.6 MM; MATERIAL: CU; FOR USE ON BOILER MILL, REFURBISHMENT	233619	EA	5
447	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 119 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 12.5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNA 515 BEARING TYPE : 22215CCK/W33; CAT NO: 13186/1EN; MODEL NO: SNA 515	725820	EA	5
448	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 149 MM; OUTSIDE DIAMETER: 160 MM; WIDTH: 12.5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNA 518 BEARING TYPE :23218CCK/W33; CAT NO: 13186/EN; MODEL NO: SNA518; 12.5/160 LOCATING RING, BEARING BLOCK : SNA 518 BEARING TYPE :23218CCK/W33	728158	EA	5
449	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 119 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 12.5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNA 515 BEARING TYPE : 22215CCK/W33; CAT NO: 13186/1EN; MODEL NO: SNA 515	725821	EA	5
450	RING: TYPE: LOCATING(STABILIZING)RING; INSIDE DIAMETER: 167 MM; OUTSIDE DIAMETER: 180 MM; WIDTH: 9.7 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNH 520 BEARING TYPE 23220CCK/W33; CAT NO: 13186/1EN; MODEL NO: SNA 520; 12/180 LOCATING RING, BEARING BLOCK : SNH 520, BEARING TYPE 23220CCK/W33	728375	EA	5
451	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 275 MM; OUTSIDE DIAMETER: 290 MM; WIDTH: 5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNH	725819	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Scope of Work for the Supply of Bearings, Pulleys, Housing, Sleeves and Transmission Couplings at Grootvlei Power Station

	532 BEARING TYPE : 23232CCKW33; CAT NO: 13186/1EN; MODEL NO: SNH 532; 5/290 LOCATING RING FOR BEARING BLOCK : SNH 532 & BEARING TYPE: 23232CCKW33			
452	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 275 MM; OUTSIDE DIAMETER: 290 MM; WIDTH: 5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNH 532 BEARING TYPE : 23232CCKW33; CAT NO: 13186/1EN; MODEL NO: SNH 532; 5/290 LOCATING RING FOR BEARING BLOCK : SNH 532 & BEARING TYPE: 23232CCKW33	725819	EA	5
453	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 215 MM; OUTSIDE DIAMETER: 230 MM; WIDTH: 5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNH 526 BEARING TYPE : 23226CCKW33; CAT NO: 13186/1EN; MODEL NO: SNH526; 10/230 LOCATING RING; BEARING BLOCK : SNH 526; BEARING TYPE : 23226CCKW33	728325	EA	5
454	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 235 MM; OUTSIDE DIAMETER: 250 MM; WIDTH: 5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNH 528 BEARING TYPE : 23228CCKW33; CAT NO: 13186/1EN; MODEL NO: SNH528	725818	EA	5
455	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 139 MM; OUTSIDE DIAMETER: 150 MM; WIDTH: 12.5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNA 517 BEARING TYPE : 22217CCKW33; CAT NO: 13186/1EN; MODEL NO: SNA 517; 12.5/150 LOCATING RING FOR BEARING BLOCK : SNA 517 & BEARING TYPE : 22217CCKW33	725817	EA	5
456	RING: TYPE: LOCATING (STABILIZING) RING; INSIDE DIAMETER: 119 MM; OUTSIDE DIAMETER: 130 MM; WIDTH: 12.5 MM; MATERIAL: STEEL; APPLICATION: BEARING BLOCK : SNA 515 BEARING TYPE : 22215CCKW33; CAT NO: 13186/1EN; MODEL NO: SNA 515	725820	EA	5

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.