

	ADDENDUM TO TENDER E2611GXMPHEN - Supply Delivery and Installation of Sand and Filter Nozzles at Water Treatment Plant at Hendrina Power Station.	Unique Identifier	
		Revision	1
		Revision Date	Once off issue
		Group Technology & Commercial	

To: All Tenders

Date: 18 March 2026

From: Penelope Maka

Enquiries:

Penelope Maka

Tel :013 296 3305

Email: MakaPB@eskom.co.za

Supply Delivery and Installation of Sand and Filter Nozzles at Water Treatment Plant at Hendrina Power Station.

TENDER: E2611GXMPHEN

This serves to inform you that the following documents has been updated:

1. SOW.

1.2. Filter nozzle S1 dimensions

i. Type is S1, Slots is 0,35mm (36x0.35), Thread (ØA) is G1 33.25, Thread Length (L1) is 20 mm, Shaft (L2) is 250 mm, inside diameter (ØB) is 16 mm.

2. SAND FILTER GRADING

i. greater than 1.41mm - 0-5%

ii. 1.8mm to 1.2mm - greater than 25% but less than 30%

iii. 0.95mm to 1mm - greater than 35% - less than 45%

iv. 0.85mm to 0.95mm - greater than 15% - less than 25%

v. 0.71mm to 0.85mm - between 0-5%

NB: Tenderers that submitted tenders before an extension was granted that they may leave their tender as valid or withdraw their tender by sending Eskom a withdrawal notices or submit an amended tender.

All documents are uploaded on Eskom Tender Bulletin and National Treasury website.