

Annexure C3.2: Scope of Work (including drawings, where applicable)

- The Wastewater treatment works is currently in a state of decay it is therefore highly recommended to attend the site briefing to ensure accurate pricing.
- The team attending the briefing should include engineering technical personnel

Module 3 and 4 chlorine system:

- Conduct an in-depth condition assessment of module 3 and 4 chlorine dosing system and compile a full scope of refurbishment
- Install chlorine dosing system as per conducted assessment
- Test and commission module 3 and 4 chlorine dosing system back to full functionality

Module 5 chlorine system:

- Conduct an in-depth condition assessment of the chlorine dosing system and compile a full scope of repairs
- Conduct all necessary repairs and replacements to ensure functionality of components/equipment
- Test and commission the chlorine dosing system back to full functionality