



- NOTES:

- 1) Concrete marker posts to be placed at an offset of 1m from centre line of pipe.
- 2) When looking in the direction of water flow, concrete marker posts to be placed on the left hand side.
- 3) Concrete marker posts must be placed at bends and tees on the pipeline.
- 4) Concrete marker posts must be placed in line of site, so that the next marker post is visible from the previous marker post.

THIS DRAWING IS THE PROPERTY OF FLUX/SDM CONSULTING ENGINEERS (Pty) Ltd.
AND MAY NOT BE COPIED OR REPRODUCED EITHER WHOLLY OR IN PART
WITHOUT THE WRITTEN PERMISSION OF THE AFOREMENTIONED COMPANY

THIS DRAWING IS NOT TO BE SCALED. FIGURED DIMENSIONS ONLY ARE TO BE FOLLOWED. ADDITIONAL DIMENSIONS, WHEN REQUIRED, WILL BE PROVIDED UPON REQUEST. CONTRACTORS ARE TO CHECK ALL DIMENSIONS BEFORE WORK COMMENCES AND REFER ANY DISCREPANCY TO THE ENGINEER FOR ADJUSTMENTS.

DRAWING No.	REFERENCE DRAWINGS :		

A	MAY 2026	ISSUED FOR INFORMATION	G.S
NO.	DATE	REVISION	DRAWN

ISSUED FOR TENDER

CLIENT



UMKHANYAKUDE DISTRICT MUNICIPALITY
STAND 13433, KINGFISHER RD PORTION 7
REMAINDER OF HARLINGEN FARM
RICHARDS BAY
3900
TEL: (035) 573 8600
FAX: (035) 573 1094

CONSULTING ENGINEERS



SUITE 306 GRANADA SQUARE
16 CHARTWELL DRIVE
UMHILANGA ROCKS
4320
TEL: +27 (0) 31 561 1431

PROJECT	COMPLETION OF NONDABUYA WSS
---------	-----------------------------

DRAWING TITLE

STANDARD DRAWINGS PIPE MARKER

	SIGNATURE		DATE	PR.No.	SHEET SIZE A0
DESIGNED	M.T		MAY 2026		
DRAWN	G.S		MAY 2026		SCALE
CHECKED	N.N		MAY 2026		AS SHOWN
APPROVED					DWG STATUS P
CO-ORDINATOR					P = PRELIMINARY C = CONSTRUCTION

DRAWING NUMBER

UKDM-0057-07

REVISION No
A

SDM-DRAWING No.
COPYRIGHT RESERVED