

TENDER NAME:

TURBINE AND BOILER HIGH PRESSURE VALVES STELLITE FROM UNIT 1 TO 6 FOR A PERIOD OF 5YRS AT KRIEL POWER STATION.

Clarification Questions

1) Pricelist

- a. "Section 1.1.1 Restilting of valves", does not provide a column for pricing the works for a Workshop Repair. Is the intention to have these noted valves always repaired on site? **Please that on the Price item list you make a provision for workshop and in situ work.**
- b. Can we request the pricelist in Excel format please.
- c. "Section 1.1.8 Maintenance – Preliminary and Generals", to execute works on site the Contractor would need to have the following resources be part of the site team:
 - i. Site Manager – Legal Appointment to oversee the works
 - ii. Quality Officer – for completion of all quality documents and inspections for the site works
 - iii. Safety Officer – to oversee all safety requirements required for the onsite insitu works

(Legal appointment)

- iv. Welders – to execute the welding on the valve repair for the on site works

As it stands these resources are omitted from the pricing schedule. Can Eskom kindly advise how these resources should be catered for in the existing pricing schedule provided?

2) NEC Contract

- a. The contract does not make allowance for CPA, how is Eskom planning on handling this over the contract period?

3) Scope of Work

- a. Is the Contractor responsible to undertake NDE on the valves for onsite works, or will this be done by the Eskom NDE Contractor on site?
- b. "Section 1.1 Executive overview, point 5", speaks to the Contractor fulfilling design requirements and design calculations. Can Eskom please indicate what is meant by this, as no design works gets undertaken during the refurbishment process.

To try and respond to the questions raised by our contracted partner,

1.1 consist of in situ done online and off site stelling the tenderer is expected to make a provision for both on site and off site stelling.

1.1 (b) The contracted partner can transport the document for Microsoft word to Excel and vs on their own.

1.1 C 1-1v Correct

2.

(a) The tenderer must make a provision to cover NDE

(b) Please ignore this portion as the tenderer is not expected to do the design