

PROVISION OF SUPPLY AND DELIVERY OF PULSE JET FABRIC FILTER PLANT (PJFF) CAGES ON “AS AND WHEN REQUIRED” BASIS AT KUSILE POWER STATION FOR THE PERIOD OF FIVE (5) YEARS

E1188GXMPKUS

No.	Document	Section	Page	Requirement	Clarification Questions	Client Response																
1.					<ul style="list-style-type: none">As raised in the clarification meeting please advise on how the required cage sample is to be submitted? Can the Tenderer send email picture confirmation of the cage sample and upon short listing within a 2 business work day notice provide the required sample?Please confirm the quantities requirements per year and a forecast date for when full units will be required.	A PICTURE OF THE CAGE IS TO BE SUBMITTED AND WORKSHOP VISITS WILL BE CONDUCTED FOR CAGE INSPECTIONS WITH TENDERES THAT MEET MANDATORY REQUIREMENTS																
2.					<p>1. Could you please send us this document, “Medupi Kusile Cage Specification 474-11972” as referred to in the Technical Evaluation Criteria, however, it is not provided on the tender bulletin as per attached.</p> <p>2. We also seek clarification on the following items on the TEC;</p> <p><u>3.3. QUALITATIVE TECHNICAL EVALUATION CRITERIA</u></p> <table><tr><td><u>3.</u></td><td><u>Welding</u></td><td><u>Medupi Kusile Cage Specification 474-11972</u></td><td><u>40</u></td></tr><tr><td><u>3.1</u></td><td><u>Welding inspection and test plan (ITP). (Applicable to the cage manufacturing, Not generic).</u></td><td><u>Item 3.2</u></td><td><u>35</u></td></tr><tr><td><u>3.2</u></td><td><u>Welder qualifications (Applicable to the cage manufacturing, Not generic).</u></td><td><u>Item 3.2</u></td><td><u>30</u></td></tr><tr><td><u>3.3</u></td><td><u>Welding procedures (Applicable to the cage manufacturing, Not generic).</u></td><td><u>Item 3.2</u></td><td><u>35</u></td></tr></table> <p>- Item 3.2. Welder qualifications – could you please clarify what kind of welder requirements are required here? Majority of</p>	<u>3.</u>	<u>Welding</u>	<u>Medupi Kusile Cage Specification 474-11972</u>	<u>40</u>	<u>3.1</u>	<u>Welding inspection and test plan (ITP). (Applicable to the cage manufacturing, Not generic).</u>	<u>Item 3.2</u>	<u>35</u>	<u>3.2</u>	<u>Welder qualifications (Applicable to the cage manufacturing, Not generic).</u>	<u>Item 3.2</u>	<u>30</u>	<u>3.3</u>	<u>Welding procedures (Applicable to the cage manufacturing, Not generic).</u>	<u>Item 3.2</u>	<u>35</u>	<p>DOCUMENT HAS BEEN PROVIDED</p> <p>THE TET HAS BEEN REVIEWS AND CHANGED ACCORDINGLY</p>
<u>3.</u>	<u>Welding</u>	<u>Medupi Kusile Cage Specification 474-11972</u>	<u>40</u>																			
<u>3.1</u>	<u>Welding inspection and test plan (ITP). (Applicable to the cage manufacturing, Not generic).</u>	<u>Item 3.2</u>	<u>35</u>																			
<u>3.2</u>	<u>Welder qualifications (Applicable to the cage manufacturing, Not generic).</u>	<u>Item 3.2</u>	<u>30</u>																			
<u>3.3</u>	<u>Welding procedures (Applicable to the cage manufacturing, Not generic).</u>	<u>Item 3.2</u>	<u>35</u>																			

No.	Document	Section	Page	Requirement	Clarification Questions	Client Response
					<u>welding in the production of cages is done by spotwelding machines?</u> 3. <u>Quantity of cages required as per NEC:</u> - <u>How many cages are required in the 5 year period?</u> - <u>Price schedule; Item 4 has no quantity. The total quantity of cages as per NEC is 296000, is this correct?</u>	PROJECTED DELIVERY SCHEDULE PROVIDED (BASED ON CURRENT OUTAGE SCHEDULE)

END