

Title: **Tender Technical Evaluation
Strategy: Grootvlei HAZLOC**

Unique Identifier: **GVL/0480**

Alternative Reference Number: **N/A**

Area of Applicability: **Engineering**

Documentation Type: **Strategy**


Revision: **1**

Total Pages: **12**

Next Review Date: **N/A**

Disclosure Classification: **CONTROLLED
DISCLOSURE**


Compiled by



Kgotso Makweya
Electrical Engineer,
Grootvlei Ps

Date: 12/08/2022


Functional Responsibility



Richard Brayshaw
Electrical Engineering Manager,
Grootvlei Ps

Date: 12/08/2022

Authorised by



Thabo Montja
Engineering Manager,
Grootvlei Ps

Date: 12/08/2022

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

Contents	Page
1. INTRODUCTION	3
1.1 SCOPE	3
1.1.1 Purpose	3
1.1.2 Applicability.....	3
1.2 NORMATIVE/INFORMATIVE REFERENCES.....	3
1.2.1 Normative	3
1.2.2 Informative.....	3
1.3 DEFINITIONS.....	3
1.3.1 Classification	4
1.4 ABBREVIATIONS.....	4
1.5 ROLES AND RESPONSIBILITIES.....	4
1.6 PROCESS FOR MONITORING.....	4
1.7 RELATED/SUPPORTING DOCUMENTS.....	4
2. TENDER TECHNICAL EVALUATION STRATEGY	4
2.1 TECHNICAL EVALUATION THRESHOLD	4
2.2 TET MEMBERSHIP.....	5
2.3 MANDATORY TECHNICAL EVALUATION CRITERIA	6
2.4 QUALITATIVE TECHNICAL EVALUATION CRITERIA.....	7
2.5 TET MEMBER RESPONSIBILITIES.....	11
3. AUTHORISATION.....	12
4. REVISIONS	12
5. DEVELOPMENT TEAM	12

Tables

Table 1: Qualitative Evaluation Criteria Scoring Table	4
Table 2: TET Members	5
Table 3: Mandatory Technical Evaluation Criteria.....	6
Table 4: Qualitative Technical Evaluation Criteria.....	7
Table 4: TET Member Responsibilities.....	11

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

1. Introduction

The purpose of this document is to outline the criteria to be used to conduct Technical Evaluation for the Compliance of HAZLOC Classified Areas at Grootvlei Power Station, as outlined in “GVL/0478: Grootvlei Power Station Hazloc Compliance Report”, based on the decision by Grootvlei Power Station Management to outsource Hazloc services to ensure compliance within the power station, by a suitably qualified, experienced, and well-established service provider.

1.1 Scope

The Tender Technical Evaluation Strategy will define the following technical evaluation criteria:

- a) Mandatory Evaluation Criteria.
- b) Qualitative Evaluation Criteria.
- c) TET Membership.

Once the Technical Evaluation Strategy is approved, no changes to the evaluation criteria will be permitted, without formal revision and re-approval of the Technical Evaluation Strategy.

1.1.1 Purpose

The purpose of this tender technical evaluation strategy is to define the Mandatory Evaluation Criteria, Qualitative Evaluation Criteria and Technical Evaluation Team (TET) member responsibilities for tender technical evaluation, and serves as basis for the tender technical evaluation process.

1.1.2 Applicability

This document applies to the Grootvlei Power Station, with specific reference to HAZLOC areas.

1.2 Normative/Informative References

Parties using this document shall apply the most recent edition of the documents listed in the following paragraphs.

1.2.1 Normative

- [1] GVL/0478: Grootvlei Power Station Hazloc Compliance Report
- [2] 240-48929482: Tender Technical Evaluation Procedure
- [3] Eskom Procurement Policy and Supply Chain Management Procedure 32-1034

1.2.2 Informative

N/A

1.3 Definitions

No Definitions required.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

1.3.1 Classification

Controlled Disclosure: Controlled Disclosure to external parties (either enforced by law, or discretionary).

2. Abbreviations

Abbreviation	Description
CV	Curriculum Vitae
HAZLOC	Hazardous Locations
MIE	Master Installation Electrician
N/A	Not Applicable
TET	Technical Evaluation Team
COC	Certificate of Compliance
SOW	Scope of Work
Ex	Explosion proof
IA	Inspection Authority

2.1 Roles and Responsibilities

As per 240-48929482: Tender Technical Evaluation Procedure

2.2 Process for Monitoring

N/A

2.3 Related/Supporting Documents

N/A

3. TENDER TECHNICAL EVALUATION STRATEGY

3.1 TECHNICAL EVALUATION THRESHOLD

The technical evaluation criteria will be sent out with the tender enquiry and the service providers are required to meet the minimum scoring of 80% to qualify.

The guideline for Qualitative scoring is shown in Table 1:

Table 1: Qualitative Evaluation Criteria Scoring Table

Score	Percentage	Designation
5	100	COMPLIANT Meet technical requirement(s) AND; No foreseen technical risk(s) in meeting technical requirements.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

4	80	COMPLIANT WITH ASSOCIATED QUALIFICATIONS Meet technical requirement(s) with; Acceptable technical risk(s) AND/OR; Acceptable exceptions AND/OR; Acceptable conditions.
2	40	NON-COMPLIANT Does not meet technical requirement(s) AND/OR; Unacceptable technical risk(s) AND/OR; Unacceptable exceptions AND/OR; Unacceptable conditions.
0	0	TOTALLY DEFICIENT OR NON-RESPONSIVE

3.2 TET MEMBERSHIP

The names of TET members will be finalised at time of evaluation, in line with available team members, with these names included in technical evaluation feedback report after evaluation.

Table 2: TET Members

TET member	TET Member Name	Designation
TET 1	To be submitted to Procurement at time of evaluation.	Electrical Engineering Representative, trained in HAZLOC.
TET 2	To be submitted to Procurement at time of evaluation.	Electrical Engineering Representative, trained in HAZLOC.
TET 3	To be submitted to Procurement at time of evaluation.	Electrical Maintenance Representative, trained in HAZLOC.
TET 4	To be submitted to Procurement at time of evaluation.	Electrical Maintenance Representative, trained in HAZLOC.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

3.3 MANDATORY TECHNICAL EVALUATION CRITERIA

Table 3 defines Mandatory Technical Evaluation Criteria to be used during evaluation.

Table 3: Mandatory Technical Evaluation Criteria

No	Mandatory Technical Criteria Description	Reference to Technical Specification / Tender Returnable	Motivation for use of Criteria
1.	The tendering contractor shall have a competent person registered as MIE (Master Installation Electrician), with experience working in hazardous locations (HAZLOC). Proof to be provided in the form of a detailed CV, together with a certified copy of the Certificate of Appointment by the relevant government authority.	The tenderer to provide a certified copy of the Certificate of Appointment by the relevant government authority.	Compliance to Occupational Health and Safety Act (Act 85 of 1993) regulation 9.

Note to TET members:

Mandatory Technical Evaluation Criteria are “must meet” requirements, failing which the contractor’s tender will not be considered further.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

3.4 QUALITATIVE TECHNICAL EVALUATION CRITERIA

Table 4 defines all Qualitative Technical Evaluation Criteria to be used as well as reference to specification and specific weighting.

Table 4: Qualitative Technical Evaluation Criteria

No	Qualitative Technical Criteria Description		Reference to Technical Specification / Tender Returnable	Scoring Criteria	Criteria Weighting
1. MIE Profile Related experience					
	Previous Experience and Customer Satisfaction.		Provide at least 3 traceable references of workplaces where similar work was successfully executed i.e. issuance of HAZLOC CoCs was done. (e.g. Signed contract or purchase order document).	0% - No response. 40% - 1 reference. 80% - 2 reference. 100% - 3 references and above.	15%
2. MIE Skills Capacity Qualifications and experience of key personnel: Demonstration of Appropriately skilled and Qualified Personnel.					
	2.1	Provide technical qualification and MIE certification.	Provide certification.	0% - No response. 100% - Technical qualification and registered MIE with the Department of Labour.	30%

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

No	Qualitative Technical Criteria Description		Reference to Technical Specification / Tender Returnable	Scoring Criteria	Criteria Weighting
	2.2	The tenderer must provide an MIE with 5 years of experience executing similar scope in a heavy industry (e.g. a power plant) with extreme hazardous work areas.	Provide CV and qualification of the MIE.	0% - No response. 40% - Between 0 and 3 years. 80% - Between 3 and 5 years. 100% - 5 years and above.	15%
3. MIE Technical Capacity Technical Capacity					
	3.1	Work Programme and method statement to comply to in executing the works. N.B. The contractor shall submit both the Work programme and method statement. Failure to do so, will result in a score of zero.	Provide detail proposal of how to perform the works as per works info or SOW. Provide at least 2 previous reports for similar works previously executed.	100% - Meet technical requirement(s) and no foreseeable risk(s) in meeting technical requirements. 80% - Meet technical requirement(s) with acceptable technical risk(s)/exceptions and half of the list completed. 40% - Does not meet technical requirement(s) or unacceptable technical risks/ exceptions and quarter of the list complete.	20%

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

No	Qualitative Technical Criteria Description		Reference to Technical Specification / Tender Returnable	Scoring Criteria	Criteria Weighting
				0% - Totally deficient or non-responsive.	
	3.2	Detailed schedule for duration of the works.	The contractor must state the duration to execute the works.	100% - Submit a work schedule which indicates date of completion of work and date to issue the CoC per work program. The work program refers to a Hazloc work area. 0% - No work schedule submitted.	10%
	3.3	Confirmation of lead times for Ex-rated parts, together with IA certificates as per Scope of Work.	The contractor to provide the lead times of Ex-rated parts complete with IA certificates as required in the Scope of Work.	100% - Capability to acquire the stock within one (1) week. 80% - 2 – 3 weeks. 40% - 4 - 6 weeks. 0% - longer than 6 weeks.	10%

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

No	Qualitative Technical Criteria Description		Reference to Technical Specification / Tender Returnable	Scoring Criteria	Criteria Weighting
				TOTAL:	100%

Note to TET members:

For Qualitative Technical Evaluation Criteria, a minimum scoring of 80% is required.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

3.5 TET MEMBER RESPONSIBILITIES

This table shows the TET members allocated to evaluate the various criteria as defined in Table 2 and Table 3 respectively.

Table 5: TET Member Responsibilities

Mandatory Criteria Number	TET 1	TET 2	TET 3	TET 4
1	x	x	x	x
Qualitative Criteria Number	TET 1	TET 2	TET 3	TET 4
1.	x	x	x	x
2.1	x	x	x	x
2.2	x	x	x	x
3.1	x	x	x	x
3.2	x	x	x	x
3.3	x	x	x	x

Note to TET members:

TET 1 will have access to all evaluator scores to complete score verification and consolidations.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.

4. Authorisation

This document has been seen and accepted by:

Name	Designation
Boitumelo Shika	Electrical Engineer, Grootvlei Power Station
Doctor Mazeka	Electrical Engineer, Grootvlei Power Station
Dyke Monyane	Chief Electrical Engineer, Asset Management
Leonard Janse Van Rensburg	Senior Electrical Engineer, Grootvlei Power Station
Peter Phochana	HAZLOC Subject Matter Expert, Asset Management
Tracey Damons	Documentation Centre

5. Revisions

Date	Rev.	Compiler	Remarks
July 2022	1	Kgotso Makweya	Document is a Technical Evaluation strategy which will be used when selecting the most suitable service provider.

6. Development Team

The TET members as listed in Table 1 were involved in the development of this document.

CONTROLLED DISCLOSURE

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorised version on the system.

No part of this document may be reproduced without the expressed consent of the copyright holder, Eskom Holdings SOC Limited, Reg No 2002/015527/30.