

Tender Technical Evaluation Criteria Duvha Power Station

Unit 2 Condenser Tube Repairs

1. Technical evaluation criteria

1.1. Mandatory requirements

The submission of the returnables stated in this section is mandatory.

Failure to submit any of these returnables will result in disqualification of the tender.

1. Verifiable experience of the Contractor or sub-Contractor or joint venture partner regarding expanding more than 10 000 tubes on site during a single project for a turbine size greater than 100 MW in the last 5 years.

1.2. Qualitative requirements

1. An example of the Contractor's QCP for a typical condenser retube project
2. Method statement for the repair of the tubes "B" pass cold condenser inlet waterbox
3. Method statement for the repair of the tubes "B" pass hot condenser inlet waterbox