


## Meteringonline Database

Account Name	Customer No.	Building No.	Unit No.
Phase 1 - Summation	sisi_22		

Phase 1 - Summation From : 2023-06-1 00:00 to 2023-06-30 00:00 (Utility: Electricity)



Energy Analysis	
Total Consumption	3322550.92
Effective Rate	1.66727456480362
Maximum kWh Demand	6920.72
Average kWh Demand	4773.7800574713
Consumption Demand Load Factor	68.978084035639
Maximum Demand Analysis	
Maximum Demand	7392.9943404821
MD Reached at	2023-06-28 08:30:00
Average kVA Demand	5108.0992272916
kVA Load Factor	69.09377976013
Power Factor at Maximum Demand	0.93611866603278
Average Power Factor	0.93621178009233