

**REFURBISHMENT TO THE GOVERNMENT PRINTING WORKS  
ADMINISTRATIVE HEAD QUARTERS  
LOCATED AT 389 SOPHIE DE BRUYN STREET, PRETORIA CENTRAL**

Item No		Unit	Quantity	Rate	Amount
	<b><u>SECTION NO. 3</u></b>				
	<b><u>BILL NO. 2</u></b>				
	<b><u>FIRE PROTECTION (PROVISIONAL) (CPAP WORK GROUP NO. 148 UNLESS OTHERWISE STATED)</u></b>				
	The Tenderer is referred to the relevant Clauses in the separate document General Preambles for Trades (2017)				
	<b><u>FIRE PROTECTION (FIRE HYDRANTS, FIRE HOSE REELS, FIRE EXTINGUISHERS AND SPRINKLERS) AND FIRE DOORS</u></b>				
	<b><u>Fire extinguishers</u></b>				
1	Supply and install new fire extinguishers (4.5Kg) (works to ensure compliance)	No	42		
	<b><u>Fire hose reels</u></b>				
2	Service existing fire hose reels	No	18		
	<b><u>Fire hydrants</u></b>				
3	Service existing fire hydrants	No	16		
	<b><u>Automatic sprinkler installation</u></b>				
4	De-commission sprinkler system			SUM	
5	Remove existing sprinkler heads and install new sprinkler heads	No	140		
6	Re-commission sprinkler system			SUM	
	<b><u>General</u></b>				
7	Allow for new life safety valve arrangement per floor (schematic to comply with statutory requirements)			SUM	
	<b>Carried Forward</b>			R	
	SECTION NO. 3 : FIRE PROTECTION Bill No. 2 Fire Protection and Fire Doors (Provisional) <b>PREPARED BY: DBSA</b>				

**REFURBISHMENT TO THE GOVERNMENT PRINTING WORKS  
ADMINISTRATIVE HEAD QUARTERS  
LOCATED AT 389 SOPHIE DE BRUYN STREET, PRETORIA CENTRAL**

	<b>Brought Forward</b>		R	
8	Inspect existing valve station and allow for full service (works to ensure compliance)		SUM	
	<b><u>Provisional sums</u></b>			
9	Fire signage allowance (photo luminescent)	Item		120 000.00
10	Repair rusted damaged pipes	Item		144 000.00
11	Contingency	Item		90 000.00
12	Supply, install and commission Jockey Pump, including interconnecting pipework and pump test start arrangements, complete to pumphouse pipework	Item		170 000.00
	<b>Carried Forward to Summary of Section No. 3</b>		R	
	SECTION NO. 3 : FIRE PROTECTION			
	Bill No. 2			
	Fire Protection and Fire Doors (Provisional)			
	<b>PREPARED BY: DBSA</b>			