

1	A	B	C	D	E	F	G	H	I	
2	Turbine Hall			 Johannesburg Water			PAGE NO.			
3	65 Ntengi Pilliso							CLOSING DATE AND TIME		
4	Newtown							5-Mar-26	16:00	
5	P O Box 61542							Date of Issue		
6	Marshalltown 2107							17-Feb-26		
7	Tel : (011) 688-1400 Fax :									
8	(011) 688-1556									
9		INITIATING DEPARTMENT	INITIATOR							
10							QUOTATION DATE		VALIDITY	
11							60 DAYS			
12		QUOTATION REFERENCE		COLLECTIVE NO.						
13		RFQJW02ENS26-UPGRADE UNDERFLOW PUMP STATION MCC PANEL COMPONENTS								
14		QUOTATION REQUESTED FROM								
15										
16										
17										
18										
19										
20										
21		UPGRADE UNDERFLOW PUMP STATION MCC PANEL COMPONENTS		DESCRIPTION OF ITEM OFFERED	UOM	QTY REQUIRED	PRICE QUOTED EXCL. OF V.A.T.	DISCOUNT	PRICE QUOTED INCL. OF V.A.T.	
22										
23	1.	Upgrade the MCC components of 2 x washwater pumps at Underflow Pump Station as per BOQ			sum	1				
24		NB: BoQ to be completed in full to avoid disqualification								
25		NB: Evaluation criteria is attached, all required documents to be submitted with the RFQ response								
26		NB: Site briefing is compulsory at Northern Works on stated date and time								
27		NB: Valid registration as CIDB grade 1 EP required								
28										
29										
30										
31										
32		SPECIFIC GOALS		POINTS						
33		SMME (An EME or QSE) 51% or more black owned by Black People		20						
34		NB: All service providers coming to attend site briefing must wear safety shoes and safety reflective jackets								
35										
36		COMPULSORY SITE BRIEFING @ NORTHERN WASTEWATER TREATMENT PLANT- DATE 25/02/2026 TIME 10H00								
37		CONTACT PERSON : Phakameli Dube @ 682 326 6969								
38		NB: All supplier responding to RFQ's should use their own company letterhead not JW RFQ								
39										
40		QUOTATION REF AS ABOVE: RFQ JW 124 MS 24 VOLKANO ALLCAST SERIES- HDMI WIRELESS DISPLAY ADAPTER OR EQUIVALENT								
41		NB: All suppliers responding to RFQs should use their own company letter head not JW RFQ Template AND MAKE SURE THEIR EMAIL ADDRESS IS VISIBLE ON THEIR QUOTATION.								
42		NB: A copy of valid lease agreement or municipal account(not older than 3 months) should be submitted with a quote								
43		NB: MBD forms attached should be completed and submitted with the quote								
44		NB: All Quotes should be on PDF (MS WORD, MS EXCEL, PICTURES ARE NOT ALLOWED)								
45		NB: Copy of valid BBBEE CERTIFICATE or SWORN AFFIDAVIT to be submitted with the quote								
46		PLEASE NOTE THAT SUBMISSIONS MUST BE MADE ON THE E-TENDER PORTAL (https://www.stenders.co.za/). NO EMAIL SUBMISSIONS WILL BE ACCEPTED.								
47		SUPPLIER DETAILS								
48	OFFICIAL STAMP	AUTHORISED BY:		1. QUOTATIONS RECEIVED AFTER CLOSE OF BUSINESS ON THE CLOSING DATE WILL NOT BE ACCEPTED.						
49		SIGNATURE:		2. QUOTATIONS WITHOUT BRAND NAMES WHERE REQUIRED WILL NOT BE ACCEPTED						
50		DATE:		3. PRICES QUOTED MUST BE AS PER THE UNIT INDICATED AND BE EXCLUDED OF VAT						
51				4. ACCEPTANCE OF A QUOTATION WILL BE SUBJECT TO JOHANNESBURG WATER'S SUPPLY CHAIN POLICY						
52				5. TOTAL QUOTATION VALUE TO INCLUDE VAT WHERE APPLICABLE						



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

1. SCOPE OF WORK

Repair and Maintenance of Electrical Equipment for Unit 4 Bioreactors and ET at Northern Works

2. PURPOSE

The aim of the SHE specification is to ensure that any contractor which is appointed by Johannesburg Water to conduct any work complies with the SHE requirements of the SHE specification and any other legislative requirement applicable to the contract scope.

3. APPLICABILITY

This document is applicable to all contractors and suppliers conducting contractual activities for and on behalf of Johannesburg Water.

4. APPOINTMENTS

The contractor and its appointed sub-contractor must make the relevant legislative and non-statutory appointments, which must be maintained valid for the entire contract duration.

All appointees shall be suitably trained and found to be competent for the responsibilities there are assigned for.

Copies of all relevant appointments and the relevant competence certificates must be kept in the relevant SHE file.

5. INSURANCE

The contractor and all its appointed sub-contractor(s) shall be registered with an appropriate compensation commissioner and have a valid letter of good standing from commissioner. The contractor is responsible for ensuring the Letter of Good Standing is valid for the entire duration of the project/contract. A copy of the letter of Good Standing must be kept in the SHE file.

6. COSTING FOR SHE REQUIREMENTS

The contractor is responsible for ensuring that SHE costing is taken into consideration for the entire project/contract as this will ensure they comply with the SHE legislative requirements

7. INDUCTION

An initial induction shall be done with key personnel to familiarize them with the requirements on site and for compiling the SHE file.



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

Once labourers are appointed JW will conduct an induction on SHE requirements, and the contractor is also required to conduct their company specific induction

8. SUBMISSION OF SAFETY FILE

- Once appointed the contractor can submit their safety file for approval.
- Approval will be granted when the critical items have been sufficiently addressed.

9. RISK ASSESSMENT

- Every Contractor who has been appointed contractually to conduct work for Johannesburg water shall do compile a baseline risk assessment prior to starting with work, subject to the approval of the Client.
- Thereafter the task-based risk assessments will be done daily with every task being done.

10. SAFE WORKING PROCEDURES / METHOD STATEMENTS

The following statements / safe working procedures must be compiled:

- Incident investigation, emergency plan, waste management plan, PPE procedure, hand tool procedure, hazardous chemical substance procedure.
- Method statement for the entire works

11.ELECTRICAL CONTRACTOR & RESPONSIBILITIES

- No person may do electrical installation work as an electrical contractor unless that person has been registered as an electrical contractor in terms of the Regulation.
- The principal contractor who does electrical installation work as an electrical contractor shall register annually in the form of Annexure 3 with the chief inspector or a person appointed by the chief inspector. An application for registration shall be accompanied by a prescribed fee.
- An electrical contractor shall be responsible for the safety, safe use and maintenance of the electrical installation he or she uses or leases.



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

12.CERTIFICATE OF COMPLIANCE

- A registered person may issue a certificate of compliance accompanied by the required test report only after having satisfied himself or herself by means of an inspection and test that a new electrical installation complies with the provisions of regulation 5(1) and was carried out under his or her general control; or an electrical installation which existed prior to the publication of the current edition of the health and safety standard incorporated into these Regulations in terms of regulation 5(1), complies with the general safety principles of such standard; or the existing part of the electrical installation complies with the general safety principles of such standard and is reasonably safe, and the extensions or alterations effected comply with the provisions of regulation 5(1) and were carried out under his or her general control.
- Any person who undertakes to do electrical installation work shall ensure that a valid certificate of compliance is issued for that work and no person may amend a certificate of compliance.

13.WORKING AT HEIGHTS

- A competent person must compile a fall protection plan for all tasks which will be done at elevated position.
- The requirements as per the Construction regulations for working at heights shall be always complied with by the contractor.
- The fall protection plan shall be specific to the work that will be conducted at elevated position and proper provision must be made for rescue of employees at heights.
- Fall protection plan must include fall risk assessment detailing proper controls to be implemented.
- All employees who their duties entail working at heights must be declared medically fit by an Occupational Health Practitioner for working at heights.
- Employees who will be working at heights must be trained by a competent service provider for working at heights and must be trained on use of fall prevention/arrest devices to be used at heights.
- Employees working at height must be trained on the latest approved fall protection plan before work commences at height.

14. WORKING IN CONFINED SPACES



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

- An employer/contractor shall take steps to ensure that a confined space is entered by an employee or other person only after the air therein has been tested and evaluated by a person who is competent to pronounce on the safety thereof, and who has certified in writing that the confined space is safe and will remain safe while any person is in the confined space, taking into account the nature and duration of the work to be performed therein.

15. MEDICAL SCREENING REQUIREMENTS

- The contractor shall ensure that a medical surveillance programme is implemented for all employees.
- The medical examination shall be conducted in line with the employee job profile/job description.
- A valid medical fitness certificate must be submitted together with the SHE File for approval for all employees who will be doing work for Johannesburg Water.
- Any employee(s) who are declared conditionally fit must be provided with employment which does not aggravate their medical condition as to endanger themselves or other employees.
- The following tests shall be done:
 - Audiograms.
 - A cardio-respiratory examination
 - Lung function tests.
 - Eye/ sight tests.
 - A general physical examination.
 - A review of previous medical history.
 - Blood pressure tests
 - Glucose tests
 - Vaccinations (Hepatitis A & Typhoid)

16. TOOLBOX TALKS

- The contractor shall ensure they conduct toolbox talks with their employees on a weekly basis and records of these must be kept in the SHE file.
- The objective of toolbox talks should be to communicate relevant site information to assist in improvement of occupational health and safety performance.
- Employees must acknowledge the receipt of toolbox talks and this record must also be kept in the SHE file.

17 .PERSONAL PROTECTIVE EQUIPMENT (PPE)



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

- Contractor must issue their employees SABS approved PPE. A copy of the PPE issue register signed by the employee issued with the PPE must be kept in the SHE file.
- Contractor supervisor are required to conduct continuous inspections of the PPE issued to their employees to ensure that they are still in good condition to be used by the employee or they still comply with manufacture requirements.
- The contractor is responsible for ensuring that employees are trained on the safe use of the PPE issued to them, how to maintain it and the limitations of the PPE.
- NO SHORTS OR DRESSES WILL BE ALLOWED ON SITE

18. WORKPLACE SIGNAGE

- Appropriate symbolic signage must be displayed where it is required by legislation.
- Appropriate warning, mandatory and information signs must be placed where required.
- All signs must comply to SANS/SABS requirements.
- Contractors shall use mandatory and prescribed symbolic safety signs at their lay down and site areas.

19. INCIDENT REPORTING AND INVESTIGATION

- All incidents shall be reported to the Client before the end of the shift or within 24hrs of occurrence.
- Section 24 incidents shall be reported to DOL using the prescribed format.
- The contractor shall develop an incident management procedure and communicate with all employees.

20. NOTIFICATION OF CONSTRUCTION WORK

- The contractor shall notify the DOL in the prescribed format of the intended work prior to work.

21. COMPLIANCE MONITORING

- Weekly inspections and monthly audits will be conducted on site.

22. PROJECT COMPLETION

- Upon completion of the project the SHE file shall be returned to the Client for retention and close out



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

Project details

Project Scope: Repair and Maintenance of Electrical Equipment for Unit 4 Bioreactors and ET at Northern Works

Depot / Site / Department: Northernworks

Estimated duration: TBC

Documents required

Letter of Good Standing	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
SHE plan	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Risk Assessment	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Safe working Procedures	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Notification of Construction work	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Inspection registers	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

Items required before starting

Medicals	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Vaccinations	Yes	<input type="checkbox"/>	No	<input checked="" type="checkbox"/>	N/A	<input type="checkbox"/>
PPE (boots, hard hats, overall)	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Induction	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Approval from OHS	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>

APPOINTMENTS AND COMPETENCIES

<u>Construction Supervisor</u>						
Appointment	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
CV (and/ certificates)	Yes	<input checked="" type="checkbox"/>	No	<input type="checkbox"/>	N/A	<input type="checkbox"/>
<u>Safety Officer</u>						
Appointment	Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>	N/A	<input type="checkbox"/>
CV (and/ certificates)	Yes	<input checked="" type="checkbox"/>	No	<input checked="" type="checkbox"/>	N/A	<input type="checkbox"/>

NB* Other appointments will be based on the number of employees on site as required by law.



Document title :	Minimum SHE Requirements for Construction Related RFQ projects		
Revision	00	Author:	OHS: Projects
Effective Date	January 2017	Pages:	01

RETURNABLE ANNEXURE A: ACKNOWLEDGEMENT OF SHE SPECIFICATION & ANNEXURES

CONTRACTOR:	
-------------	--

I, the undersigned, hereby acknowledge that I have obtained copies of the following listed documentation and confirm that I fully understand the contents thereof and the consequences of non-compliance. The Contractor furthermore reiterates its commitment to compliance of the requirements contained within the following provided documentation:

- Johannesburg Water SOC Ltd, Safety, Health & Environmental (SHE) Specification, Annexure 1: Baseline risk assessment conducted for or on behalf of Johannesburg Water SOC Ltd;

Signed at on this Day of 20.....

CONTRACT MANAGER			
NAME	DESIGNATION	DATE	SIGNATURE
CONTRACT SUPERVISOR			
NAME	DESIGNATION	DATE	SIGNATURE
WITNESS (1)			
NAME	DESIGNATION	DATE	SIGNATURE
WITNESS (2)			
NAME	DESIGNATION	DATE	SIGNATURE



HEALTH, SAFETY & ENVIRONMENTAL (SHE) SPECIFICATION: BASELINE RISK ASSESSMENT

PROJECT NUMBER:	RFQ
PROJECT LOCATION:	Northern Works
PROJECT DESCR:	Upgrade the MCC components of 2 x washwater pumps at Underflow Pump Station

POSSIBLE RISKS FOR THIS PROJECT

Task	Hazard	Risk	Consequence	Rating	Controls
Compliance with applicable legislation for safety, health and environment	Contractor processes and/or procedures not developed according to legislation requirements.	Not complying with applicable legislation and client SHE specifications.	Litigation, multiple injuries and death. Work stoppages	M	Planning, design and implementation to comply with legislative requirements, especially for Health, Safety and Environment together with Quality. Appointment of a qualified person to assist with the development of legislative guided processes and procedures.
Conducting SHE Induction training	Employees, contractors, suppliers, and visitors not aware of applicable legislating for the project and policies.	Non-compliance to legislation.	Work stoppages Multiple injuries	M	Every new employee or visitor must be inducted before entering company premises or starting work. All employees absent from work or on leave for a period of 14days must be inducted. Inducted visitors must at all times be accompanied when walking around company premises.
Arranging Medical surveillance or examination	Employees not medically fit for work appointed for. No proof of medical fitness certificate. Employees not Vaccinated	Non-compliance to statutory requirements. Exposure to unidentified contagious diseases carriers.	Work stoppages. Incidents resulting to injuries	L	Medical examination or assessments must be conducted prior to start of work and annually by an Occupational Medical Practitioner. Every person must be declared medically fit for the type of work they performing and copies of

					employees' medical certificates to be kept on site. Employees must be vaccinated prior to work on site
Gate access to site premises - by people	Walking on the vehicle's driveways Lack of observation Intoxicated pedestrian employee or visitor entering security gate Employees, visitors or contractors entering with firearm Unauthorized entry	Personal injuries due to vehicles driving over people. Personal fight due to arrogant intoxicated people. Theft due to unauthorized entry.	Personal fight due to arrogant intoxicated people. Work stoppages resulting in delay to production Theft due to unauthorized entry.	L	Only Authorised entry on JW premises Zero alcohol tolerance All Employees, contractors, suppliers and visitors to walk only on designated walkways in and around site/client premises.
Obtain necessary JW documentation and JW approvals	Working without authorization from JW	JW removing Contractor from site	Delay in production	L	No work is allowed to start without the necessary documentation and approvals in place. Occupational notices must be available on site kept on site in the Health and Safety File
Working on site	Working during peak hours	Employees and vehicles moving around the vicinity	Serious injuries Vehicle damages	M	Access to the work area must be restricted/monitored Designated pedestrian routes must put in place to restrict unauthorized access Work must be planned for quieter times of the day when reduced/restricted pedestrian access is required to the area Safe working area must be cordoned off around the area and signage must be used as appropriate High visibility clothing worn by Site Supervisor if working on traffic route.
	Manual lifting of objects/materials	Back pain Muscles strains	Pains Muscular disorder	M	Proper lifting tool to be inspected before use

			Back ache		Employees must be trained on the lifting of objects/material
	Manual handling	Lifting of heavy Objects	Back pains	M	Follow proper lifting techniques
Wet floor	✓ Wet floor	✓ Slippery floor	✓ Injuries	M	<ul style="list-style-type: none"> ✓ Employees must always wear the PPE (boots) on site. ✓ Housekeeping must be maintained on site at all times
Weather conditions	Weather conditions; high winds, heavy rain, hot weather etc	Eye strains	Fall injuries, sun burn, heat exhaustion	M	<p>Employees assesses the weather conditions before undertaking external work and does not undertake the task if conditions unsuitable</p> <p>Employees wears clothing appropriate to the weather conditions</p> <p>Employees wears clothing to cover skin and wears sunscreen in hot sunshine</p> <p>Employees keeps well hydrated and takes regular breaks in hot weather.</p>
Electricity	Electric cables	Use of faulty cables/unsafe electric cables	Burns/electric shock/fatality	M	<p>Site Supervisor must undertake an inspection of area to identify any electrical hazards / overhead power cables</p> <p>No work must be carried out within 6 meters of high voltage cables</p> <p>Live supplies must be isolated where necessary</p> <p>Aluminum ladders must not be used where any electrical hazard exists</p>
Electrical Installations	Electricity Incompetent personnel Wrong tools	Contact with live electricity Incompetent person Connecting electricity	Electrocution Serious Injuries	H	<p>Follow lock out procedure</p> <p>Ensure that equipment are earthed to an approved earthing point</p>

	Damaged cables	Electric shocks			Ensure a zero potential test is performed for electricity is isolated Inspect all tools Use correct tools for the job
Cables	Use of faulty cables	Fire ignition	Burns/ damages	M	Visual inspection of cable before use
Cutting Cables	Cutting of Cables on site	Eye penetration	Eye injuries/ blindness	M	Safety goggles shall be worn by employees when cutting steel
Low and Medium Voltage	Conducting Low and Medium Voltage electrical maintenance work	Exposure to live electricity Failure to follow the lock procedure can result into electrution, property damage or multiple fatalities	Burns Property Damages Fatality	M	Implement lockout procedure and all tasks must be supervised by qualified Electricians. Wear appropriate PPE
	Exposure to arc flash	Skin burns, toxic gas inhalation, illuminous effect (eye damage), flying objects, explosion (pressure)	Skin Burns Explosion Gas inhalation	M	Safe Operating Procedure for Low Voltage Operating. PPE rated for arc flash
Electrical Components (Maintenance)	Static electricity and unintentional touching live parts or encroaching into live chamber	Employees can be electrocuted	Injuries Fatality	M	Only authorized, trained and competent (valid switching certificates) employees must supervise Electrical components maintenance. Electrical rooms to be always locked. Lockout SOP. MV Operating SOP. Proper signage.
Installation of Cables and Electrical equipment/accessories	Cable connection Inspection	Electrocution Injury /Damage to equipment Chocking	Injuries / damage to employees and equipment fatality	H	Authorized person with C.O.C must do all the installation. Emergency stop button must always be serviceable. Observe proper lifting techniques.

	Incorrect placing of equipment. Lifting procedure not followed No lockout/tag out done on live equipment	Machine can start running unexpectedly			Ensure communication between employees. Technical Skills Maintenance plan
Components (PLC) Programming	Programming of components (PLC)	Error in programming/plant malfunction	Plant dysfunctional	L	Only Competent personnel to program PLC Logical controllers. Plant to be tested after programming with works personal.
Test & Commission	Live Yard	Electrocution Injury Working unauthorized Miss-communication between employees	Injury or death	H	Fire extinguisher must always be on site Obtain a permit and follow all procedures listed Strict supervision Competent technician operation Issue test certificate for every testing and inspection done
	Unit activation	Auto start	Electric shock	M	Tag out
Wet floor	Wet floor	Slippery floor	Injuries	M	Employees must always wear the PPE (boots) on site. Housekeeping must be maintained on site at all times
Height	Working at height	Falling of objects, debris	Fracture Fatality Head injuries/concussion	M	pre job brief must be conducted before the commencement of the work full time supervision on site hardhat must be provided safety arrest must be provided to the employees A safe working area is cordoned off around the work at height equipment and signage is used as appropriate

					A belt holster or belt hooks are used for carrying tools up/down ladder Any person footing the ladder is advised to wear head protection. Employees are advised to bag any debris into small quantities and lower it slowly to the ground.
Grinder	Cutting of components using Grinder	Untrained staff	Injuries Fatal Property damage	H	Only the right competent personnel to operate the grinder.
	Use of Electricity	Improper maintenance	Shock/ Burns	M	Always switch off electricity before working
	Use of faulty electric cables	Fire ignition	Burns/ damages	M	Visual inspection of cable before use
	Electrical safety	Electrical shock or burns Damaged portable electrical appliances, cables, plugs	Injuries Properties damage	M	All portable electrical equipment should be tested for electrical safety at correct interval Electrical cables and plugs should be regularly visually inspected by the user for damage
	Cutting and welding of the Steels	Burns	injuries	M	Care with torch and PPE All the steel cut must be placed in a barricaded space
	Incompetent employees	Wrong connections	Burning of equipment	L	Use only competent employees
Drill	Incompetent personnel	Incorrect operation	Injuries Property damages	M	
	Drilling Drill pit Drill sharp metal fibers	Vibration Cutting edges Eye penetration	Damaged hearing Carpal tunnel syndrome	M	Use hearing protection when exposed to excessive noise levels

	High Noise Levels Cutting Grinder/Disc	Finger cuts Expose to high noise level area Uncontrolled Disc Electrical equipment failure Sharp window edges	Cuts/ injuries Eye irritation / Blindness Minor cuts resulting into injury njuries to persons operating Eye injuries		(greater than 85 dB over an 8-hour work period) Assess noise level with sound level meter if possibility exists that level may exceed 85Db Rotate drilling tasks to minimize worker exposure to equipment vibration Use right size of a drill to drill different layers of the ground Assess manual guide carefully to ensure correct usage of portable electrical devices.
	Working environment	May feel too hot/cold	Fatigue Discomfort	M	Temperature must always be kept within a comfortable range.
Hacksaw	Use of manual Hacksaw and Electrical Hacksaw	Damaged blade and flying objects	Injuries	M	Conduct training about using hand tools and provide proper PPE (gloves, safety boots, overalls, goggles). Hand tools SOP Only qualified Artisans to operate the electrical powered hacksaw and proper lock out procedure to be implemented. Periodic equipment inspection. Proper PPE (safety boots, goggles, overalls, gloves)
Using hand tools	Using hand tools (spanners, screw drivers etc.)	Damaged Tools	Injuries	L	Conduct training about using hand tools and provide proper PPE. Hand tool SOP. Use proper PPE
Use of hazardous chemical substances	The use of Chemicals	Inhalation of chemicals Fumes from the chemicals Wrong handling of the paint	Skin burns or irritation caused by contact with a chemicals	M	Using respiratory mask; replace Respirators/Dust musk to be used at all times when working with hazardous material.

		chemicals getting into the eyes.	Material in contact with the employee's skin resulting in skin irritation. chemicals dropping into the eyes resulting in blindness Inhaling fumes from hazardous material resulting in lung infection/problems		<p>Rotate workers working with hazardous material.</p> <p>chemical risk assessment must be communicated before commencement of work</p> <p>Visual inspection for any signs of damage must be conducted before work commences</p> <p>Wear gloves at all times, wear full PPE to avoid skin contact.</p> <p>Ensure standard safety procedures are followed.</p> <p>Wear safety goggles properly at all times. Training on SDS.</p>
Climbing down on ladder or structure	Working at heights	Falling onto / Falling objects Mechanical failure of step ladder bolts Loosing footing and falling to ground Smooth angle iron surfaces that can be slippery	Employees falling from heights which may result in fatality Personal injuries from elevated equipment	M	Admin: provide training for personnel working at heights Developing a safe working procedures and inspections should be conducted on regular basis
Grinder	The use of Grinder	Suspended loads Open flames Small chips on the floor	Injuries	H	<p>Employees should be provided with the right PPE to protect themselves from cutting themselves.</p> <p>Area must be cleared after a task.</p> <p>Only the right competent personnel to operate the grinder.</p>
Clean site and remove Rubble	Waste Disposal	Injuries or property damaged	Injuries	H	A proper waste disposal system should be in place

					Waste should be removed daily and placed in the correct waste disposal system
	Poor house keeping	Trip and fall	Injuries	H	Good housekeeping to be maintained
General activities in and around site	Protection of public	Injury to member of public from site works	Injuries	M	Barriers and signage to be in place.

RISK ASSESSMENT MATRIX

Likelihood	Consequences				
	Insignificant (minor problem easily handled by normal day to day processes)	Minor (Some disruption possible e.g., damage equal to R150k)	Moderate (significant time / resources required. E.g., damage equal to R500k)	Major (Operations severely damaged. E.g., damages equal to R1m)	Catastrophic (business survival is at risk. Damage equal to R5m – 10m)
Almost certain (90% chance)	High	High	Extreme	Extreme	Extreme
Likely (between 50-90%)	Moderate	High	High	Extreme	Extreme
Moderate (between 10-50%)	Low	Moderate	High	Extreme	Extreme
Unlikely (between 3-10%)	Low	Low	Moderate	High	Extreme
Rare (<3%)	Low	Low	Moderate	High	High

RFQ Evaluation Criteria

NO.	MANDATORY CRITERIA	YES/NO
1.	Compulsory briefing session was attended	
2.	The contractor submitted proof of valid registration/letter certificate with minimum CIDB grading of 1 EP. The certificate/letter must be submitted together with the RFQ.	
3.	BOQ completed in full by the contractor	
4.	Contractor submitted proof of at least one completed project whereby the scope of work was installation or maintenance or repair of MCC panels at wastewater plant or portable water plant (completion certificate or reference letter signed by the client: with working contact details of the client, email and telephone numbers)	

CRITERIA NO #	CRITERIA	EVIDENCE	SUB-CRITERIA/CLAUSE	WEIGHTING	SCORE
1.	Company's Experience The Tenderer (Company) is required to have experience in the installation, repairs, refurbishment, or maintenance of conveyor belts.	The Tenderer (Company) must provide relevant reference letter(s) or completion certificates with proof that they have executed and successfully completed the required works in rendering services of installation, repairs, refurbishment, or maintenance of conveyor belts. <i>This document must be completed by the referee and included in the tender submission. Alternatively, the client's letterhead may be used for this purpose provided it complies with the functional criteria requirements. A separate form must be completed for each reference as required in the evaluation criteria. The Information provided will be verified and if found to be false or misrepresented, punitive measures will be instituted against the respective party including blacklisting and restriction from participating in any future government tender.</i>	Total Number of Years with respect to relevant experience in conveyor belts	50	
			Less than one (1) year		0
			One (1) to two (2) years		30
			Three (3) to four (4) years		40
			Five (5) years or more		50
2.	Qualifications of Artisan: Fitter	The tenderer is required to submit the following copy of qualification for their PLC Technician/Engineer who will be assigned for the execution of the work. - Fitting, Fitter, Millwright or Fitter and Turner Trade Test Certificate	Bidder is to submit proof of relevant specified qualification	30	
			The bidder did not provide the required qualification		0
			<i>Fitting, Fitter, Millwright or Fitter and Turner Trade Test Certificate</i>		18
			<i>Fitting, Fitter, Millwright or Fitter and Turner Trade Test Certificate plus N3 (NQF 4) or Higher Mechanical Qualification Certificate</i>		30
3.	Experience of Artisan: Fitter	The tenderer must submit CVs of their key personnel describing their relevant work experience in installation, repairs, refurbishment, or maintenance of conveyor belts.	Total Years of Experience with respect to conveyor belts.	20	
			Less than three (3) years		0
			Three (3) years or more but less than five (5) years		12

			Five (5) years or more but less than seven (7) years		16
			Seven (7) years or more		20
MINIMUM QUALIFYING SCORE					60
TOTAL					100

CONTACTABLE REFERENCE

To Johannesburg Water (SOC) Ltd

I, the undersigned being duly authorised to do so, hereby furnish a reference to Johannesburg Water relative to the **Repair and Service of BC06 conveyor belt and associated equipment at Northern Works**

Name of Tenderer:

Description of Goods / Services provided

.....
.....
.....
.....

Duration: Year-Month-Day when the Goods / Services were provided

Start date (Year- Month -Day) when the above was provided:/...../.....

End date (Year- Month -Day) when the above was provided:/...../.....

Name of authorised person:

Signature: **Date**

Telephone/Mobile:

Email:

Completed on behalf (Name of Client)

NB: This document must be completed by the referee and included in the **tender submission**. Alternatively, the client's letterhead may be used for this purpose provided it complies with the functional criteria requirements. A separate form must be completed for each reference as required in the evaluation criteria. Information provided will be verified and if found to be false or misrepresented, punitive measures will be instituted against the respective party including blacklisting and restriction from participating in any future government tender.

Curriculum Vitae of Key Personnel

Provide separate forms for each key personnel as per the position listed in the form:

Artisan: Fitter

Curriculum Vitae		
Name:		Date of birth:
Profession:		Nationality:
Qualifications:		
Name of Employer (firm):		
Current position:		Total Months Relevant Experience:
<u>Employment Record:</u>		
<u>Experience Record Pertinent to Required service:</u>		
START DATE (day/ month/year)	End DATE (day/month year)	ROLE WHICH PROVES RELEVANT EXPERIENCE

Certification:

I, the undersigned, certify that, to the best of my knowledge and belief, this data correctly describes me, my qualifications and my experience.

.....
Signature of person named in the schedule

.....
Date

REFURBISHMENT OF UNIT 01, 03, 04 AND 05 REST ROOMS

No.	DESCRIPTION	UNIT	QTY	RATE	AMOUNT
SECTION A : Material Supply and Delivery					
1	Supply and deliver contactor (230V coil, ABB, model AF140-30)	each	4		
2	Supply and deliver LW Terminal enlargement (ABB, model LW140)	each	4		
3	Supply and deliver LT Terminal shroud (ABB, model LT140-30L)	each	4		
4	Supply and deliver overload relay (ABB, model TF140DU-142)	each	4		
5	Supply and deliver ELCOR sensor model AC100E	each	2		
6	Supply and deliver side-mount auxiliary contact block (ABB, CAL19, 1NO 1NC)	each	12		
7	Supply and deliver panel flex cable (single-core, 600/1000V, PVC, SANS 1574-3, red, Cu, 35mm ²)	m	100		
8	Supply and deliver 35mm ² pin lugs	each	35		
9	Supply and deliver 35mm ² ring lugs (hole to MCCB dimensions)	each	9		
10	Supply and deliver 35mm ² cable heat shrink (red, white and blue)	m	9		
11	Supply and deliver panel mount analogue ammeter 150/5A	each	2		
12	Supply and deliver CT for ammeter 5VA, CL1, 150/5A	each	2		
13	Supply and deliver MCCB, ABB, XT2H 160A MA In160A with shunt trip	each	2		
14	Supply and deliver 60 X 60 Narrow Slot Trunking + covers	m	2		
15	Supply and deliver 80 X 60 Narrow Slot Trunking + covers	m	2		
16	Supply and deliver Din rail Narrow Slot	m	2		
17	Supply and deliver gravo labels 150mm x 35mm	each	2		
18	Supply and deliver Stud terminal blocks 125A WRT35/M6 (EM)	each	8		
19	Supply and deliver Stud terminal blocks covers ADWRT35 (EM)	each	16		
Total Section A					
SECTION B: Labour and site work					
20	Install contactor	each	4		
21	Install overload relay	each	4		
22	Install earth leakage sensor	each	2		
23	Install contact blocks	each	12		
24	Install panel flex cable 35mm ²	m	100		
25	Install 35mm ² pin/ring lugs	each	44		
26	Install 35mm ² cable heat shrink	m	9		
27	Install panel mount ammeter	each	2		
28	Install CT	each	2		
29	Install MCCB	each	2		
30	Install Trunking + covers	m	4		
31	Install Din rail	m	2		
32	Install gravo labels 150mm x 25mm	each	2		
33	Commission and test the two pump unit panels	sum	1		
34	Compliance with OHS requirements (safety file)	sum	1		

Guide: How to submit a response on the E-tender Portal

- Submit on E tender portal, following the below:
 1. (<https://www.etenders.gov.za/>)
 2. Search/Click Browse Opportunities by organ of state (Johannesburg Water)/search by RFQ reference number .
 3. Click the **+ sign** to expand the tender/ RFQ information.
 4. start the e submission process.
 5. Supplier login
 6. Use your CSD Credentials to Login. Contact CSD on (csd@treasury.gov.za) in case you forgot your login credentials. “My profile should show if you have logged in successfully”.
 7. select supplier.
 8. check the submission checklist and attached the compulsory documents.
 9. confirm and proceed .

If the application is not going through on the E-tender portal Contact:

eTenders Contact Centre

+27(0)12 406 9222 / 012 406-9229 / 012 312-5000

etenders@treasury.gov.za

<https://etenders.treasury.gov.za>

POPIA PRIVACY STATEMENT

Johannesburg Water SOC Limited

In terms of the Protection of Personal Information Act, 213 (Act 4 of 2013), also called the POPI Act or POPIA, Johannesburg Water SOC Limited, undertakes all reasonable measures to protect personal information and to keep it private and confidential.

1. Privacy Notice applies to:

Suppliers, vendors, contractors, service providers, etc whether appointed or prospective.

2. Definitions of personal information

According to the Act “personal information” means information relating to an identifiable living, natural person, and where it is applicable, an identifiable, existing juristic person. All addresses including residential, postal and email addresses.

3. About the Public Entity

Johannesburg Water (SOC) Limited, registration number 2000/029271/30

3.1 The information we collect

We collect information directly from you where you provide us with your personal details. Where possible, we will inform you what information you are required to provide to us and what information is optional.

3.2 How Johannesburg Water use your information

We will use your personal information only for the purposes for which it was collected and agreed with you. For example: to gather contact information, to confirm and verify your identity, for the evaluation and adjudication of bids and quotations for tenders, request for quotations, and other personal information for the procurement of goods and services by the Entity.

3.3 Disclosure of information

We may disclose your personal information to our Shareholder, the City of Johannesburg, and other Government agencies such as National Treasury, and the Auditor-General of South Africa. We have agreements in place to ensure that they comply with the privacy requirements as required by the Protection of Personal Information Act.

We may also disclose your information:

- Where we have a duty or a right to disclose in terms of law;
- Where we believe it is necessary to protect our rights.

3.4 Information Security

We are legally obliged to provide adequate protection for the personal information we hold and to stop unauthorised access and use of personal information. We will, on an ongoing basis, continue to review our security

POPIA PRIVACY STATEMENT

Johannesburg Water SOC Limited

controls and related processes to ensure that your personal information remains secure.

When we contract with third parties, we impose appropriate security, privacy and confidentiality obligations on them to ensure that personal information that we remain responsible for, is kept secure. We will ensure that anyone whom we pass your personal information agrees to treat your information with the same level of protection as we are obliged to.

3.5 Your rights: Access to Information

You have the right to request a copy of the personal information we hold about you. To do this, simply contact us at informationofficer@jwater.co.za, and specify what information you require.

3.6 Correction of your personal information

You have the right to ask us to update, correct or delete your personal information. We will require a copy of your identification document to confirm your identity before making changes to personal information we may hold about you. We would appreciate it if you would keep your personal information accurate and up to date.

3.7 How to contact us

If you have any queries about this document; you need further information about our privacy practices; wish to withdraw consent; exercise preferences or access or correct your personal information, please contact us at the numbers listed on our website or send an email to informationofficer@jwater.co.za.



a world class African city



City of Johannesburg

Johannesburg Water SOC Ltd

Turbine Hall
65 Ntsemi Piliso Street
Newtown
Johannesburg

Johannesburg Water
PO Box 61542
Marshalltown
2107

Tel +27(0) 11 688 1400
Fax +27(0) 11 688 1528

www.johannesburgwater.co.za

PLEASE SUPPLY THE FOLLOWING DOCUMENTS TO ENABLE US TO EVALUATE YOUR SUBMISSION :			
Returnable Documents	Description	Yes/No	
1	Original Valid Tax Clearance Certificate /valid SARS PIN		COMPULSORY
2	A, certified /original/valid, BBBEE certificate /sworn affidavit (Please note that the Sworn Affidavit must be compliant as per B-BBEE Practice Guide 01 of 2018 , NON COMPLIANT AFFIDAVIT WILL BE SCORED ZERO)		COMPULSORY
3	Municipal rates and taxes (Must not be older than 90 days in arrears in line with regulation 38.		COMPULSORY
4	Signed Declaration of Interest form (MBD 4)		COMPULSORY
5	Declaration of Bidders past supply chain management practices (MBD 8)		COMPULSORY
6	Certificate of Independent Proposal Determination (MBD 9)		COMPULSORY
7	Proof of CSD registration /MAAA Supplier Number		COMPULSORY
8	Preference points claim form in terms of the preferential procurement regulations 2022 (MBD 6.1)		COMPULSORY
9	Company registration documents with ID copies of directors / shareholders.		COMPULSORY

Directors:

Ms Gugulethu Phakathi (Chairperson), Mr Ntshavheni Mukwevho (Managing Director and Executive Director),
Mr Johan Koekemoer (Financial Director and Executive Director), Mr Phetole Modika, Mr Siphamandla Mnyani, Mr Siyabonga Mthembu,
Mrs Zandile Meeleso, Mr Pholoso Matjele, Mr Kgaile Mogoye, Mr Sandiso Mgengwana, Mr Molate Mashifane, Ms Pamela Mabece,
Mr Lunga Bernard

Ms Kethabile Mabe (Company Secretary),
Johannesburg Water SOC Ltd
Registration Number: 2000/029271/30

MBD 4

DECLARATION OF INTEREST

- 1. No bid will be accepted from persons in the service of the state¹.
- 2. Any person, having a kinship with persons in the service of the state, including a blood relationship, may make an offer or offers in terms of this invitation to bid. In view of possible allegations of favouritism, should the resulting bid, or part thereof, be awarded to persons connected with or related to persons in service of the state, it is required that the bidder or their authorised representative declare their position in relation to the evaluating/adjudicating authority.
- 3 In order to give effect to the above, the following questionnaire must be completed and submitted with the bid.**

3.1 Full Name of bidder or his or her representative:.....

3.2 Identity Number:

3.3 Position occupied in the Company (director, trustee, hareholder²):.....

3.4 Company Registration Number:

3.5 Tax Reference Number:.....

3.6 VAT Registration Number:

3.7 The names of all directors / trustees / shareholders members, their individual identity numbers and state employee numbers must be indicated in paragraph 4 below.

3.8 Are you presently in the service of the state? **YES / NO**

3.8.1 If yes, furnish particulars.

.....

¹MSCM Regulations: "in the service of the state" means to be –

- (a) a member of –
 - (i) any municipal council;
 - (ii) any provincial legislature; or
 - (iii) the national Assembly or the national Council of provinces;
- (b) a member of the board of directors of any municipal entity;
- (c) an official of any municipality or municipal entity;
- (d) an employee of any national or provincial department, national or provincial public entity or constitutional institution within the meaning of the Public Finance Management Act, 1999 (Act No.1 of 1999);
- (e) a member of the accounting authority of any national or provincial public entity; or
- (f) an employee of Parliament or a provincial legislature.

² Shareholder" means a person who owns shares in the company and is actively involved in the management of the company or business and exercises control over the company.

3.9 Have you been in the service of the state for the past twelve months? **YES / NO**

3.9.1 If yes, furnish particulars.....

.....

3.10 Do you have any relationship (family, friend, other) with persons in the service of the state and who may be involved with the evaluation and or adjudication of this bid?..... **YES / NO**

3.10.1 If yes, furnish particulars.

.....
.....

3.11 Are you, aware of any relationship (family, friend, other) between any other bidder and any persons in the service of the state who may be involved with the evaluation and or adjudication of this bid? **YES / NO**

3.11.1 If yes, furnish particulars

.....
.....

3.12 Are any of the company's directors, trustees, managers, principle shareholders or stakeholders in service of the state? **YES / NO**

3.12.1 If yes, furnish particulars.

.....
.....

3.13 Are any spouse, child or parent of the company's directors trustees, managers, principle shareholders or stakeholders in service of the state? **YES / NO**

3.13.1 If yes, furnish particulars.

.....
.....

3.14 Do you or any of the directors, trustees, managers, principle shareholders, or stakeholders of this company have any interest in any other related companies or business whether or not they are bidding for this contract. **YES / NO**

3.14.1 If yes, furnish particulars:

.....
.....

4. Full details of directors / trustees / members / shareholders.

Full Name	Identity Number	State Employee Number

.....
Signature

.....
Date

.....
Capacity

.....
Name of Bidder

**PREFERENCE POINTS CLAIM FORM IN TERMS OF THE PREFERENTIAL
PROCUREMENT REGULATIONS 2022**

This preference form must form part of all tenders invited. It contains general information and serves as a claim form for preference points for specific goals.

1. GENERAL CONDITIONS

- 1.1 The following preference point systems are applicable to invitations to tender:
- the 80/20 system for requirements with a Rand value of up to R50 000 000 (all applicable taxes included); and

1.2 To be completed by the organ of state

- a) The applicable preference point system for this tender is the 80/20 preference point system.

- 1.3 Points for this tender (even in the case of a tender for income-generating contracts) shall be awarded for:

- (a) Price; and
- (b) Specific Goals.

1.4 To be completed by the organ of state:

The maximum points for this tender are allocated as follows:

	POINTS
PRICE	80
SPECIFIC GOALS	20
Total points for Price and SPECIFIC GOALS	100

- 1.5 Failure on the part of a tenderer to submit proof or documentation required in terms of this tender to claim points for specific goals with the tender, will be interpreted to mean that preference points for specific goals are not claimed.

- 1.6 The organ of state reserves the right to require of a tenderer, either before a tender is adjudicated or at any time subsequently, to substantiate any claim in regard to preferences, in any manner required by the organ of state.

2. DEFINITIONS

- (a) “**tender**” means a written offer in the form determined by an organ of state in response to an invitation to provide goods or services through price quotations, competitive tendering process or any other method envisaged in legislation;

- (b) “**price**” means an amount of money tendered for goods or services, and includes all applicable taxes less all unconditional discounts;
- (c) “**rand value**” means the total estimated value of a contract in Rand, calculated at the time of bid invitation, and includes all applicable taxes;
- (d) “**tender for income-generating contracts**” means a written offer in the form determined by an organ of state in response to an invitation for the origination of income-generating contracts through any method envisaged in legislation that will result in a legal agreement between the organ of state and a third party that produces revenue for the organ of state, and includes, but is not limited to, leasing and disposal of assets and concession contracts, excluding direct sales and disposal of assets through public auctions; and
- (e) “**the Act**” means the Preferential Procurement Policy Framework Act, 2000 (Act No. 5 of 2000).

3. FORMULAE FOR PROCUREMENT OF GOODS AND SERVICES

3.1. POINTS AWARDED FOR PRICE

3.1.1 THE 80/20 PREFERENCE POINT SYSTEMS

A maximum of 80 points is allocated for price on the following basis:

80/20

$$Ps = 80 \left(1 - \frac{Pt - Pmin}{Pmin} \right)$$

Where

- Ps = Points scored for price of tender under consideration
- Pt = Price of tender under consideration
- Pmin = Price of lowest acceptable tender

3.1.1. POINTS AWARDED FOR PRICE

A maximum of 80 points is allocated for price on the following basis:

80/20

$$Ps = 80 \left(1 + \frac{Pt - Pmax}{Pmax} \right) \circ$$

Where

- Ps = Points scored for price of tender under consideration
- Pt = Price of tender under consideration
- Pmax = Price of highest acceptable tender

4. POINTS AWARDED FOR SPECIFIC GOALS

4.1. In terms of Regulation 4(2); 5(2); 6(2) and 7(2) of the Preferential Procurement Regulations, preference points must be awarded for specific goals stated in the tender. For the purposes of this tender the tenderer will be allocated points based on the goals stated in table 1 below as may be supported by proof/ documentation stated in the conditions of this tender:

Table 1: Specific goals for the tender and points claimed are indicated per the table below.

Note to tenderers: The tenderer must indicate how they claim points for each preference point system.)

The specific goals allocated points in terms of this tender	Number of points allocated (80/20 system)	Number of points claimed (80/20 system)	Proof of documents per specific goals
SMME (An EME or QSE) 51% or more black owned by Black People	20		<ul style="list-style-type: none"> •Valid BBBEE Certificate issued by SANAS accredited verification agency or DTI /CIPC BBBEE Certificate for Exempted Micro Enterprises or Qualifying Small Enterprise or Affidavit sworn under oath.

DECLARATION WITH REGARD TO COMPANY/FIRM

4.2. Name of company/firm.....

4.3. Company registration number:

4.4. TYPE OF COMPANY/ FIRM

- Partnership/Joint Venture / Consortium
- One-person business/sole propriety
- Close corporation
- Public Company
- Personal Liability Company
- (Pty) Limited
- Non-Profit Company
- State Owned Company

[TICK APPLICABLE BOX]

4.5. I, the undersigned, who is duly authorised to do so on behalf of the company/firm, certify that the points claimed, based on the specific goals as advised in the tender, qualifies the company/ firm for the preference(s) shown and I acknowledge that:

- i) The information furnished is true and correct;
- ii) The preference points claimed are in accordance with the General Conditions as indicated in paragraph 1 of this form;
- iii) In the event of a contract being awarded as a result of points claimed as shown in paragraphs 1.4 and 4.2, the contractor may be required to furnish documentary proof to the satisfaction of the organ of state that the claims are correct;
- iv) If the specific goals have been claimed or obtained on a fraudulent basis or any of the conditions of contract have not been fulfilled, the organ of state may, in addition to any other remedy it may have –

- (a) disqualify the person from the tendering process;
- (b) recover costs, losses or damages it has incurred or suffered as a result of that person's conduct;
- (c) cancel the contract and claim any damages which it has suffered as a result of having to make less favourable arrangements due to such cancellation;
- (d) recommend that the tenderer or contractor, its shareholders and directors, or only the shareholders and directors who acted on a fraudulent basis, be restricted from obtaining business from any organ of state for a period not exceeding 10 years, after the *audi alteram partem* (hear the other side) rule has been applied; and
- (e) forward the matter for criminal prosecution, if deemed necessary.

.....	
SIGNATURE(S) OF TENDERER(S)	
SURNAME AND NAME:
DATE:
ADDRESS:

DECLARATION OF BIDDER'S PAST SUPPLY CHAIN MANAGEMENT PRACTICES

- 1 This Municipal Bidding Document must form part of all bids invited.
- 2 It serves as a declaration to be used by municipalities and municipal entities in ensuring that when goods and services are being procured, all reasonable steps are taken to combat the abuse of the supply chain management system.
- 3 The bid of any bidder may be rejected if that bidder, or any of its directors have:
 - a. abused the municipality's / municipal entity's supply chain management system or committed any improper conduct in relation to such system;
 - b. been convicted for fraud or corruption during the past five years;
 - c. willfully neglected, reneged on or failed to comply with any government, municipal or other public sector contract during the past five years; or
 - d. been listed in the Register for Tender Defaulters in terms of section 29 of the Prevention and Combating of Corrupt Activities Act (No 12 of 2004).
- 4 **In order to give effect to the above, the following questionnaire must be completed and submitted with the bid.**

Item	Question	Yes	No
4.1	Is the bidder or any of its directors listed on the National Treasury's Database of Restricted Suppliers as companies or persons prohibited from doing business with the public sector? (Companies or persons who are listed on this Database were informed in writing of this restriction by the Accounting Officer/Authority of the institution that imposed the restriction after the <i>audi alteram partem</i> rule was applied). The Database of Restricted Suppliers now resides on the National Treasury's website (www.treasury.gov.za) and can be accessed by clicking on its link at the bottom of the home page.	Yes <input type="checkbox"/>	No <input type="checkbox"/>
4.1.1	If so, furnish particulars:		
4.2	Is the bidder or any of its directors listed on the Register for Tender Defaulters in terms of section 29 of the Prevention and Combating of Corrupt Activities Act (No 12 of 2004)? The Register for Tender Defaulters can be accessed on the National Treasury's website (www.treasury.gov.za) by clicking on its link at the bottom of the home page.	Yes <input type="checkbox"/>	No <input type="checkbox"/>
4.2.1	If so, furnish particulars:		
4.3	Was the bidder or any of its directors convicted by a court of law (including a court of law outside the Republic of South Africa) for fraud or corruption during the past five years?	Yes <input type="checkbox"/>	No <input type="checkbox"/>

4.3.1	If so, furnish particulars:		
Item	Question	Yes	No
4.4	Does the bidder or any of its directors owe any municipal rates and taxes or municipal charges to the municipality / municipal entity, or to any other municipality / municipal entity, that is in arrears for more than three months?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
4.4.1	If so, furnish particulars:		
4.5	Was any contract between the bidder and the municipality / municipal entity or any other organ of state terminated during the past five years on account of failure to perform on or comply with the contract?	Yes <input type="checkbox"/>	No <input type="checkbox"/>
4.7.1	If so, furnish particulars:		

CERTIFICATION

I, THE UNDERSIGNED (FULL NAME)
CERTIFY THAT THE INFORMATION FURNISHED ON THIS
DECLARATION FORM TRUE AND CORRECT.

I ACCEPT THAT, IN ADDITION TO CANCELLATION OF A CONTRACT,
ACTION MAY BE TAKEN AGAINST ME SHOULD THIS DECLARATION PROVE
TO BE FALSE.

.....
Signature

.....
Date

.....
Position

.....
Name of Bidder

CERTIFICATE OF INDEPENDENT BID DETERMINATION

- 1 This Municipal Bidding Document (MBD) must form part of all bids¹ invited.

- 2 Section 4 (1) (b) (iii) of the Competition Act No. 89 of 1998, as amended, prohibits an agreement between, or concerted practice by, firms, or a decision by an association of firms, if it is between parties in a horizontal relationship and if it involves collusive bidding (or bid rigging).² Collusive bidding is a *pe se* prohibition meaning that it cannot be justified under any grounds.

- 3 Municipal Supply Regulation 38 (1) prescribes that a supply chain management policy must provide measures for the combating of abuse of the supply chain management system, and must enable the accounting officer, among others, to:
 - a. take all reasonable steps to prevent such abuse;
 - b. reject the bid of any bidder if that bidder or any of its directors has abused the supply chain management system of the municipality or municipal entity or has committed any improper conduct in relation to such system; and
 - c. cancel a contract awarded to a person if the person committed any corrupt or fraudulent act during the bidding process or the execution of the contract.

- 4 This MBD serves as a certificate of declaration that would be used by institutions to ensure that, when bids are considered, reasonable steps are taken to prevent any form of bid-rigging.

- 5 In order to give effect to the above, the attached Certificate of Bid Determination (MBD 9) must be completed and submitted with the bid:

¹ Includes price quotations, advertised competitive bids, limited bids and proposals.

² Bid rigging (or collusive bidding) occurs when businesses, that would otherwise be expected to compete, secretly conspire to raise prices or lower the quality of goods and / or services for purchasers who wish to acquire goods and / or services through a bidding process. Bid rigging is, therefore, an agreement between competitors not to compete.

CERTIFICATE OF INDEPENDENT BID DETERMINATION

I, the undersigned, in submitting the accompanying bid:

(Bid Number and Description)

in response to the invitation for the bid made by:

(Name of Municipality / Municipal Entity)

do hereby make the following statements that I certify to be true and complete in every respect:

I certify, on behalf of: _____ that:

(Name of Bidder)

1. I have read and I understand the contents of this Certificate;
2. I understand that the accompanying bid will be disqualified if this Certificate is found not to be true and complete in every respect;
3. I am authorized by the bidder to sign this Certificate, and to submit the accompanying bid, on behalf of the bidder;
4. Each person whose signature appears on the accompanying bid has been authorized by the bidder to determine the terms of, and to sign, the bid, on behalf of the bidder;
5. For the purposes of this Certificate and the accompanying bid, I understand that the word "competitor" shall include any individual or organization, other than the bidder, whether or not affiliated with the bidder, who:
 - (a) has been requested to submit a bid in response to this bid invitation;
 - (b) could potentially submit a bid in response to this bid invitation, based on their qualifications, abilities or experience; and
 - (c) provides the same goods and services as the bidder and/or is in the same line of business as the bidder

6. The bidder has arrived at the accompanying bid independently from, and without consultation, communication, agreement or arrangement with any competitor. However communication between partners in a joint venture or consortium³ will not be construed as collusive bidding.
7. In particular, without limiting the generality of paragraphs 6 above, there has been no consultation, communication, agreement or arrangement with any competitor regarding:
 - (a) prices;
 - (b) geographical area where product or service will be rendered (market allocation)
 - (c) methods, factors or formulas used to calculate prices;
 - (d) the intention or decision to submit or not to submit, a bid;
 - (e) the submission of a bid which does not meet the specifications and conditions of the bid; or
 - (f) bidding with the intention not to win the bid.
8. In addition, there have been no consultations, communications, agreements or arrangements with any competitor regarding the quality, quantity, specifications and conditions or delivery particulars of the products or services to which this bid invitation relates.
9. The terms of the accompanying bid have not been, and will not be, disclosed by the bidder, directly or indirectly, to any competitor, prior to the date and time of the official bid opening or of the awarding of the contract.

³ Joint venture or Consortium means an association of persons for the purpose of combining their expertise, property, capital, efforts, skill and knowledge in an activity for the execution of a contract.

10. I am aware that, in addition and without prejudice to any other remedy provided to combat any restrictive practices related to bids and contracts, bids that are suspicious will be reported to the Competition Commission for investigation and possible imposition of administrative penalties in terms of section 59 of the Competition Act No 89 of 1998 and or may be reported to the National Prosecuting Authority (NPA) for criminal investigation and or may be restricted from conducting business with the public sector for a period not exceeding ten (10) years in terms of the Prevention and Combating of Corrupt Activities Act No 12 of 2004 or any other applicable legislation.

.....
Signature

.....
Date

.....
Position

.....
Name of Bidder

Js9141w 4