

SYMBOL	DESCRIPTION	QTY	MAKE
Z1	SUITABLE ZONE 1 EX LED LUMINAIRE	2	TBC
Z2	SUITABLE ZONE 2 EX LED LUMINAIRE	5	TBC
RM	RAIL MOUNT	7	
FM	FLOOR MOUNT	0	
BM	BUND MOUNT	0	
	PROPOSED CABLE ROUTE		
	EXISTING CABLE		

SPECIAL NOTES:


MINIMUM REQUIRED LIGHTING LUX LEVELS AS PER PL 682 SPEC

NOTES:

1. RACKING TO COMPLY WITH TPL SPECIFICATION PL727.
2. RACKING MATERIAL: GALVANISED STEEL LADDER RACK.
3. RACKING TO BE INSTALLED 300mm CLEAR OF FLANGES (TO ALLOW FOR FLOGGING ACCESS).
4. INSTRUMENT AND ELECTRICAL RACKS TO CROSS AT 90 DEGREES.
5. DOUBLE BANKING OF CABLES ON RACKS IS PERMITTED.
6. RACKING AND ANGLE IRON DROPPERS TO BE SITE RUN.
7. POSITION OF LIGHTS TO BE CONFIRMED ON SITE WITH TPL SITE AGENT AND APPROVAL OF DESIGNS.

RACKING LEGEND

PROPOSAL


ACC TANKS 5&6 LIGHTING LAYOUT
 LANGLAAGTE DEPOT

REVISIONS			
PROJECT NAME			
LIGHTING UPGRADE			
DRAWN	WD	REF.	
TRACED	CAD	DATE	11.10.21
CHECKED	K.N	APPROVED	Z.M
SCALE	NTS		
DRAWING No.	PL122547		REV