


NOTE:-

1. SINGLE WRAP GUY GRIP NOT ACCEPTABLE..
2. STAY TO BE POSITIONED AS CLOSE TO CROSSARM OR EQUIPMENT AS POSSIBLE.
3. MINIMUM DIMENSION FROM BOTTOM OF THE INSULATOR TO GROUND TO BE 4000MM WHERE THERE IS NO EQUIPMENT ON THE POLE. IF THERE IS EQUIPMENT ON THE POLE THE INSULATOR IS TO HANG BELOW THE EQUIPMENT WITH A MINIMUM DISTANCE OF 3000MM FROM THE BOTTOM OF THE INSULATOR TO THE GROUND.
4. FOR ANTI-CLIMBING DEVICE SEE D-DT-0399.
5. STAY GRIP (D-DT-3195) TO BE POSITIONED ABOVE GUYGRIP, FOR APPLICATION SEE D-DT-0341 SH. 5 (IF REQUIRED).

(INFORMATION TAKEN
FROM D-DT-1265)

REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.
<div></div>		STAY ASSEMBLY (MV - 97kN) WOOD POLES				
AUTH:						
DATE:						
CHKD:						
DATE:		D-FS-18231		SET	SHEET	REVISION
DRAWN: PJ BURGER				1	1	1
DATE: 31/05/2021						