

NOTE :

1. NUMBER OF STAYS AS PER DRAWING D-DT-0312.
2. STAYS TO BE PLACED AS CLOSE TO CROSSARM AS POSSIBLE.
3. PHASING CONFIGURATION TO D-DT-0311.

REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	PROJECT NO.

Eskom Distribution

AUTH:

DATE:

CHKD:

DATE:

DRAWN: PJ BURGER

DATE: 31.05.2021

MV HEAVY CONDUCTOR
22kV H-POLE BRACED TERMINAL STRUCTURE
GENERAL ARRANGEMENT

D-FS-18234

SET	SHEET	REVISION
2	1	1

A4L