

 Eskom	Standard	Technology
--	-----------------	-------------------

Title: **SCORING CRITERIA FOR
TENDER TECHNICAL
EVALUATION OF
TRANSFORMERS AND
REACTORS BUSHINGS**

Unique Identifier: **240-86964223**

Alternative Reference Number: **n/a**

Area of Applicability: **Engineering**

Documentation Type: **Standard**

Revision: **2**

Total Pages: **10**

Next Review Date: **July 2026**

Disclosure Classification: **Controlled
Disclosure**

Compiled by



Khayakazi Dioka

**Corporate Specialist
Transformers and Reactors**

Date: 14 July 2021

Approved by



Sidwell Mtetwa

**Corporate Specialist
Transformers and Reactors**

Date: 22 July 2021

Authorized by



Bheki Ntshangase

**Senior Manager SE&D
Asset Management**

Date: 22 July 2021

Supported by SCOT/SC



Bheki Ntshangase

SCOT/SC Chairperson

Date: 22 July 2021

Content

	Page
Executive Summary.....	3
1. Introduction.....	4
2. Supporting clauses	4
2.1 Scope	4
2.1.1 Purpose.....	4
2.1.2 Applicability	4
2.2 Normative/informative references	4
2.2.1 Normative.....	4
2.2.2 Informative	4
2.3 Definitions.....	4
2.3.1 General	4
2.3.2 Disclosure classification.....	5
2.4 Abbreviations.....	5
2.5 Roles and responsibilities	5
2.6 Process for monitoring	5
2.7 Related/supporting documents	5
3. Specification Minimum Requirements	5
3.1 Methodology	5
3.2 Critical Requirements (CRS).....	6
3.2.1 Completeness of documents	6
3.2.2 Functional Requirements	6
3.3 Scored Requirements.....	6
3.4 Factory Assessment.....	6
4. Authorisation.....	7
5. Revisions	7
6. Development team	7
7. Acknowledgements	7
Annex A – Critical Requirements – Completeness of documents.....	8
Annex B – Critical Requirements – Technical Requirements.....	9
Annex C – Discretionary Requirements	10

Tables

Table 1: Technical Scoring Details	6
--	---

Executive Summary

The technical tender evaluation is one of the critical gates in the enquiry chain to ensure that the bidders understand the customer's requirements and they are capable of designing, manufacturing, testing at works, prepare for shipment, transport, and can offer the required after sales technical support services. This tender technical evaluation criterion was created to evaluate all tenders for Capacitance Graded Bushings for Application in Power Transformers and Shunt Reactors, which are in accordance to specification 240-56062799. Compliance with this document will ensure that all suppliers bidding to supply capacitance graded bushings for transformers and reactors to Eskom are evaluated fairly and transparently. It minimises the influence of an individual discretion of a person doing the evaluation. The assessment of each supplier will be based on the information the supplier provided during the tender stage and on the factory assessment.

1. Introduction

This scoring criterion shall be used in conjunction with the Technical Specification for Capacitance-Graded Bushings for Application in Power Transformers and Shunt Reactors in All Eskom Divisions Standard 240-56062799, to ensure that all the suppliers are scored on the same basis and in a transparent manner. This document details the method of evaluating based on

The tender returns as detailed in Annexure A - C

The document shall be used for all capacitance-graded bushings for transformers and reactors, which are according to technical specification 240-56062799. The factory assessment shall form part of contract award requirements.

2. Supporting clauses

2.1 Scope

This document covers only the evaluation criteria of the bushings for transformer and reactors tender returns. It does not specify the requirements of this equipment.

2.1.1 Purpose

This document was produced in order to record the standardized scoring method as per the above scope.

2.1.2 Applicability

This document shall apply throughout Eskom Holdings Limited Divisions. It is applicable to all the *Contractors* that shall be tendering to supply capacitive AC bushings or any other HV bushings, as deemed applicable, to Eskom.

2.2 Normative/informative references

Parties using this document shall apply the most recent edition of the documents listed in the following paragraphs.

2.2.1 Normative

- [1] 240-56062799 Technical Specification for Capacitor Bushings for Application in Power Transformers and Shunt Reactors in All Eskom Divisions Standard

2.2.2 Informative

- [2] ISO 9001 Quality management systems
[3] 32-1034 Eskom procurement and supply management procedure
[4] 240-53207174 Practice note and guide on the implementation of the Preferential Procurement Policy Framework Act (PPPFA)

2.3 Definitions

2.3.1 General

Definition	Description
Contractor	Refers to the supplier or bidder
Equipment	Refers to a transformer or reactor bushing

Definition	Description
Tender returns	A document(s), filled or compiled by the bidder, returned as a response to a tender and were part of the requirements at the time of issuing the enquiry.

2.3.2 Disclosure classification

Controlled disclosure: controlled disclosure to external parties (either enforced by law, or discretionary).

2.4 Abbreviations

Abbreviation	Description
SCOT	Steering Committee of Technology

2.5 Roles and responsibilities

All the Eskom employees and/or appointed bodies involved in the tender technical evaluation shall use this criterion.

2.6 Process for monitoring

This document and its relevance will be periodically evaluated by the relevant SCOT Care Group.

2.7 Related/supporting documents

The schedule A of the relevant AB schedules shall form part of the evaluation.

3. Specification Minimum Requirements

3.1 Methodology

The technical tender evaluation is one of the critical gates in the enquiry chain to ensure that the bidders understand the customer's requirements and they are capable of designing, manufacturing, testing at works, prepare for shipment, transport, and can offer the required after sales technical support services. This evaluation criterion will be used to measure the suppliers or bidders in these parameters. This will be achieved by doing both the desktop exercise using tender returns and prior to awarding a contract, evaluating each factory that is intended for supply of the bushings to Eskom.

Each supplier enters the technical evaluation with 100 points. The technical pass mark is 90 points. This means that, after application of applicable penalty (ies), the supplier must remain with at least 90 points to pass the evaluation, if scoring less than that, the supplier is eliminated from further evaluations. The total applicable penalties do not necessarily add to 100 points and as soon as the remaining points fall below the stipulated thresholds as stipulated, no further evaluation is done.

The scoring details can be summarized as follows

Table 1: Technical Scoring Details

Item	Points	Remarks
Critical Requirements as per Annexure A and Annexure B	80	The supplier is penalised 21 points for each criteria not met.
Scored Criteria as per Annexure C	20	The only tender returns that will progress to this gate are those who remained with a minimum of 80 points from the critical requirements evaluation.
Factory Capability Assessment Evaluation		This will be done pre-contact award and only on the bids that met technical and all other requirements. Only the factories that have been declared accredited after the factory assessment, with no risk outstanding, can proceed to the next commercial process. Any risk identified during the assessment must be addressed within an agreed and reasonable period from the date of written notification.

3.2 Critical Requirements (CRS)

3.2.1 Completeness of documents

The bidder is required to submit all the information required and the document must be correctly completed. The gaps (blanks), TBA, and similar remarks will render the document incomplete. In the cases where the required information is provided as an attachment or accompanying page, it must be so indicated and made easy to reference. If any of the required information is not available, 21 points will be deducted from the 100 points.

3.2.2 Functional Requirements

These are the important parameters that the tenderers must comply with and are not negotiable at all. If the proposal by the bidder does not meet these requirements, 21 points will be a penalty for each deviation and resulting in an immediate disqualification. Parameters that are guaranteed to a value positively tighter than Eskom's requirements, without altering the functionality and compatibility will neither be penalized nor extra-awarded.

The list of all critical requirements are provided in Appendix A and B of this document.

3.3 Scored Requirements

Each deviation on these items will be penalized as indicated in the penalty lists of Annexures C. A supplier must not lose more than 10 points from this section out of 20 points. Any penalties exceeding 10 points will result in the supplier being disqualified.

3.4 Factory Assessment

The factory assessment will be done for each factory that is intended to supply Eskom with the bushings. Companies that have more than one factory will not be getting a blanket assessment; each factory will be evaluated on its own merit.

The critical areas during factory assessment will at least include:

- Factory profile indicating the range of bushings the factory can produce.
- Design criteria bases and guidelines
- Design process flow, tools and competencies
- Research and Development capabilities and partners
- Factory Equipment and Plant capacity

ESKOM COPYRIGHT PROTECTED

Factories that have been previously evaluated, have a signed accreditation, and have supplied Eskom with bushings in the last 5 years may be exempted from this requirement and this will be at Eskom's discretion. This assessment could be either physically or virtually.

4. Authorisation

This document has been seen and accepted by

Name and surname	Designation
Bheki Ntshangase	Senior Manager – Substation Equipment and Diagnostics & SCOT Plant SC Chairman
Sidwell Mtetwa	Corporate Specialist - Substation Equipment and Diagnostics and SCOT Transformers CG Chairman
Mashilo Moabelo	Senior Engineer – Substation Equipment and Diagnostics - Transmission
Mantsie Hlakudi	Chief Engineer - Substation Equipment and Diagnostics - Transmission
Thapelo Ndlovu	Senior Advisor - Transmission Transformers ETT Chairperson
Mohamed Mukuddem	Engineer - Distribution Transformers ETT Chairperson
Lionel Jordaan	Senior Consultant - Generation Transformers ETT Chairperson

5. Revisions

Date	Rev	Compiler	Remarks
July 2021	2	K Dioka	Revised Annexures A,B and C Revised to align with commercial requirements Document changed from a report to a standard
July 2019	1	K Dioka	New Document

6. Development team

This document was developed by Khayakazi Dioka and Sidwell Mtetwa.

7. Acknowledgements

Not applicable.

Annex A – Critical Requirements – Completeness of documents

No	Item details	Score		Remarks
1	Are the technical schedules completely filled and all the information provided?	Y	N	
2	Drawing Provided	Y	N	

Note: A “No” in any of these items will mean a deduction of 21 points.

Annex B – Critical Requirements – Technical Requirements

Bushings Evaluation Criteria		Requirement	Yes	No	Remarks
	Product Type Number				
1.1	Technology Requirements				
1.1.1	Dry Type Bushing	as per schedule A	0	-21	
1.1.2	Capacitive (Y/N)	Yes	0	-21	
1.1.3	Shed Materials (Composite/Porcelain)	as per schedule A	0	-21	
1.2	Ratings				
1.2.1	Dielectric (BIL, SIL, Applied 1 minute)	as per schedule A	0	-21	
1.2.2	Electric (current and rated voltage)	as per schedule A	0	-21	
1.2.3	Mechanical (Cantilever and seismic)	Minimum, as per schedule A	0	-21	
1.3	Dimensions				
1.3.1	Stems and flanges	as per Schedule A	0	-21	
1.3.2	Air vent	present	0	-21	

Note: A "No" in any of these items will mean a deduction of 21 points.

Annex C – Discretionary Requirements

Total points: 20

2	Discretionary Requirements					
		Requirement	0	-2	-5	Remarks
2.1	Oil side dimensions	as per schedule	Perfect fit that complies with requirements	Acceptable with deviations that need no modification of turrets, CTs or winding connections	Not acceptable as they required modifications	
2.2	Conductor (cable, removable solid rod, flexible)	as per schedule A	Complies with requirements	Acceptable with deviations	Not Acceptable	
2.3	Lifting lugs	As per clause 3.9 – 240-56062799	Complies with requirements		Not acceptable	
2.4	Test points	permanent connection, self-grounded, sealing	Complies with requirements		Not acceptable	
2.5	Corona shield technology	Aluminium epoxy coated	Complies with requirements		Not acceptable	
2.6	Creepage distance	31mm/kV	Complies with requirements		Not acceptable	
2.7	Ambient Parameters compliance	-10 to 50	Complies with requirements	-10 to 40	Out of range	
2.8	Type test certificates/reports (dielectric, thermal, environment)	present	Acceptable		Not acceptable/ not provided	
2.9	Prevention of moisture ingress to the condenser	fiberglass tube	Provided in the design		Not provided in the design	