

TENDER CLARIFICATION

REQUEST FOR QUOTATION MOOKODI EXTENSION & 1ST 500MVA TRANSFORMER STRINGING & CABLING

Clarification 02	Request For Proposal No. E2621NTCSAMWP,
------------------	-----------------------------------------

The following clarification is needed in response to queries and questions raised by Tenderers.

Clarification Request in **BLACK** and Clarification Response in **RED**

Items	Clarification / Discussion																				
01	<p>May you please send through specifications for the SCADA panels as in the BOQ. Item 62 and 63.</p> <table style="width: 100%; border-collapse: collapse; margin-top: 10px;"> <tr> <td style="width: 15%;"></td> <td style="width: 60%;">TeleControl (SCADA):</td> <td style="width: 10%;"></td> <td style="width: 10%;"></td> <td style="width: 5%;"></td> </tr> <tr> <td></td> <td>Supply and deliver the following:</td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;">62</td> <td>Supply and install patch panels, boxes and leads.</td> <td style="text-align: center;">no.</td> <td style="text-align: center;">42</td> <td></td> </tr> <tr> <td style="text-align: center;">63</td> <td>Supply and install Ethernet switches, patch panels, boxes and leads.</td> <td style="text-align: center;">no.</td> <td style="text-align: center;">14</td> <td></td> </tr> </table>		TeleControl (SCADA):					Supply and deliver the following:				62	Supply and install patch panels, boxes and leads.	no.	42		63	Supply and install Ethernet switches, patch panels, boxes and leads.	no.	14	
	TeleControl (SCADA):																				
	Supply and deliver the following:																				
62	Supply and install patch panels, boxes and leads.	no.	42																		
63	Supply and install Ethernet switches, patch panels, boxes and leads.	no.	14																		
01	<p>The Ethernet switches will be installed by the protection scheme supplier. Attached is the proforma template for the supply of patch panels and patch boxes; they may request the catalogue from the supplier if required.</p>																				
02	<p>Can you please advise if the 500MVA transformer is on the plinth already or we will have to transport it to site and place it on the plinth.</p>																				
02	<p>Transportation and installation of the 500MVA Transformer will be done by manufacture of the transformer (OEM). QS will remove it from the BOQ.</p>																				
03	<p>Please could you extend the closing date of 30th April 2026</p>																				
03	<p>Extension Granted to 21 May 2026</p>																				