

Bidder question

Good Day

Please assist with the below query specifications for electrical components on Bill No.8 (PV Conduit);

NO1: Size of DB

NO2: Size of cable tray

NO3: Which cable tray supports

NO4: Depends on NO2

NO5: Size of trunking

NO6: Which cable tray supports

NO7: For which trunking

NO9: Which color power skirting

NO10: Same as NO9

NO12: Which color GPW

NO13: What sizes

NO16: What type Din rail or samite

NO18: What type of 4x4 boxes

NO20: Which type

## Response to Bidder Question

NO1: Size of DB... **1000mm x 400mm x 120mm**

NO2: Size of cable tray... **300mm**

NO3: Which cable tray supports... **for Soffit Suspension 300mm Cable Trays**

NO4: Depends on NO2

NO5: Size of trunking... **300mm**

NO6: Which cable tray supports... **Soffit Suspension for 300mm**

NO7: For which trunking... **300mm**

NO9: Which color power skirting... **Motor Craft Grey**

NO10: Same as NO9

NO12: Which color GPW ... **L1 - Red, L2 - Yellow, L3 - Blue, Neutral - Black, Earth - Green-Yellow**

NO13: What sizes... **2,5mm dia**

NO16: What type Din rail or samite.. **DIN Rail (EN60715 or Equivalent)**

NO18: What type of 4x4 boxes... **PVC**

NO20: Which type