


DETAIL OF SAND FILLED CABLE TRENCH
INSIDE TRANSFORM BUND AREA

NOTES:

1. SCREED TO BE 25mm MIN THICKNESS
2. SCREED TO BE 1:3 CEMENT/RIVER SAND MIX
3. SAND FILL TO BE WELL COMPACTED



DRAWN GETEKEN	W.M	28-3 2017	CHKD NAGES	C.F	31-3 2017	AUTH MAS		31-3 2017	REV	1	DATE DATUM	
H.V. YARD CIVIL WORK STANDARD DETAILS									0.54/390			
									SHEET 68			
DRG. TEK REGISTR												