



NOTE:
CONCRETE GRADE 25/13

SINGLE CABLE TRENCH

(600x450 FOR SVC)

C.A.D. DRG. NAME: 390K15B.DGN
C.A.D. REFERENCE No. MUTS 0.54 / 390L015B.R00-01

**TRANSMISSION
SUBSTATION
TECHNOLOGY
DEPARTMENT**



ESKOM

DRAWN
GETEKEN

DJC.S

03.94

CHKD
NAGES

D.N.

03.94

AUTH
MAS

DJC.S

28/
03/94

REV

0

DATE
DATUM

H. V. YARD CIVIL WORK
STANDARD DETAILS

0.54/390

SHEET 15B