

C.A.D. DRG NAME: 390K37B.DGN

C.A.D. REF No.MUTS 0.54/390L037B.R00;01

TRANSMISSION
SUBSTATION
TECHNOLOGY
DEPARTMENT



DRAWN
GETEKEN

DJC.S 10/94

CHKD
NAGES

AUTH
MAS

DJC.S

28/
10/94

REV

0

DATE
DATUM

H. V. YARD CIVIL WORK
STANDARD DETAILS

0.54/390

SHEET 37B

FRAME TO BE 60x60x5mm
ANGLE CAST IN AND GALV

NOSING PLATE

25x5mm FLATx100 LONG
FISHTAIL LUGS WELDED TO
ANGLE (5mm FILLET) AT
500mm c/c

M S GRATING WITH 60x5,5 BEARER BARS
(TYPE B RS40 25 BEARERS/m) FULLY BANDED
AND GALVANISED - A NON SLIP NOSING PLATE
(OPEN TYPE) TO BE WELDED TO UNDERSIDE OF
GRATING

TERRACE LEVEL

YARD STONE

RIVER SAND

MESH REF 245

CABLE TRENCH RAMP DETAIL (ALTERNATIVE WITH GALV GRATING)

DETAIL 37B

NOTE:
CONCRETE GRADE 25/13