

PLAN



SECTION A-A

SECTION B-B

NOTES

1. WHEN TOP OF OIL DAM IS LEVEL WITH TERRACE AND BUNDWALL HEIGHT 300mm NO STEPS OR HANDRAILS REQUIRED
2. IF TOP OF OIL DAM LEVEL IS MORE THAN 200 BELOW TERRACE LEVEL AND HEIGHT FROM TOP OF WALL TO TOP OF DAM IS MORE THAN 500mm THEN ACCESS STEP AND HANDRAIL ONTOP OF WALL IS REQUIRED

OIL DAM ACCESS STAIRS

ESKOM	DRAWN GETEKEN	DJC.S	07/07 2017	CHKD NAGES	DB.N.	07/07 2017	AUTH MAS		7.7.20	REV	0	DATE DATUM	07/07 2017
	H.V. YARD CIVIL WORK STANDARD DETAILS									0.54/390			
	DRG.TEK REGISTR									SHEET 74a			