




REINFORCEMENT :

FLOORS : MESH METRIC REF 245

WALLS : 10 mm RODS BOTH WAYS AT 150 mm CRS

ALL WALLS & FLOORS 100 mm THICK

DETAIL 29

COVERS
TO SUIT**ARRANGEMENT OF
TRENCH COVERS****CABLE TRENCH
CROSSING DETAIL**CONC. SLAB MESH
REINFORCED METRIC
FABRIC NO. 245FOR TRENCH SECTIONS SEE DETAIL 15 & 16.
FOR STEEL SUPPORTS SEE DETAIL 18.
FOR TRENCH COVERS SEE DETAIL 17A.THE C.A.D. REFERENCE NUMBER IS :
MUTS0.54/00390K29.R04DRAWN
GETEKEN

Z.K.F.

23/4/80

CHKD
NAGES

R.J.C.

AUTH
MAS

J.J.

REV

4

DATE
DATUM

12/12/94

**H V YARD CIVIL WORK
STANDARD DETAILS****0.54/390****SHEET 29**DRG. TEK
REGISTR

A4L