



100mm WIDE GAPS WIDTH OF FLOOR FILLED WITH NO-FINES CONCRETE FOR DRAINAGE AT APPROX. 3m INTERVALS ALONG FLOOR

NOTE:  
CONCRETE GRADE 25/13

## DOUBLE CABLE TRENCH

( ALTERNATIVE FOR SHALLOW ROCK )

C.A.D. DRG. NAME: 390K16A.DGN  
C.A.D. REFERENCE No. MUTS 0.54/390L016A.R00-01

**TRANSMISSION  
SUBSTATION  
TECHNOLOGY  
DEPARTMENT**  
  
**ESKOM**

DRAWN GETEKEN	DJC.S	03.94	CHKD NAGES	D.N.	03.94	AUTH MAS	DJC.S	28/ 03/94	REV	1	DATE DATUM	14/7 1995
H. V. YARD CIVIL WORK STANDARD DETAILS										0.54/390		
										SHEET 16A		