

# PHOKWANE LOCAL MUNICIPALITY

## HARTSWATER BULK WATER SUPPLY UPGRADE

# TENDER DRAWINGS VOLUME 3

CONTRACT NUMBER: PLM/TUPG01/1611 - 2025 NOVEMBER 2025



		REGISTER: HARTSWATER BULK WATER SUPPLY UPGRADE
/ERSION	DRAWING NUMBER	DRAWING DESCRIPTION
		CIVIL DRAWING
		GENERAL
1.0	2024-06-G/A/001	DRAWING REGISTER
1.0	2024-06-G/D/001	CONTRACT NAME BOARD
1.0	2024-06-G/E/001	ENGINEERS CAMP
1.0	2024-06-G/P/001	LOCALITY MAP
		CITE LAVOLITE
	I	SITE LAYOUTS
1.0	2024-06-A/P/001	REFURBISHMENT AND DECOMMISSIONING OF EXISTING INFRASTRUCTURE SITE LAYOUT
1.0	2024-06-A/P/002	EXISTING, REFURBISHED AND NEW INFRASTRUCTURE SITE LAYOUT
1.0	2024-06-A/P/003	PROPOSED FINAL INFRASTRUCTURE SITE LAYOUT
		STRUCTURE LAYOUTS
1.0	2024-06-B/P/001	SLUDGE POND, CCC, TWT, BRT AND MACHINE ROOM LAYOUT
1.0	2024-06-B/P/002	SLUDGE POND LAYOUT & DETAILS
1.0	2024-06-B/P/003	CHLORINE CONTACT CHANNEL, TREATED WATER TANK AND BACKWASH RECOVERY TANK LAYOUT & DETAILS
1.0	2024-06-B/P/004	MACHINE ROOM LAYOUT & DETAILS
1.0	2024-06-B/P/005	TRANSFORMER AND GENERATOR BUILDING LAYOUT & DETAILS
1.0	2024-06-B/P/006	SLUDGE DRYING BEDS LAYOUT & DETAILS
1.0	2024-06-B/P/007	FLASH MIXER CHAMBER
1.0	2024-06-B/P/008	SUPERNATANT PUMP STATION AND PIPE WORK CHAMBER
1.0	2024-06-B/P/009	CHLORINATION BUILDING
1.0	2024-06-B/P/010	ADMIN BUILDING
1.0	2024-06-B/P/011	GUARD HOUSE
	1	PUMP MAINS
	2024 25 11/2/224	
1.0	2024-06-W/P/001	NEW PUMP MAIN LAYOUTS TO RESERVOIR
	•	DETAILS
1.0	2024-06-B/A/001	DOOR AND WINDOW SCHEDULE
1.0	2024-06-B/D/001	TYPICAL STRUCTURE DETAILS
1.0	2024-06-R/D/001	TYPICAL ROAD AND PAVING DETAILS
1.0	2024-06-F/D/001	STEEL MESH PANEL FENCE DETAILS
1.0	2024-06-F/D/002	STEEL MESH PANEL SLIDING GATE DETAILS
1.0	2024-06-F/D/003	SECURITY FENCING (WELDED RAZOR MESH, DIAMOND MESH AND FLAT WRAP)
1.0	2024-06-W/A/001	TYPICAL CHAMBER DETAILS
1.0	2024-06-W/D/001	TYPICAL AIR VALVE INSTALLATION DETAILS
1.0	2024-00-W/D/001	WATER METER INSTALLATION LAYOUT & DETAILS FOR 200ND & 250ND WATER METER INSTALLATION ON 250mmØ TO
1.0	2024-06-W/D/002	350mmØ WATER MAIN
1.0	2024-06-W/D/003	TYPE 1 & TYPE 2 SCOUR VALVE INSTALLATION LAYOUT AND DETAILS
1.0	2024-06-W/D/004	TYPE 3 & TYPE 4 SCOUR VALVE INSTALLATION LAYOUT AND DETAILS
1.0	2024-06-W/D/005	TYPICAL GATE VALVE INSTALLATION IN PRECAST MANHOLE
1.0	2024-06-W/D/006	TYPICAL SLEEVE PIPE DETAILS AND CONCRETE ENCASEMENT FOR WATER PIPELINES
1.0	2024-06-W/D/007	TYPICAL WATER MAIN INSTALLATION DETAILS
1.0	2024-06-W/D/008	TYPICAL END-STRUCTURE, GARDEN TAP AND STOP COCK DETAILS
1.0	2024-06-S/D/001	TYPICAL SEWER MANHOLE, RODDING EYE AND MARKER DETAILS
		MECHANICAL DRAWING
		GENERAL ARRANGEMENT
0.5	DYN-075-006-001	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RAW WATER PUMP SET LAYOUT SHEET 1 OF 2
0.5	DYN-075-006-002	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RAW WATER PUMP SET LAYOUT SHEET 2 OF 2
0.5	DYN-075-006-003	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT HIGH LIFT PUMP SET NO 1 LAYOUT SHEET 1 OF 2
0.5	DYN-075-006-004	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT HIGH LIFT PUMP SET NO 1 LAYOUT SHEET 2 OF 2
0.5	DYN-075-006-005	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT HIGH LIFT PUMP SET NO 2 LAYOUT SHEET 1 OF 3
0.5	DYN-075-006-006	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT HIGH LIFT PUMP SET NO 2 LAYOUT SHEET 2 OF 3
0.5	DYN-075-006-007	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT HIGH LIFT PUMP SET NO 2 LAYOUT SHEET 3 OF 3
0.5	DYN-075-006-008	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT SERVICE WATER PUMP SET LAYOUT SHEET 1 OF 3
0.5	DYN-075-006-009	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT SERVICE WATER PUMP SET LAYOUT SHEET 2 OF 3
0.5	DYN-075-006-010	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT SERVICE WATER FUMP SET LAYOUT SHEET 3 OF 3
0.5	DYN-075-006-011	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RECOVERY WATER PUMP SET LAYOUT SHEET 1 OF 4
0.5	DYN-075-006-012	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RECOVERY WATER PUMP SET LAYOUT SHEET 2 OF 4
0.5	DYN-075-006-013	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RECOVERY WATER PUMP SET LAYOUT SHEET 3 OF 4
0.5	DYN-075-006-014	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RECOVERY WATER PUMP SET LAYOUT SHEET 4 OF 4
0.5	DYN-075-006-014	EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT RECOVERT WATER PUMP SET LATOUT SHEET 1 OF
0.5	WCE-2025-06-001	GENERAL ARRANGEMENT: SUPERNATANT PUMP STATION BUILDING SHEET 1 OF 2
0.1	WCE-2025-06-001	GENERAL ARRANGEMENT: SUPERNATANT PUMP STATION BUILDING SHEET 2 OF 2
0.1	WCE-2025-06-001a	GENERAL ARRANGEMENT: SOPERINATANT POWER STATION BOILDING SHEET 2 OF 2  GENERAL ARRANGEMENT: TYPICAL DRAINAGE PUMP STATION
U.1	VVCL-2023-00-002	GENERAL ANNANGENTERS. TITICAE DIVANINAGE FUNIF STATION
	i .	
		FIECTRICAL DRAWING
0.1	WCE-2025-06-003	ELECTRICAL DRAWING SITE PLAN EXTERNAL AREA LIGHTENING

REV	isions				
No.	DATE	BY		DE	SCRIPTION
NOT	res				
NO	E3				
REF	ERENCE	DRAWI	NGS		
PLA	N Nr.		-	DESCRIF	TION
$\vdash$					
APPROV					DATE
APPROV					DATE:
CLIENT:_					DATE:
PRINT	ISSUED ON				
4	Tse	ٔ داد	Tsw	101	





PHOKWANE LOCAL MUNICIPALITY

UPGRADING OF HARTSWATER WATER TREATMENT PLANT

PHOKWANE LM


DRAWING REGISTER

	DESIGN	DATE	DRAWN	DATE
ı	-	JUN 2025	=	JUN 2025
	SURVEYED	DATE	CHECKED	DATE
ı	-	-	J.BATEMAN	JUN 2025

SCALE

2024-06-G/A/001

REVISION No.



-	$\overline{}$	GALVANISED STEEL PIPE			
		25mmx25mmx2.5mm THICK SQUARE TUBING 40mm Ø x 4.6mm THICK			
		GALVANISED WASHER			
		32mmx32mm STEEL CABLE RACKING ——250mm LONG, WELDED TO			
Щ		SQUARE TUBING FRAME	REV	/ISIONS	
_		30mm Ø x 4.6mm THICK	No.	DATE	BY
		GALVANISED WASHER 100mm LONG M16 GALVANISED			
		BOLT AND NUT			
		-	1	1	1

No.	DATE	BY	DESCRIPTION

#### NOTES

- LETTERS TO BE CAPITALISED.

- All lettering to be painted on. Stick-on labels will NOT be permitted.

REFERENCE DRAWINGS					
PLAN Nr.	DESCRIPTION				





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

PHOKWANE LM

PROJECT NAME BOARD

DESIGN	DATE	DRAWN	DATE
-	JUN 2025	-	JUN 2025
SURVEYED	DATE	CHECKED	DATE
-	-	J.BATEMAN	JUN 2025

AS SHOWN

SCALE

2024-06-G/D/001



TYPICAL MOBILE OFFICE



OFFICE DESK



**BOARDROOM TABLE** 



A1 PLAN TROLLEY (20 CLAMP CAPACITY)



**ROTATING HIGH BACK CHAIR** 




RICKSTACKER CHAIR




**STATIONARY CABINET** 



**FILING** CABINET





ENGINEERS OFFICE & BOARDROOM

• MODULAR BUILDING TO SUIT SIZE AS SPECIFIED ON DETAIL LAYOUT
• 12000 BTU SPLIT AIRCON UNIT (LG) TO BE PROVIDED IN OFFICE.
• 24000 BTU SPLIT AIRCON UNIT (LG) TO BE PROVIDED IN BOARDROOM.
• OFFICES TO BE CLEANED ON A DAILY BASIS

OFFICE FURNITURE (ALL FURNITURE TO BE NEW)

1. 1 x OFFICE DESK INCLUDING DRAWERS AND SHELVES

2. 1 x A1 PLAN TROLLEY (20 CLAMP CAPACITY)

3. 1 x 4 DRAWER FILING CABINET.

4. 1 x ROTATING HIGH BACK CHAIR.

5. 15 x RICKSTACKER CHAIRS.

6. 2 x PLASTIC ROUND WASTE BINS.

7. 4 x 2m x1.2m MAGNETIC WHITE BOARDS.

8. 3 x FULL STATIONERY CUPBOARDS.

9. 2 x 2500x900mm BOARDROOM TABLES.

9. 2 x 2500x300mm BOARDROOM TABLES.

STATIONERY PACKAGE (TOTAL # OF SETS SPECIFIED IN TENDER DOCUMENT)

• 1 x PENGL & LEAD

• 1 x ERASER

• 1 x CORRECTION FLUID

• 1 x PRESTIK

• 1 x PRITT

• 1 x SCISSOR

• 4 x MAGNETS

• 1 x STAPLER & BOX OF STAPLES

• 1 x PUNCH

• 1 x BOX RUBBER BANDS

• 1 x BOX A4 PAPER

RESIDENT ENGINEER COMMUNICATION PACKAGE(S) (TOTAL NO. SETS SPECIFIED IN TENDER DOCUMENT) • LAPTOP

 DATACARD
 PRINTER, FAX, COPIER • 2 x 3m EXTENSION CORDS

CAMERA
 TELEPHONE

KITCHEN (NEW)
• 1 x 220I FREEZER REFRIGERATOR COMBO


• 1 x 20I MANUAL MICROWAVE OVEN (800W) • 1 x 1.7L KETTLE

1.x 1.71. KETTLE
 1.x DOUBLE HOT PLATE (SOLID PLATE)
 6.x MUGS, PLATES, UTENSILS (KNIVES, FORKS, TEASPOONS)
 DISPOSABLE CUPS, KNIVES, FORKS, TEASPOONS (PROVIDED AND MAINTAINED ON A MONTHLY

BASIS)

• COFFEE, TEA, BOTTLED WATER & MILK (PROVIDED AND MAINTAINED ON A MONTHLY BASIS)

• PAPER TOWEL, CLEANING MATERIALS (DISHWASHING LIQUID, HANDY ANDY, FURNITURE POLISH, CLOTHS, SPONGES), HAND SOAP AND TOILET PAPER (PROVIDED AND MAINTAINED ON A MONTHLY BASIS)



TYPICAL SITE LAYOUT

REVISIONS DATE DESCRIPTION NOTES

REFERENCE I	DRAWINGS			
PLAN Nr.	DESCRIPTION			
APPROVED:				
ENGINEER:	DATE:			
APPROVED:				
CLIENT:	DATE:			
PRINT ISSUED ON				





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM


**ENGINEERS CAMP** 

DESIGN	DATE	DRAWN	DATE
Ē	JUN 2025	=	JUN 2025
SURVEYED	DATE	CHECKED	DATE
-	-	J.BATEMAN	JUN 2025

AS SHOWN

2024-06-G/E/001





REV	/ISIONS					
No.	DATE	BY	DESCRIPTION			
NOTES						
		EXISTING	STRUCTURE			

EXISTING PIPE TO BE DECOMMISSIONED

REFERENCE DRAWINGS

PHOKWANE LOCAL MUNICIPALITY

UPGRADING OF HARTSWATER WATER TREATMENT PLANT

PHOKWANE LM

REFURBISHMENT AND DECOMMISSIONING OF EXISTING INFRASTRUCTURE SITE LAYOUT


DESIGN	DATE	DRAWN	DATE
Ē	JUN 2025	÷	JUN 2025
SURVEYED	DATE	CHECKED	DATE
-	-	J.BATEMAN	JUN 2025


SCALE 1:500


2024-06-A/P/001





-	JUN 2025	-	JUN 2025
SURVEYED	DATE	CHECKED	DATE
-	-	J.BATEMAN	JUN 2025























#### GENERAL DESCRIPTIONS: CONCRETE WORK:

CUPICATION, SAVE AS MAY BE AMENDED OR ADDED TO HEREAFTER.

1.1 THE WALL FOUNDATION SHALL BE CAST ON A BLINDING OF 50mm MINIMUM THICKNESS.
1.2 MINIMUM SAFE BEARING PRESSURE REQUIRED - 150KPA

CONCRETE:

2.1 CONCRETE DESIGN HAS BEEN BASED ON A MAXIMUM CRACK WIDTH OF 0.1mm IN ACCORDANCE WITH BS 8007: 1997

2.2 CONCRETE CLASSES:
ALL STRUCTURAL CONCRETE: 35MPa/19mm.
BLINDING: 15MPa/19mm.

2.3 CONCRETE COVER TO REINFORCEMENT INCLUDING LINKS SHALL BE 50mm

REINFORCEMENT:
3.1 ALL REINFORDING STEEL SHALL BE WIRE-BRUSHED AND KEPT CLEAN AND FREE OF ANY MILL-SCALE, RUST, OIL OR ANY OTHER DELETERIOUS COMPOUNDS.
3.2 WELDING ON REINFORCING STEEL WILL NOT BE PERMITTED.
3.3 ALL REINFORCING STEEL, FIXED IN POSITION ON SITE SHALL BE CHECKED BY THE ENGINEER PRIOR TO CONCRETING.

FORM WORK:
4.1 FORM WORK SHALL BE ERECTED AND FIXED IN AN APPROVED MANNER AND SHALL BE INSPECTED BY THE ENGINEER PRIOR TO CONCRETING.
4.2 STRIPPING TIMES OF THE FORM WORK SHALL BE AS SPECIFIED IN THE SPECIFICATION OR AS PER THE ENGINEERS SITE INSTRUCTIONS.

DESIGN STRENGTH:

6.1 REINFORCING: HIGH YIELD fy = 450 MPa MILD STEEL fy = 250 MPa

REVISIONS No. DATE BY

DESCRIPTION

NOTES

REFERENCE DRAWINGS			
PLAN Nr.	DESCRIPTION		

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM


**FLASH MIXER CHAMBER** 


Н	DESIGN	DATE	DRAWN	DATE
Н		JUN 2025	-	JUN 2025
Н	SURVEYED	DATE	CHECKED	DATE
Ш	-	-	J.BATEMAN	JUN 2025


SCALE AS SHOWN


2024-06-B/P/007












**SECTION Y-Y** SCALE 1:25




#### **NORTH ELEVATION** SCALE 1:50



SCALE 1:50



#### **EAST ELEVATION** SCALE 1:50



**WEST ELEVATION** 

SCALE 1:50

#### GENERAL DESCRIPTIONS: BUILDING WORK

NOTE: ALL BUILDING WORK TO BE IN LINE WITH SANS 10400.

FOUNDATION: CONCRETE CLASS 35MPa/19 STRIP FOOTING.

WALLS:
INTERNAL WALLS STOCK BRICK, PLASTERED AND PAINTED, EXTERNAL WALLS
HARD-BURNT FIRST GRADE CLAY FACE BRICKS (FBS) TO CLIENT AND ENGINEER'S
APPROVAL.
ENTIRE ORDER TO BE DELIVERED TO SITE PRIOR TO CONSTRUCTION AND BRICKLAYER
TO WORK FROM AT LEAST 4 x BATCHES SIMULTANEOUSLY IN ORDER TO PREVENT THE
COCUPRENCE OF A PATCHY APPEARANCE. HORIZONTAL JOINTS TO BE CHAMFERED TO
FORM SHOULDER MAX. 10mm DEEP AND STRUCK EVEN AND SMOOTH PERPS TO BE
FLUSH, EVEN AND SMOOTH. ALL FACE BRICK WORK TO BE DELIVERED CLEAN AND FREE
FROM MORTAR STAINS.

FLOORS:
100mm THICK CONCRETE CLASS 15MPa/19 SLAB WITH 50mm THICK STEEL FLOATED
SCREEN, FINISHED WITH FLEXIBLE POLYURETHANE COATING SYSTEM
"abocote PU" OR SIMILAR AND APPROVED WITH NON SLIP DRESSING, GRAIN SIZE
TO BE FINALISED WITH CLIENT. COLDUR GREEN WITH YELLOW SAFETY MARKINGS AT
WALKING AND WORKING AREAS, ALL IN ACCORDANCE TO MANUFACTURERS
INSTRUCTION.

ROOF:
TRUSSES
:SA PINE GANGNAIL TRUSSES SPACED AT MAX 1000mm C/C.
ALL TRUSSES TO BE SUPPORTED ON 114mm x 38mm SA PINE WALL PLATE.
PURLINS
: SA PINE PURLINS SPACED AT MAX 1000mm C/C.
BRANDERING SAP NIE BRANDERING SPACED AT MAX 4000mm C/C.
ROOF SHEETS: 0.6mm THICK IBR CHROMADEK SHEETING. COLOR AS PER CLIENTS
SPECIFICATIONS.

CEILING
:6.4mm THICK RHINO BOARD FINISHED OFF WITH RHINO CORNICE ON
ALL EDGES.

RISK CONTROL

A DHERE TO DIESEL TANK CODE OF PRACTICE.
PLACE APPROPRIATELY SIZED SIGNAGE.

A PPROPRIATE SIZE OF FIRE EXTINGUISHERS SHOULD BE PLACED.
CONTINGENCY PLAN MUST BE IN PLACE.

## DOORS & WINDOWS: AS PER DOOR & WINDOW SCHEDULES.

DAMP PROOF:

WATER PROOFING: PLASTIC SHEETING UNDER COMPLETE FLOOR & BASE SLABS.

APPROVED DAMP PROOF COURSE IN WALLS UNDER WINDOW SILLS.

REVISIONS DATE DESCRIPTION NOTES

REFERENCE DRAWINGS





PHOKWANE LOCAL MUNICIPALITY

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

PHOKWANE LM

#### **GUARD HOUSE**

DESIGN -	DATE JUN 2025	DRAWN -	DATE JUN 2025
SURVEYED	DATE	CHECKED	DATE
•		J.BATEMAN	JUN 2025

SCALE AS SHOWN

2024-06-B/P/011

#### ADD FOR DINING REST AND ABLUTION

WINDOW SCHEDULE	2000	92.	250	160mmØ VENT PIPE.  600 600 88 EXTRACTION FAN.	000	1022
TYPE	W1 (3 OFF)	W2 (4 OFF)	W3 (X OFF)	W4 (3 OFF)	W5 (6 OFF)	W6 (2 OFF)
DESCRIPTION	STANDARD RESIDENTIAL STEEL PROFILE	STANDARD RESIDENTIAL STEEL PROFILE	STANDARD RESIDENTIAL STEEL PROFILE	WINBLOCK WB 66 260(590x590)	WINBLOCK WB 66 260(590x590)	STANDARD RESIDENTIAL STEEL PROFILE NCS WITHOUT CENTER MULLION
FITTINGS	STANDARD CHROMIUM PLATED	STANDARD CHROMIUM PLATED	STANDARD CHROMIUM PLATED	TWO WINVENTS (TOP HUNG) TYPE WVS 66T THREE WITH TINTED FIXED GLAZING DIRECTLY INTO WINBLOCK ONE LEFT OPEN FOR EXTRACTION FAN	TWO WINVENTS (TOP HUNG) TYPE WVS 66T FOUR WITH TINTED FIXED GLAZING DIRECTLY INTO WINBLOCK	NOT APPLICABLE
GLASS	4mm CLEAR DRAWN GLASS AS PER NBR	4mm CLEAR DRAWN GLASS AS PER NBR	4mm OBSCURED GLASS AS PER NBR	FACTORY GLAZED (515x515), TINTED	FACTORY GLAZED (515x515), TINTED	IN ACCORDANCE TO SANS 0400-1990, PART N, TABLE 1 (4mm THICK)
FINISH	FACTORY APPLIED PRIME COAT. ONE UNDERCOAT AND TWO COATS ENAMEL	FACTORY APPLIED PRIME COAT. ONE UNDERCOAT AND TWO COATS ENAMEL	FACTORY APPLIED PRIME COAT. ONE UNDERCOAT AND TWO COATS ENAMEL	POWDER COATED	POWDER COATED	PRIME COAT, ONE UNDERCOAT TWO COATS POLYURETHANE ENAMEL

DOOR SCHEDULE	1745 051 cd	900	32 814 32 26 1	914	3 000	1524
TYPE	D1 (1 OFF)	D2 (3 OFF)	D3 (5 OFF)	D4 (1 OFF)	D5 (1 OFF)	D6 (3 OFF)
FRAME	ALUMINIUM FRAME WITH HINGES FIXED TO 230mm WALL	ALUMINIUM FRAME WITH HINGES FIXED TO 230mm WALL	1,6mm PRESSED METAL FRAME FOR 115mm WALL. ALL FRAMES TO BE DOUBLE REBATE TYPE.	STD MS TRANSFORMER ROOM FRAME FOR 230 mm WALL	SUPPORT BRACKETS AND GUIDES FIXED TO IPE SUPPORT & FRAME	STD MS TRANSFORMER ROOM FRAME FOR 230 mm WALL
DOOR	ALUMINIUM DOUBLE DOORS WITH 6mm SAFETY GLASS AND WEATHER BAR	ALUMINIUM SINGLE DOOR WITH 6mm SAFETY GLASS AND WEATHER BAR	STANDARD SEMI-SOLID DOOR IN SAPELE WITH TWO CONCEALED EDGES.	STD MS TRANSFORMER ROOM DOOR WITH LOUVERS OVER 1/3 OF LENGTH OF DOOR	CHAIN OPERATED ROLLER SHUTTER DOOR WITH SLATS AND HOOD	2438 x 1524mm STANDARD TRANSFORMER STEEL DOOR WITH A LOUVRE INSERT AT LOWER HALF OF THE DOOR PANELS.
FITTING	UNION L2244E EUROPROFILE DEADLOCK UNION PH33 DOOR HANDLES UNION N8825 DOOR CLOSER	UNION L2244E EUROPROFILE DEADLOCK UNION PHOS DOOR HANDLE UNION N8825 DOOR CLOSER	UNION C2 662-24-9756 C2 LEVER LOCKSET, OR SIMILAR AND APPROVED. HINGES AS SUPPLIED WITH FRAME.	HEAVY DUTY	STANDARD	HEAVY DUTY
FINISH	FRAME AND DOOR: EPOXY POWDER COAT ROYAL BLUE	FRAME AND DOOR: EPOXY POWDER COAT ROYAL BLUE	FRAME: PRIME COAT, ONE UNDERCOAT AND TWO COATS ENAMEL. DOOR: PREPARE AND STOP, APPLY THREE COATS WOOD SUBE OR SIMILAR APPROVED.	FRAME AND DOOR: PRIME COAT, ONE UNDERCOAT AND TWO COATS POLYURETHANE ENAMEL. COLOUR DECIDED BY ENGINEER ON SITE	HOT DIP GALVANISED	ONE UNDER COAT AND TWO COATS POLYURETHANE ENAMEL

`				
	1			
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-	DE/	/ISIONS		
-	KEV	ISIONS		
-	No.	DATE	BY	DESCRIPTION
-				
-				
-				
-				
-				
-		•		
-	NO.	TES		
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-				
-	REE	ERENCE	DRAW/I	NGS
-			1	
-	PLA	AN Nr.	-	DESCRIPTION
-				
-				
-				
- [				
	APPROV	/ED:		
				DATE:
	ENGINE	ER:		DATE:
	APPROV	ER:		
	ENGINE	ER:		DATE:DATE:
	APPROV	ER:		
	APPROV	ER:	1	_ DATE:
	APPROV	ER:	1	_ DATE:
	APPROV	ER:	ela '	Tsweu.
	APPROV	ER:	ela '	Tsweu.
	APPROV CLIENT:	FED:	ela	TSWEU.
	APPROV CLIENT:	FED:	ela	TSWEU.
	APPROV CLIENT:	FED:	ela	Tsweu.
	APPROV CLIENT:	FED:	CONSULTATION OF THE PROPERTY O	TSWEU.
	APPROV CLIENT: PRINT Mobile: 329 Stat	ISSUED ON	ela	TSWEU.
	APPROV CLIENT:	ISSUED ON	CONSULTATION OF THE PROPERTY O	TSWEU  ING ENGINEERS  way, Welkom, outh Africa
	APPROV CLIENT: PRINT Mobile: 329 Stat	TSUED ON  15( +27(0)832 +27(0)832 2600, Welker	CONSULT 265 1524 sbers, States m, 9460, Si	TSWEU TING ENGINEERS way, Welkom, outh Africa
	APPROV CLIENT: PRINT Mobile: 329 Stat	TSUED ON  15( +27(0)832 +27(0)832 2600, Welker	CONSULT 265 1524 sbers, States m, 9460, Si	TSWEU  ING ENGINEERS  way, Welkom, outh Africa
	APPROV CLIENT: PRINT Mobile: 329 Stat	TSUED ON  15( +27(0)832 +27(0)832 2600, Welker	CONSULT 265 1524 sbers, States m, 9460, Si	TSWEU TING ENGINEERS way, Welkom, outh Africa
	APPROV CLIENT: PRINT Mobile: 329 Stat	ISUED ON  15SUED ON  +27 (0)83 2 teway Cham 22600, Welke	CONSULT 265 1524 sbers, States m, 9460, Si	TSWEU TING ENGINEERS way, Welkom, outh Africa
	APPROV CLIENT: PRINTI Mobile: 329 State	ISUED ON  15SUED ON  +27 (0)83 2 teway Cham 22600, Welke	CONSULT 265 1524 sbers, States m, 9460, Si	TSWEU TING ENGINEERS way, Welkom, outh Africa
	APPROV CLIENT: PRINTI Mobile: 329 State	ISUED ON  15SUED ON  +27 (0)83 2 teway Cham 22600, Welke	CONSULT 265 1524 sbers, States m, 9460, Si	TSWEU TING ENGINEERS way, Welkom, outh Africa

LITY

UPGRADING OF HARTSWATER WATER TREATMENT PLANT


PHOKWANE LM


DOOR & WINDOW SCHEDULE


DESIGN	DATE	DRAWN	DATE
Ē	JUN 2025	=	JUN 2025
SURVEYED	DATE	CHECKED	DATE
-	-	J.BATEMAN	JUN 2025


SCALE AS SHOWN

2024-06-B/A/001










DRAINAGE CHAMBER SCALE 1:25



## - SEAL OPENING BETWEEN MANHOLE COVER AND FRAME WITH BITUMEN OR SIMILAR APPROVED AFTER FINAL INSPECTION AND SYSTEM HAS BEEN FLUSHED. PRECAST CONCRETE COVER SLAB WITH ACCESS OPENING. USE PRECAST SPACER OR ADAPTOR SLABS FOR FINAL COVER HEIGHT ADJUSTMENT.

PRE-CAST CONCRETE SHAFT SECTIONS WITH 250 mm STARTER RING CAST INTO CONCRETE - 700 mmØ STARTER SHAFT SECTION, 250mm WIDE PLACED INTO WET CONCRETE FLOOR. 150 mm THICK CLASS 20/19 CONCRETE SURROUND. - IL VARIES BETWEEN 20,35-20,25.

SUB-SOIL DRAINAGE


INSPECTION CHAMBER

SCALE 1:25

FALL FALL

#### TYPICAL STAIR DETAIL SCALE 1:10

MENTIS RACTAGRID TYPE RS40 WITH 40 x 4,5 BEARER.



TYPICAL ACCESS COVER SCALE 1:10



TYPICAL LOCKABLE MANHOLE COVER LID

STRUCTURAL STEEL NOTES

- LOTION MEMBERS ARE DESIGNED TO THE REQUIREMENTS OF SANS 10400 (LATEST EDITION), AND ALL REFERENCED DESIGN CODES. THO FIRE DESIGN CODES STEELWORK TO BE IN ACCORDANCE WITH EN 100252 SSSSJA, MILL TEST CERTIFICATES TO BE PROVIDED. COLD FORMED STEELWORK TO ANAW MINIMAY WIELD STRESS OF COLD FORMED STEELWORK TO FANAW MINIMAY WIELD STRESS OF

- 250MPa
  BOLTS, NUTS & WASHERS TO BE CLASS 4.6 U.O.S.
  WELDS TO BE CONTINUOUS FILLET WELDS (U.O.S.) WITH A THROAT
  THICKNESS NOT EXCEEDING 7.7 TIMES THE
  THINNER MATERIAL THICKNESS WELDED TO.

#### FABRICATION & ERECTION:

ABRICATION & ERECTION:
STEEL FABRICATION AND SERECTION TO COMPLY WITH SANS
1200H AND MAY NOT COMMENCE BEFORE SHOP DRAWINGS
AND AN BECTION METHOS DATAMENT HAVE BEEN APPROVED
BY THE ENGINEER.
CONNECTION DETAILS TO BE APPROVED BY ENGINEER BEFORE
THE SHOP DRAWINGS ARE SUBMITTED FOR APPROVAL
(a) MINIMUM BOCE DISTANCE TO BOLTS TO BE 1.75 TIMES THE
MINIMUM BOLT SPACING TO BE 2.5 TIMES THE BOLT
DIAMPTER ILOS.

- (b) MIMIMUM BOLT SPACING TO BE 2.5 TIMES THE BOLT DIAMETER U.O.S.
  ALL BOLT HOLES TO BE DRILLED, NOT PUNCHED.
  CONTRACTOR TO ENSURE THE STABILITY AND SAFE ERECTION OF THE STRUCTURE, AND TO PROVIDE ALL NECESSARY BRACING TO ENABLE HIM TO DO SO, SUCH BRACING TO BE INDICATED ON THE ERECTION GENERAL ARRANGEMENT DRAWINGS.
  NO SITE CUTTING OR WELDING WILL BE ALLOWED UNLESS PRIOR ARRANGEMENT WITH THE ENGINEER.
  ALL STEEL WORK DE LIVERED TO THE SITE SHALL BE STACKED ON TIMBER SUPPORTS AT LEAST 300mm FROM GROUND LEVEL.

- GENERAL:

  1. THESE DRAWINGS TO BE READ IN CONJUNCTION WITH THE GENERAL LAYOUT DRAWINGS AND ANY DISCREPANCIES TO BE RESOLVED BEFORE CONSTRUCTION COMMENCES.

  2. SHOP DRAWINGS AND AN ERECTION METHOD STATEMENT TO BE SUBMITTED TO THE ENGINEER FOR APPROVAL PRIOR TO FABRICATION OF ANY STEELWORK.

  3. THE ENGINEER WILL NOT BE HOSE DRESPONSIBLE FOR ANY WORK THAT DEVIATES FROM THE ENGINEERS- OR ANY WORK THAT DEVIATES FROM THE ENGINEERS- OR ANY OWN THAT DEVIATES FROM THE ENGINEERS- OR ANY OWN THAT DEVIATES FROM THE ENGINEERS- OR ANY STRUCTURAL STEELWORK IS MANUFACTURED. ALL INTERPACING CONCRETE WORK IS TO BE SURVEYED TO CONFIRM DIMENSIONS, LEVELS, BOLT POSITIONS ETC. RECTIFICATION OF ANY TACK OF FITT DUE TO NON-COMPULANCE WITH THE ABOVE, WILL BE AT THE COST OF THE CONTRACTOR.

  3. WHERE ANY MEMBER SIZES OR DETAILS ON THE WORKSHOP DRAWINGS, DEVAITE SUBSTANTIALLY FROM THE DESIGN DRAWINGS, THE CONTRACTOR SHALL INFORM THE ENGINEER EXPLICITLY IN WEITING IN ORDER TO OBTAIN APPROVAL FOR SUBCHIEVED TO ANY EXTRACT OR SHALL INFORM THE ENGINEER EXPLICITLY IN WEITING IN ORDER TO OBS WILL RESULT IN NON-PAYMENT OF ANY EXTRACT HOS HOW.

  THE DESIGN DRAWNS ON ON FAIL THE ORDER THE TIME TO DO SO WILL THE DESIGN ON THE WORKSHOP DRAWINGS AND SIFEFILIENT OF THE FIRST.
- THE DESIGN DRAWINGS DO NOT NORMALLY SHOW CONNECTION DETAILS. ALL CONNECTIONS ARE TO BE FULLY DETAILED ON THE WORKSHOP DRAWINGS AND SUFFICIENT TIME SHOULD BE ALLOWED FOR THE ENGINEER TO APPROVE SUCH CONNECTION DETAILS. ON RECEIVING THE DESIGN DRAWINGS, THE CONTRACTOR MUST ARRANGE A MEETING-WORKSHOP WITH THE ENGINEER TO DISCUSS THE DESIGN, ERECTION METHOD AND CONNECTION DETAILS, AS WELL AS A QUALITY CONTROL METHOD.

#### FINISHES TO STEELWORK:

SURFACE PREPARATION:
(a) EXPOSED STEELWORK:
BLAST CLEAN STEELWORK TO Sa 2.5 OR SIS 05-59-00 OR
ALTERNATIVE TO BE APPROVED BY ENGINEER.

- WINE BRUSHING AS PER SANS 1200
  PRIMER:
  APPLY ONE COAT (30 MICRON) ZINC CROMATE PRIMER IN
  ACCORDANCE WITH SANS 681.
  INTERMEDIATE COAT:
- ACCOMUNANCE WHI IT SANS 561.

  INTERMEDIATE COAT:
  APPLY BY BRIUSH AND ACCORDANCE WITH SANS 561. USE
  APPLY BY BRIUSH AND ACT IN ACCORDANCE WITH SANS 561. USE
  TYPE LIF PAINT IS APPLIED WITHIN 16 HOURS OF APPLICATION
  OF ZINC PHOSPHATE PRIMER, OTHERWISE USE TYPE I COLOUR
  TO DIFFER FROM COLOUR OF FINAL COAT.
  TOP COATS: (ONLY FOR EXPOSED STEELWORK)
  AS SPECIFIED BY ARCHITECT.
  ALLOW 24 HOURS BETWEEN COATS FOR DRYING,
  DAMAGES TO COATINGS DURING TRANSIT, SITE WELDING
  ANDOR ERECTION MUST BE WIRE BRUSHED TO BARE METAL
  AND FOLLOWED BY THE APPLICABLE SPECIFICATION,
  APPROVED ALTERNATIVE PRODUCTS MAY BE USED.

#### STEEL GRADES:

- ACCESS LADDER INSIDE RESERVOIR TO BE STAINLESS STEEL
  GRADE SIGL
  ALL OTHER STEELWORK TO BE HOT DIPPED GALVANISED MILD
  STEEL TO SAMS 0121.

REVISIONS DATE DESCRIPTION NOTES

REFERENCE DRAWINGS				
PLAN Nr.	DESCRIPTION			

APPROVED:	
ENGINEER:	DATE:
APPROVED:	
CLIENT:	DATE:

Tsela Tsweu

Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600, Welkom, 9460, South Africa



PRINT ISSUED ON

PHOKWANE LOCAL MUNICIPALITY

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM


#### **TYPICAL STRUCTURE DETAILS**

DESIGN	DATE	DRAWN	DATE	ı
-	JUN 2025	-	JUN 2025	l
SURVEYED	DATE	CHECKED	DATE	ı
-	-	J.BATEMAN	JUN 2025	l


SCALE


### 2024-06-B/D/001






## TYPICAL PAVEMENT DESIGN DETAIL FOR 5.0m SURFACED ACCESS STREETS (PAVING BLOCK FINISH)





TYPICAL SECTION THROUGH FIG.8b MOUNTABLE KERB



TYPICAL PAVING DETAIL

- PRIOR TO THE UNDERTAKING OF ANY VIBRATORY OR PAD FOOT ROLLING WITHIN THE ROAD FOUNDATION, AN ON SITE TRIAL SECTION SHALL BE PREPARED AND CONDUCTED IN ORDER TO ASCERTAIN THE AVERAGE NUMBER OF mª PASSES REQUIRED IN ORDER TO OBTAIN THE SPECIFIED COMPACTION EFFORT FOR THE ROADBED PREPARATION.
- THE ENGINEER SHALL THEN INSTRUCT THE CONTRACTOR TO REMOVE AND SPOIL THE TOPSOIL AND HILLWASH OVERBURN TO WEARING COURSE DEPTH OR FERRICRETE LEVEL, WHERE REQUIRED WHICHEVER IS THE SHALLOWEST.
- ALL FERRICRETE MATERIAL SHALL BE CUT TO TEMPORARY STOCKPILE AS DETERMINED BY THE ENGINEER FOR LATER USE IN THE PAVEMENT STRUCTURE AND WEARING COURSE LAYER WORKS
- THE CONTRACTOR SHALL THEN APPLY THE NUMBER OF m² PASSES ORDERED BY THE ENGINEER, PERIODICALLY WATERING AND BLADING THE ROADBED FOUNDATION AREA TO ENSURE MAXIMUM WORKABILITY AND COMPACTION EFFICIENCY.
- AFTER APPLYING THE VIBRATORY OR PAD FOOT ROLLING, CUT TO FILL OR BLADE TO WINDROW THE FERRICRETE PINNACLES, RIP, SCARIFY AND RECOMPACT ROADBED TO ABOVE SPECIFICATION WHERE REQUIRED.

#### LEGEND:

- a) REQUIREMENTS ARE GIVEN IN THE FOLLOWING ORDER: LAYER THICKNESS/MATERIAL/CBR AND
  MIN COMPACTION/MIN. GM/MAX. PI
  b) MIN. UNCONFINED COMPRESSIVE STRENGTH (UCS) IS
- SHOWN IN MPa.
  c) MIN. DENSITY IS GIVEN AS % OF MAX MODIFIED

- COMIN. DENSITY IS GIVEN AS % OF MAX MODIFIED AASHTO DENSITY.

  MIN. SG = STABILIZED GRAVEL

  NG = NATURAL GRAVEL

  IS = IN SITU SOIL

  PI = PLASTICITY INDEX

  GM = GRADING MODULES

  SBP = SHOULDER BREAK POINT

  ### FIGURE & MOUNTABLE CONCRETE KERB (CLASS)

  25/31 EYTRIDER ON BASE

  25/31 EYTRIDER ON B 25/13) EXTRUDED ON BASE
- 8 250mm WIDE x 100mm THICK EDGE CHANNEL CAST IN ALTERNATIVE SECTIONS, THE EXPOSED END SHALL BE COATED WITH BITUMINOUS EMULSION BEFORE THE INTERMEDIATE SECTION IS CAST, 6mm JOINT WITH APPROVED JOINT FORMING MATERIAL AT 6m INTERVALS MAXIMUM.

1	SEGMENTED PAVING SHAPE S-A (G-BLOCKS), CLASS 25, 80mm THICK
2	RIVER SAND 20 / RIVER SAND IMPORTED FROM COMMERCIAL SOURCE
3	BASE $125 \mathrm{mm}$ C4 MATERIAL COMPACTED TO 98% MOD AASHTO DENSITY.
4	SUBBASE 150mm G6 MATERIAL COMPACTED TO 95% MOD AASHTO DENSITY

ROADBED PREPARATION (REFER TO NOTES)
VIBRATORY OR PAD FOOT ROLLING (NUMBER OF PASSES TO BE DETERMINED BY ENGINEER ON SITE) OR RIP SCARIFY AND RE-COMPACT 150/IS/@90%

FILL - ONLY WHERE REQUIRED

FILL TO BE A MINIMUM OF G9 MATERIAL TO BE COMPACTED IN LAYERS NOT EXCEEDING 150mm THICKNESS TO 90% MOD AASHTO DENSITY.

1000mm WIDE SHOULDER WEARING COURSE 7 1000mm WIDE SHOULDER WEARING COURSE CUT TO FILL FROM ROAD FOR ACCOMMODATION OF TRAFFIC WHERE REQUIRED

REVISIONS					
No.	DATE	BY	DESCRIPTION		

NOTES

REFERENCE DRAWINGS		
PLAN Nr.	DESCRIPTION	

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

PHOKWANE LM


TYPICAL ROAD AND PAVING **DETAILS** 


DATE JUN 2025 JUN 2025

AS SHOWN


SCALE

2024-06-R/D/001





l w	WELDED WIRE MESH FENCING		
NO#	DESCRIPTION		
1	WELDED WIRE MESH PANEL		
2	POST STEEL TAPER LOCKING		
3	CLAMP COME SINGLE		
4	CLAMP COME DOUBLE		
5	CAP POST		
6	SCREW TORX		
7	UNDERDIG 0.5m (OPTIONAL)		
8	SPIKE CASTLE STEEL		



#### NOTES:

- STEEL MESH PANELS:
  PANEL SIZES AS SHOWN.
  MESH APERTURE SIZE SHALL BE 76.2mm x 12.7mm AT WIRE CENTRES.
  WIRE DIAMETER TO BE 4mm.
  ALL FIXTURES SHALL BE ON THE INSIDE OF THE FENCE.
  PANELS AND FIXTURES SHALL BE HOT DIP GALVANIZED WITH UV RESISTANT POLYESTER POWDER COATING ON EXTERIOR.

- POSTS:

  POST PROFILE WILL BE TUBING WITH WALL THICKNESS NOT LESS THAN 2mm.

  POSTS SHALL INCLUDE "LOCKING RECESS MECHANISM" TO SECURE PANEL EDGE.

  POSTS SHALL BE SEALED WITH A UV STABILIZED POLYMER CAP.

  POST FOUNDATIONS TO BE 400mm x 400mm x 600mm DEEP CONCRETE CLASS 15MPa/19

  ALL POSTS TO BE HOT DIP GALVANIZED WITH UV RESISTANT POLYESTER POWDER COATING ON EXTERIOR.

REVISIONS

No. DATE BY DESCRIPTION

#### NOTES



OPTIONAL CONCRETE STRIP BELOW FENCE PANELS.



OPTIONAL MESH PANEL BELOW FENCE PANELS.

#### NOTE:

OPTIONAL ITEMS TO BE INSTALLED ONLY ON INSTRUCTION FROM THE CLIENT.

REFERENCE DRAWINGS		
PLAN Nr.	DESCRIPTION	

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM


#### STEEL MESH PANEL FENCE **DETAILS**

DESIGN	DATE	DRAWN	DATE
-	JUN 2025	€	JUN 2025
SURVEYED	DATE	CHECKED	DATE
-	-	J.BATEMAN	JUN 2025

SCALE as shown

## 2024-06-F/D/001





REV	isions		
No.	DATE	BY	DESCRIPTION

HOT DIPPED GALVANISED TO SABS 763, GENERAL APPLICATION COATING THICKNESS TO ALL POSTS AND STRUTS.



PHOKWANE LOCAL MUNICIPALITY


**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

(WELDED RAZOR MESH, **DIAMOND MESH AND** FLAT WRAP)

-	JUN 2025		JUN 2025
SURVEYED -	DATE	CHECKED J.BATEMAN	DATE JUN 2025
			$\overline{}$

2024-06-F/D/003





TYPICAL ACCESS LADDER DETAIL

SCALE 1:20



TYPICAL LOCKABLE MANHOLE COVER LID

TYPE 2A HEAVY DUTY

TOP UNIT COMPONENTS:


1. TOP PLATE - 300mm x 300mm x:
BENT 90° DOWNWARD FOR 25m

- SQUARE TUBES PLACED 25mm FROM, ONE ON EACH CORNER AND ONE IN THE CENTER OF EACH EDGE OF TOP AND BOTTOM PLATES. WELDED ONTO TOP PLATE AND BOTTOM PLATE.
- THREADED ROD 1 x 300mm LONG x 10mmØ, WELDED AT THE CENTER ONTO BOTTOM OF TOP PLATE.
- 3mm THICK ROUND HOLE PERFORATED METAL SHEET, FIXED TO INSIDE OF SQUARE TUBES.

#### EIXING BRACKET COMPONENTS:


IG BRACKET COMPONIENTS:
Somm WIBE & Sim THICK x 400 mm LONG PLATE, BOLTED
TO BOTTOM OF ROOF SLAB WITH 10mm@ x 100mm LONG
RAWL BOLTS, ONE EACH SIDE. PLATE TO HAVE 12mm@
HOLE IN THE CENTER TO ACCOMMODATE FIXING OF TOP
UNIT WITH 10mm@ THREADED ROD.

GENERAL:
A. ALL STEELWORK TO BE HOT DIP GALVANIZED.
B. PERFORATED PLATE TO BE ALUMINIUM.




AIR BREATHER DETAIL - SECTION


SCALE 1:5




POLYMER CONCRETE MANHOLE LID WITH ALTERNATIVE LOCKABLE MANHOLE COVER LID




### CONCRETE COVER SLAB LIFTING HOOK **PLAN VIEW**




TYPICAL SECTION



TYPICAL FLOOR PLAN SCALE 1:25



SECTION B-B PIPE PEDESTAL SCALE 1:10



REVISIONS DATE DESCRIPTION NOTES

REFERENCE DRAWINGS

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM

**TYPICAL CHAMBER DETAILS** 

DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		J.BATEMAN	JUN 2025

SCALE AS SHOWN

2024-06-W/A/001



## TYPICAL AIR VALVE INSTALLATION DETAIL

SCALE 1:10

	BULK PIPELINES					
	50ND, 80ND & 100ND AIR VALVE CHAMBER PII	PE ITEM LIST				
PIPE NUMBER	DESCRIPTION	MATERIAL	QUANTITY			
A1-1	D1 uPVC - STEEL FLANGE ADAPTOR.	STANDARD	2			
A1-2	D1 x 800mm LONG FLANGED STRAIGHT PIPE WITH PUDDLE FLANGE.	SANS 719/SANS 62	2			
A1-3	D1 x D2 TEE PIECE.	SANS 719/SCHEDULE 40	1			
A1-4	D2 x D3 REDUCER (ONLY IF REQUIRED)	SCHEDULE 40	1			
A1-5	D2 PN16 RESILIENT SEATED GATE VALVE TO SANS 664.	<b>DUCTILE IRON - EPOXY PAINTED</b>	1			
A1-6	D2 VENT-O-MAT 100 RBX 1601, OR SIMILAR APPROVED AIR VALVE.	<b>DUCTILE IRON - EPOXY PAINTED</b>	1			
	NOTES					
D1	D1 MAINLINE DIAMETER					
D2	D2 0.5 x D1 (HALF OF THE MAINLINE DIAMETER)					
D3	D3 AIR VALVE DIAMETER AS SPECIFIED ON LONGSECTION (50ND, 80ND & 100ND)					

1	1				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	Н				
	П	REV	ISIONS		
	П	No.	DATE	BY	DESCRIPTION
	П				
	П				
	П				
	П				
	П	NOT	ES		
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	П				
	Н	REE	RENCE	DRAWI	NGS
	П		N Nr.	1	DESCRIPTION
	П				
	Н				
	П				
	П			-	
	П			1	
	H				
	П	APPROV			
	П	ENGINEE			DATE:
	П	APPROV	ED:		
	П	CLIENT:_			DATE:
	П	PRINT	ISSUED ON		
	Н				
	П	A			
	П	Ā			
	П		To	احله	Tourou
	П	24	151	ela	Isweu
	П	#		CONSUL	ING ENGINEERS
	П	AAK A			
	П	Mobile:	27 (0)83 2 eway Chan	165 1524 ibers, State	way, Welkom, outh Africa
	إإ	- D BOX		, v+ou, S	Julia Allika
	П	5 ×	2	CLIENT	
	П		DV		PHOKWANE
	П		<b>*</b>	LO	CAL MUNICIPAL
	П		20		
	П	PROJE	ст		
	П				
	П				
	П	UF	GRA	DING	OF HARTSWAT
	П				EATMENT PLAI

LITY

TER NT


PHOKWANE LM


TYPICAL AIR VALVE INSTALLATION DETAILS

DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		J.BATEMAN	JUN 2025

SCALE 1:10

2024-06-W/D/001





250mm DIAMETER FLANGED STRAIGHT PIPE WITH PUDDLE

**SANS 719** 

FOR TYPICAL CHAMBER DETAILS REFER TO DRAWING REVISIONS DESCRIPTION MECHANICAL NOTES: ALL FLANGES TO BE DRILLED SABS 1123-1977 (1600/3) ALL YALVES. STRAINERS AND WATER METERS TO BE APPROVED BY ENGINEER IN WRITING.

THE LENGTH OF PIPES AND FITTINGS ARE APPROXIMATE ONLY - ACTUAL LENGTH TO BE DETERMINED BY CONTRACTO ONLY ACTUAL LENGTH TO BE DETERMINED BY CONTRACTO ONLY AFTER APPROVAL OF VALVES BY ENGINEER. NO ALLOWANCE HAS BEEN MADE IN PIPE AND FITTING DIMENSIONS FOR PACKINGS, GASKETS AND GAPS BETWEEN PIPEWORK - PROVISION FOR THESE TO BE MADE BY SUPPLIE FLANGE HOLES TO BE DRILLED TO ALLOW EXACT ALIGNMEN HORIZONTALLY AND VERTICALLY, AS DETAILED ON THE DRAWINGS, OF ALL PIPEWORK AND EQUIPMENT. ALL WELDING TO BE FULL STRENGTH, FULL PENETRATION. ALL PIPES, ELBOWS, TEE PIECES AND REDUCERS TO BE HOT-DIPPED GALVANISED. ALL PIPEWORK PASSING THROUGH BRICKWORK TO BE MALTHOID WRAPPED (4 LAYERS MIN.) AND SEALED AROUND PIPE WITH POLYSULPHIDE SEALANT ON BOTH FACES OF ALL BOLTS, NUTS AND GASKETS NECESSARY FOR THE PROPINSTALLATION OF THE EQUIPMENT, TO BE SUPPLIED AS PART OF THE MECHANICAL EQUIPMENT. A PEDESTAL IN CONCRETE CLASS 25MPa/19 TO BE CAST EITHER SIDE OF THE WATER METER. REFER TO PEDESTAL DETAIL ON DRAWING W/A/001. REFERENCE DRAWINGS PRINT ISSUED OF



PHOKWANE **LOCAL MUNICIPALITY** 

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM

**WATER METER INSTALLATION LAYOUT & DETAILS FOR 200ND & 250ND WATER METER INSTALLATION ON** 250mmØ TO 350mmØ WATER MAIN

DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		J.BATEMAN	JUN 2025


SCALE 1:25

2024-06-W/D/002




TYPE 1 SCOUR VALVE CHAMBER TYPICAL ONE WAY SCOUR VALVE CHAMBER LAYOUT

	BULK PIPELINES					
	TYPE 1 SCOUR VALVE CHAMBER PIPE ITEM LIST					
PIPE NUMBER	DESCRIPTION	MATERIAL	QUANTITY			
S1-1	D1 uPVC - STEEL FLANGE ADAPTOR.	STANDARD	2			
S1-2	D1 x 800mm LONG FLANGED STRAIGHT PIPE WITH PUDDLE FLANGE.	SANS 719/SANS 62	2			
S1-3	D1 PN16 NON-RETURN VALVE.	DUCTILE IRON - EPOXY PAINTED	1			
S1-4	D1 x D2 UNEQUAL TEE PIECE.	SANS 719/SCHEDULE 40	1			
S1-5	D2 PN16 RESILIENT SEATED GATE VALVE TO SANS 664.	<b>DUCTILE IRON - EPOXY PAINTED</b>	1			
S1-6	D2 x 850mm LONG STRAIGHT PIPE, WITH PUDDLE FLANGE. ONE END	SANS 719/SANS 62	1			
31-0	FLANGED, OTHER END PLAIN ENDED.	SANS / 19/SANS 62				
	NOTES					
D1	MAINLINE DIAMETER					
D2	0.5 x D1 (HALF OF THE MAINLINE DIAMETER)					



TYPE 2 SCOUR VALVE INSTALLATION TYPICAL TWO WAY SCOUR VALVE CHAMBER LAYOUT

SCALE 1:25					
	BULK PIPELINES				
	TYPE 2 SCOUR VALVE CHAMBER PIPE ITE	M LIST			
PIPE NUMBER	PIPE NUMBER DESCRIPTION MATERIAL QUANT				
S2-1	D1 uPVC - STEEL FLANGE ADAPTOR.	STANDARD	2		
S2-2 D1 x 800mm LONG FLANGED STRAIGHT PIPE WITH PUDDLE FLANGE. SANS 719/SANS 62		2			
S2-3	D1 PN16 RESILIENT SEATED GATE VALVE TO SANS 664.	<b>DUCTILE IRON - EPOXY PAINTED</b>	2		
S2-4 D1 x D2 UNEQUAL TEE PIECE. SANS 719/SCHEDULE 40		1			
S2-5	D2 PN16 RESILIENT SEATED GATE VALVE TO SANS 664.	<b>DUCTILE IRON - EPOXY PAINTED</b>	1		
S2-6 D2 x 1100mm LONG STRAIGHT PIPE, WITH PUDDLE FLANGE. ONE END SANS 719/SANS 62 FLANGED, OTHER END PLAIN ENDED.		1			
NOTES					
D1	MAINLINE DIAMETER				
D2	0.5 x D1 (HALF OF THE MAINLINE DIAMETER)				



SCOUR OVERFLOW GRID DETAIL

REVISIONS No. DATE BY

#### MECHANICAL NOTES:

- ALL FLANGES TO BE DRILLED SABS 1123-1977 (1600/3)
- ALL TALVES, STRAINERS AND WATER METERS TO BE APPROVED BY ENGINEER IN WRITING.

  THE LENGTH OF PIPES AND FITTINGS ARE APPROXIMATE ONLY ACTUAL LENGTH TO BE DETERMINED BY CONTRACTOR ONLY ACTUAL LENGTH TO BE DETERMINED BY CONTRACTOR ONLY AFTER APPROVAL OF VALVES BY ENGINEER.
- NO ALLOWANCE HAS BEEN MADE IN PIPE AND FITTING DIMENSIONS FOR PACKINGS, GASKETS AND GAPS BETWEEN PIPEWORK PROVISION FOR THESE TO BE MADE BY SUPPLIE FLANGE HOLES TO BE DRILLED TO ALLOW EXACT ALIGNMENT
- HORIZONTALLY AND VERTICALLY, AS DETAILED ON THE DRAWINGS, OF ALL PIPEWORK AND EQUIPMENT. ALL WELDING TO BE FULL STRENGTH, FULL PENETRATION.
- ALL PIPES, ELBOWS, TEE PIECES AND REDUCERS TO BE HOT-DIPPED GALVANISED.
- ALL PIPEWORK PASSING THROUGH BRICKWORK TO BE MALTHOID WRAPPED (4 LAYERS MIN.) AND SEALED AROUND PIPE WITH POLYSULPHIDE SEALANT ON BOTH FACES OF
- ALL BOLTS, NUTS AND GASKETS NECESSARY FOR THE PROPE INSTALLATION OF THE EQUIPMENT, TO BE SUPPLIED AS PART OF THE MECHANICAL EQUIPMENT.
- ALL VALVES TO HAVE A PEDESTAL IN CONCRETE CLASS 25MPa/19.

REFERENCE DRAWINGS	
PLAN Nr.	DESCRIPTION

ı		
I	APPROVED:	
ı	ENGINEER:	DATE:
ı	APPROVED:	

PRINT ISSUED ON





PHOKWANE LOCAL MUNICIPALITY

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM

#### TYPE 1 & TYPE 2 **SCOUR VALVE INSTALLATION** LAYOUT AND DETAILS


DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		J.BATEMAN	JUN 2025

SCALE 1:25

2024-06-W/D/003




#### TYPE 3 SCOUR VALVE CHAMBER TYPICAL ONE WAY SCOUR VALVE CHAMBER LAYOUT SCALE 1:25




SCOUR OVERFLOW GRID DETAIL

BULK PIPELINES				
	TYPE 3 SCOUR VALVE CHAMBER PIPE ITI	EM LIST		
PIPE NUMBER DESCRIPTION MATERIAL QUAI				
S3-1	D1 uPVC - STEEL FLANGE ADAPTOR.	STANDARD	2	
S3-2 D1 x 800mm LONG FLANGED STRAIGHT PIPE WITH PUDDLE FLANGE. SANS 719/SANS 62		2		
S3-3	D1 PN16 NON-RETURN VALVE.	<b>DUCTILE IRON - EPOXY PAINTED</b>	1	
S3-4	D1 x D2 UNEQUAL TEE PIECE.	SANS 719/SCHEDULE 40	1	
S3-5	D2 PN16 RESILIENT SEATED GATE VALVE TO SANS 664. DUCTILE IRON - EPOXY PAINTED 1			
S3-6	D2 x 850mm LONG STRAIGHT PIPE, WITH PUDDLE FLANGE. ONE END	SANS 719/SANS 62	1	
55.51	FLANGED, OTHER END PLAIN ENDED.		-	
	NOTES			
D1	MAINLINE DIAMETER			
D2	0.5 x D1 (HALF OF THE MAINLINE DIAMETER)			

	BULK PIPELINES		
	TYPE 4 SCOUR VALVE CHAMBER PIPE ITE	M LIST	
PIPE NUMBER	DESCRIPTION	MATERIAL	QUANTITY
S4-1	D3 x D4 SG IRON REDUCING TEE PIECE.	CAST IRON	1
S4-2	D4 uPVC CLASS 09 PIPE. EXACT LENGTH TO BE DETERMINED ON SITE.	uPVC	2
S4-3	D4 uPVC - STEEL FLANGE ADAPTOR.	STANDARD	3
\$4-4	D4 PN16 CAP TOP OPERATED RESILIENT SEATED GATE VALVE TO SANS 664.	DUCTILE IRON - EPOXY PAINTED	1
S4-5	D4 uPVC CLASS 09 45 DEGREE BEND.	uPVC	1
S4-6	D4 FLANGED STRAIGHT PIPE, WITH BLANK FALNGE ON OPEN END. EXACT LENGTH TO SUIT MANHOLE DEPTH.	SANS 719	1





TYPE 4 SCOUR VALVE CHAMBER

TYPICAL SECTION

FOR TYPICAL CHAMBER DETAILS REFER TO DRAWING 2024-06/W/A/001.

REVISIONS

#### MECHANICAL NOTES:

- ALL FLANGES TO BE DRILLED SABS 1123-1977 (1600/3)
- ALL YALVES STRAINERS AND WATER METERS TO BE APPROVED BY ENGINEER IN WRITING.

  THE LENGTH OF PIPES AND FITTINGS ARE APPROXIMATE ONLY ACTUAL LENGTH TO BE DETERMINED BY CONTRACTO ONLY ACTUAL LENGTH TO BE OFTERMINED BY CONTRACTO ONLY AFTER APPROVAL OF VALVES BY ENGINEER.
- NO ALLOWANCE HAS BEEN MADE IN PIPE AND FITTING DIMENSIONS FOR PACKINGS, GASKETS AND GAPS BETWEEN PIPEWORK PROVISION FOR THESE TO BE MADE BY SUPPLIE
- FLANGE HOLES TO BE DRILLED TO ALLOW EXACT ALIGNMEN HORIZONTALLY AND VERTICALLY, AS DETAILED ON THE DRAWINGS, OF ALL PIPEWORK AND EQUIPMENT.
- ALL WELDING TO BE FULL STRENGTH, FULL PENETRATION. ALL PIPES, ELBOWS, TEE PIECES AND REDUCERS TO BE HOT-DIPPED GALVANISED.
- ALL PIPEWORK PASSING THROUGH BRICKWORK TO BE MALTHOID WRAPPED (4 LAYERS MIN.) AND SEALED AROUND PIPE WITH POLYSULPHIDE SEALANT ON BOTH FACES OF
- ALL BOLTS, NUTS AND GASKETS NECESSARY FOR THE PROPE INSTALLATION OF THE EQUIPMENT, TO BE SUPPLIED AS PART OF THE MECHANICAL EQUIPMENT.
- ALL VALVES TO HAVE A PEDESTAL IN CONCRETE CLASS 25MPa/19.

REFERENCE DRAWINGS		
PLAN Nr.	DESCRIPTION	

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

PHOKWANE LM

TYPE 3 & TYPE 4 **SCOUR VALVE INSTALLATION LAYOUT AND DETAILS** 


DESIGN	DATE JUN 2025	DRAWN	DATE JUN 2025
SURVEYED	DATE	CHECKED J.BATEMAN	DATE JUN 2025

SCALE 1:25


DN

90

2024-06-W/D/004




#### TYPICAL PLAN 100ND - 250ND GATE VALVE INSTALLATION SCALE 1:25




## TYPICAL SECTION 100ND - 250ND GATE VALVE INSTALLATION

	GATE VALVE INSTALLATION IN PRECAST N	IANHOLE	
PIPE NUMBER	DESCRIPTION	MATERIAL	QUANTITY
GV1-1	D1 uPVC MAINLINE	STANDARD	
GV1-2	D1 DIAMETER uPVC - STEEL FLANGE ADAPTOR.	STANDARD	2
GV1-3	D1 DIAMETER PN16 CAP TOP OPERATED RESILIENT SEATED GATE VALVE TO SANS 664.	DUCTILE IRON - EPOXY PAINTED	1
	D1 = 75mm DIAMETER UP TO AND INCLUDING 250mm DIA	AFTER RIPELINES	
	DI = 75MM DIAMETER OF TO AND INCLUDING 250MM DIAM	HEIER PIPELINES	



## TYPICAL PLAN 300ND - 600ND GATE VALVE INSTALLATION

SCALE 1:25



## TYPICAL SECTION 300ND - 600ND GATE VALVE INSTALLATION

GATE VALVE INSTALLATION IN PRECAST MANHOLE

GATE VALVE INSTALLATION IN PRECAST MANIFOLE				
PIPE NUMBER	DESCRIPTION	MATERIAL	QUANTITY	
GV2-1	D2 uPVC MAINLINE	STANDARD		
GV2-2	D2 DIAMETER uPVC - STEEL FLANGE ADAPTOR.	STANDARD	2	
GV2-3	D2 DIAMETER x 700mm LONG FLANGED STRAIGHT PIPE.	SANS 719	2	
GV2-4	D2 DIAMETER PN16 CAP TOP OPERATED RESILIENT SEATED GATE VALVE TO SANS 664.	DUCTILE IRON - EPOXY PAINTED	1	
	D2 = 300mm DIAMETER UP TO AND INCLUDING 600mm DIA	METER PIPELINES		

:: FOR TYPICAL CHAMBER DETAILS REFER TO DRAWING 2024-06/W/A/001

	REVISIONS			
П	No.	DATE	BY	DESCRIPTION
П				
П				
П				

#### MEGHANICAL NOTES:

- ALL FLANGES TO BE DRILLED SABS 1123-1977 (1600/3)
- ALL VALVES, STRAINERS AND WATER METERS TO BE APPROVED BY ENGINEER IN WRITING.
- THE LENGTH OF PIPES AND FITTINGS ARE APPROXIMATE ONLY ACTUAL LENGTH TO BE DETERMINED BY CONTRACTO ONLY AFTER APPROVALO FO VALVES BY ENGINEER.

  NO ALLOWANCE HAS BEEN MADE IN PIPE AND FITTING
- DIMENSIONS FOR PACKINGS, GASKETS AND GAPS BETWEEN PIPEWORK PROVISION FOR THESE TO BE MADE BY SUPPLIEF FLANGE HOLES TO BE DRILLED TO ALLOW EXACT ALIGNMEN HORIZONTALLY AND VERTICALLY, AS DETAILED ON THE DRAWINGS, OF ALL PIPEWORK AND EQUIPMENT.
- ALL WELDING TO BE FULL STRENGTH, FULL PENETRATION.
- ALL PIPES, ELBOWS, TEE PIECES AND REDUCERS TO BE
- HOT-DIPPED GALVANISED. ALL PIPEWORK PASSING THROUGH BRICKWORK TO BE MALTHOID WRAPPED (4 LAYERS MIN.) AND SEALED AROUND PIPE WITH POLYSULPHIDE SEALANT ON BOTH FACES OF
- ALL BOLTS, NUTS AND GASKETS NECESSARY FOR THE PROPE INSTALLATION OF THE EQUIPMENT, TO BE SUPPLIED AS PART OF THE MECHANICAL EQUIPMENT.
- ALL VALVES TO HAVE A PEDESTAL IN CONCRETE CLASS 25MPa/19.

	REFERENCE DRAWINGS	
	PLAN Nr.	DESCRIPTION
П		
П		
П		
П		
П		
П		
П		

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT


PHOKWANE LM


#### TYPICAL GATE VALVE **INSTALLATION IN PRECAST** MANHOLE

DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		LDATEMAN	

SCALE AS SHOWN

2024-06-W/D/005






ROAD CROSSING


SCALE 1:25

TYPE	FLANGED	SLEEVE Ø	TYPE	SLEEVE PIPE				
	STEEL PIPE			NO. OF 2.44m	LENGTH OF	٧.		-
A	65 ND	300 ND		LENGTHS	SLEEVE	Х	ľ	4
В	80 ND	300 ND	1	1	2.440	1.990	-	2x0.565
C	100 ND	300 ND	2	2	4.880	4.430	-	2x0.565
l D	150 ND	375 ND	3	3	7.320	6.000	0.870	2x0.565
l F	200 ND	450 ND	4	4	9.760	6.000	3.310	2x0.565
l Ē	250 ND	525 ND	5	5	12.200	6.000	5.570	2x0.565
			6	6	14.640	2x6.000	2.190	2x0.565
G	300 ND	600 ND	7	7	17.080	2x6.000	4.630	2x0.565
H	350 ND	675 ND	8	8	19.520	3x6.000	1.070	2x0.565
1 1	400 ND	675 ND	9	9	21.960	3x6.000	3.510	2x0.565
l J	450 ND	750 ND	10	10	24.400	3x6.000	5.950	2x0.565
ĸ	500 ND	900 ND	11	11	26.840	4x6.000	2.390	2x0.565
	300 ND	300 ND	12	12	29.280	4x6.000	4.830	2x0.565


NOTE:
TYPE C-4 WILL MEAN THE FOLLOWING CROSSING TYPE
-100ND FLANGED STEEL PIPE
-300ND CONCRETE SLEEVE PIPE. 100D
WITH THE FOLLOWING IN PIPE LENGTHS
'4x2.44m OF 300Ø CONCRETE SLEEVE PIPES
'1x6m FLANGED STEEL PIPE OF 100ND
'1x3.310m FLANGED STEEL PIPE OF 100ND
'2x0.565m FLANGED STEEL PIPE OF 100ND




SECTION
ICAL SLEEVE PIPE THROUGH GRAVEL ROAD PAVEMENT
SCALE 120



LARGE SLEEVE PIPES



SMALL SLEEVE PIPES : ND <= 525mm



DETAIL A - SKID BLOCK

SCALE 1:5

REV	isions		
No.	DATE	BY	DESCRIPTION
NO	res		

REFERENCE DRAWINGS			
PLAN Nr.	DESCRIPTION		
APPROVED:			

APPROVED:	
ENGINEER:	DATE:
APPROVED:	
CLIENT:	DATE:
PRINT ISSUED ON	



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600 Welkom, 9460 South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

## UPGRADING OF HARTSWATER WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

#### TYPICAL SLEEVE PIPE DETAILS AND CONCRETE ENCASEMENT FOR WATER PIPELINES


DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		LRATEMAN	II IN 2025


SCALE AS SHOWN


DRAWING

2024-06-W/D/006


REVISION No.







STOP COCK CHAMBER




			`
REV No.	ISIONS	BY	DESCRIPTION
NO.	DATE	ьт	DESCRIPTION
NOT	res		
DEE	ERENCE	DDANY	NCC
	N Nr.	DRAWI	DESCRIPTION
APPROV ENGINEE			DATE:
APPROV	ED:		
	ISSUED ON		DATE:
A			
	Ter	أحأه	Tsweu
#	130	ela	
/TIV	+ 27 (0)83 2		TING ENGINEERS
329 Stat PO Box 2	eway Cham 2600,Welko	bers, State om, 9460, S	way, Welkom, outh Africa
7	P	CLIENT	
<b>(6)</b>	<u>D</u>		PHOKWANE
	20	LO	CAL MUNICIPALITY
PROJE	ст		
			OF HARTSWATER
V	VAIE	KIKI	EATMENT PLANT
	MENTING A	GENT:	
IMPLE		PHO	KWANE LM
	/ING TITLE	PHO	KWANE LM


**DETAILS** 

DESIGN	DATE	DRAWN	DATE
	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		J.BATEMAN	JUN 2025


SCALE AS SHOWN

2024-06-W/D/008







#### SECTION B-B FOR (150mm Ø PIPE IN PRECAST BASE) SCALE 1:25



SECTION B-B FOR (150mm Ø PIPE CAST IN SITU BASE) SCALE 1:25




#### MANHOLE PLAN SECTION C-C




(150mm Ø PIPE IN PRECAST BASE)

## SEWER CONNECTION MARKER BLOCK DETAILS



## **DETAILS OF LETTERS FOR ETCHING**

SCALE 1:1



### NOTES ON MANHOLES AND ACCESSORIES

1. Manholes of Precast Concrete Sections:

a) All concrete, benching and sealers to comprise of Dolomite aggregate and shall comply with SABS 1200 G as applicable,

b) Precast concrete sections to comply with SABS 1294.

c) Classes of concrete:

i) Precast concrete sections - 30MPar/9mm

ii) All other concrete - 20MPar/9mm

d) Channels in manholes to be laid in the wot concrete floor and the first precast concrete section to be placed and the benching completed within 24 hours after casting the concrete floor. No driers will be permitted for the benching. Benching to be steel trowel led to a smooth finish.

faces shall be struck to form a smooth, flat surface except where membels are to be plastered.

() All brides shall be moistened prior to laying, in addition, the course of bricks last laid shall be moistened by sprinkling before the next course is laid thereon. One brick wall shall be laid in English bond consisting of alternate courses of headers and stretchers. Where required, one and a half brick walls shall be laid in English bond consisting of alternate courses of headers and stretchers on each face of the wall, with header courses staggered.

d) Every course shall be laid fair and level by line. All brickwork shall be pluths, square and true to the dimensions given on the drawings. All brickwork shall be built lightly against pipes, foundations and other structural parts. No bats shall be used except for bond.

9) Step irons shall be built may shickwork proceeds.

I) Where brickbuilt manholes are constructed in wet ground or where ordered by the Engineer, their external surfaces shall be plastered. The joints in such external brickwork shall be traked out to a depth of 12mm before plastering. In all cases, manholes shall be waterlight and shall be tested for water-lightness.

representations.

Treed concrete slabs shall be 25MPa concrete. Brick manhole sizes shall not be less than the sions shown in SABS 1200 LD.

#### 3. Penetrations

a) Benching for manholes shall consist of concrete Class 20/19, steel trowel led to a smooth, impervious

trisish.

D) The inverts of manholes shall be provided with half round channeling of the same diameter of the outgoing pipe. The benching shall be carried up vertically from the channel to the level of the soffit of the higher ple from where it shall be sloped upwards at a slope of 15 to the walls. An arrisr of not less than 25mm shall be provided between the vertical side of the channel and the sloping benching. Upon completion of trowelling, the benching shall be cured by being kept well for one week

DIMENSION X AND Y FROM DRAWING					
PIPE DIAMETER	'X'	Ϋ́			
D(mm)	(mm)	(mm)			
110	100	120			
160	100	165			
200	125	450			
250	125	475			
315	150	550			
355	150	-			
400	250	-			

#### NOTES:


DIMENSION W = OD+600
W = PAY WIDTH OF PIPE TRENCH
THE APPROPRIATE CHANNEL WIDTH DIAMETER
FOR ALL INCOMING AND OUTGOING SEWER LINES MUST BE INSTALLED IN TERMS OF THE RESPECTIVE LAYOUT AND LONGITUDINAL SECTION PLANS FOR THIS PROJECT



CONCRETE MANHOLE LID



TYPICAL LOCKABLE MANHOLE COVER LID



ALTERNATIVE LOCKABLE MANHOLE COVER LID

REVISIONS DATE DESCRIPTION NOTES

REFERENCE DRAWINGS

PRINT ISSUED OF





PHOKWANE LOCAL MUNICIPALITY

**UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

PHOKWANE LM


**TYPICAL SEWER MANHOLE. RODDING EYE AND MARKER DETAILS** 


DESIGN	DATE	DRAWN	DATE	1
=	JUN 2025	-	JUN 2025	l
SURVEYED	DATE	CHECKED	DATE	ı
Ē		J.BATEMAN	JUN 2025	ı

SCALE AS SHOWN


1.0

2024-06-S/D/001






DETAIL No. 1 OF SHAFT/











RODDING EYE PLAN VIEW


SCALE 1:20

110mmØ PVC SEWER PIPE





PLAN VIEW SHOWING RAW WATER PUMP STATION LAYOUT SCALE 1:25



#### LEGEND

HDG - HOT DIP GALVANIZED

SP2	PIPE SUPPORT	SEE DRAWING No : DYN-075-006-002		
SP1	PIPE SUPPORT	SEE DRAWING No : DYN-075-006-002	2	
P30	FLANGE ADAPTOR	250 NB FLANGE ADAPTOR TO SANS 1123 TABLE 1000/3	1	Carbon Steel To JIS G3452
P29	FLANGE ADAPTOR	300 NB FLANGE ADAPTOR TO SANS 1123 TABLE 1000/3	1	Carbon Steel To JIS G3452
P28	MOTOR	KW XXX RPM XXX	2	
P27	PUMP ASSEMBLY	ETANORM 250-200-435-3E	2	
P26	DELIVERY PIPE	250 NB SCH 40	6 m	ASTM A106 Grade B Carbon Steel Seamless HD0
P25	PADDLE FLANGE	300 NB TO ASME 16.5 (OD 405 X 326 ID X 5 THK)	1	Mild steel HDG
P24	PADDLE FLANGE	250 NB TO ASME 16.5 (OD 355 X 258 ID X 5 THK)	1	Mild steel HDG
P23	DISMANTLING JOINT	250 NB FLANGE DRILLING TO PN10	1	SANS 1431 GR 350 WA
P22	SWEEP TEE FITTING	250 NB BUTT WELD TO ANSI B19.6	1	Carbon Steel To JIS G3452
P21	FLANGE	250 NB SANS 1123 TABLE 1000/3 TYPE NP/8	14	Carbon Steel A106
P20	SPOOL PIECE	250 NB SCH 40	1	ASTM A106 Grade B Carbon Steel Seamless HD
P19	SPOOL PIECE	250 NB SCH 40	1	ASTM A106 Grade B Carbon Steel Seamless HD
P18	VALVE	250 NB BUTTERFLY WAFER TYPE BOLTED IN BETWEEN FLANGES	2	Cast iron to SANS 1024 GR 250
P17	SPOOL PIECE	250 NB SCH 40	0.3 m	ASTM A106 Grade B Carbon Steel Seamless HD
P16	NON RETURN VALVE	250 NB C.W WAFER DUEL PLATE (BOLTED BETWEEN FLANGES)	2	Cast steel
P15	REDUCER	200 X 250 NB BUTT WELD CONCENTRIC	2	Carbon Steel To JIS G3452 HDG
P14	BEND	200 NB STD LONG RADIUS BUTT WELD	2	Carbon Steel To JIS G3452 HDG
P13	PRESSURE GAUGE	ASSEMBLY - SEE DRAWING NUMBER: DYN 075-006-002	4	
P12	DELIVERY PIPE	200 NB SCH 40	3 m	ASTM A106 Grade B Carbon Steel Seamless HD
P11	FLANGE	200 NB SANS 1123 TABLE 1000/3 TYPE NP/8	2	Carbon Steel A106
P10	SPOOL PIECE	250 NB SCH 40	2	ASTM A106 Grade B Carbon Steel Seamless HD
P9	FLANGE	250 NB SANS 1123 TABLE 1000/3 TYPE NP/8	6	Carbon Steel A106 HDG
P8	REDUCER	300 X 250 NB ECCENTRIC	2	Carbon Steel To JIS G3452 HDG
P7	DISMANTLING JOINT	300 NB FLANGE DRILLING TO PN10	2	SANS 1431 GR 350 WA
P6	STRAIGHT TEE	300 NB WELD TO ANSI B 16.9	1	Carbon Steel To JIS G3452 HDG
P5	BEND	300 NB STD LONG RADIUS BUTT WELD	2	Carbon Steel To JIS G3452 HDG
P4	SPOOL PIECE	300 NB NB SCH 40	2	ASTM A106 Grade B Carbon Steel Seamless HD0
P3	VALVE	250 NB GATE HAND OPP. FLANGE DRILLING TO SANS 1123 TABLE 1000/3	2	Cast iron to SANS 1024 GR 250
P2	FLANGE	300 NB SANS 1123 TABLE 1000/3 TYPE NP/8	16	Carbon Steel A106 HDG
P1	SUCTION PIPE	300 NB NB SCH 40	6 m	ASTM A106 Grade B Carbon Steel Seamless HD
MARK	ITEM	DESCRIPTION	QTY	MATERIAL

## FOR INFORMATION

	REV	'ISIONS		
	No.	DATE	BY	DESCRIPTION
	0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9
2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

DELIVERY.

4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (

ADDITIONAL 5% TO BE SUPPLIED ). PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION

OF MATING FLANGE.

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.

7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924

MAIL: corne@dynatech1.co.za



REFERENCE DRAWINGS DESCRIPTION

APPROVED:

APPROVED:

PRINT ISSUED ON



# Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE **EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT


**RAW WATER PUMP SET** 

**LAYOUT SHEET 1 OF 2** 

DESIGN	DATE	DRAWN	DATE
		C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED	DATE
		A.DE WET	NOV 2025

**SCALE** AS SHOWN

### DYN-075-006-001



REV	ISIONS		
No.	DATE	BY	DESCRIPTION
0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B" 3) ALL PIPING TO ASTITATION GRADE B
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE
FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

- 4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (
- ADDITIONAL 5% TO BE SUPPLIED ). PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO
- 5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION OF MATING FLANGE.

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110. 7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924




DESCRIPTION APPROVED:

PRINT ISSUED ON



# Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

#### **UPGRADING OF HARTSWATER WATER TREATMENT PLANT**

IMPLEMENTING AGENT:

PHOKWANE LM


**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT


#### **RAW WATER PUMP SET** LAYOUT SHEET 1 OF 2


DESIGN	DATE	C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025

**SCALE** AS SHOWN

### DYN-075-006-002







#### LEGEND HDG - HOT DIP GALVANIZED

1100-110	T DIP GALVANIZED			
PSO27	FLANGE ADAPTOR	350 NB FLANGE ADAPTOR TO SANS 1123 TABLE 1000/3	1	Carbon Steel To JIS G3452 HDG
PSO26	BELL MOUTH	450 NB BELL MOUTH TO SANS 719	2	Carbon Steel To JIS G3452 HDG
PSO25	FLANGE	350 NB SANS 1123 TABLE 1000/3 TYPE NP/8	1	Carbon Steel A106 HDG
PSO24	REDUCER	350 X 300 NB STD CONCENTRIC (BUTT WELD)	2	Carbon Steel To JIS G3452 HDG
PSO23	PADDLE FLANGE	300 NB TO ASME 16.5 (OD 405 X 326 ID X 5 THK)	1	Mild steel HDG
PSO22	BEND (MODIFIED)	300 NB STD 90° LONG RADIUS (CUT TO SUIT 60°) BUTT WELD	1	Carbon Steel To JIS G3452 HDG
PSO21	REDUCER	300 X 250 NB STD CONCENTRIC (BUTT WELD)	2	Carbon Steel To JIS G3452 HDG
PSO20	DISMANTLING JOINT	300 NB FLANGE DRILLING TO PN10	1	
PSO19	SWEEP TEE	250 X 300 NB FABRICATED TO ANSI B19.6	1	ASTM A106 Grade B Carbon Steel Seamless HD
PSO18	VALVE	250 NB BUTTERFLY WAFER TYPE BOLTED IN BETWEEN FLANGES	2	Cast iron to SANS 1024 GR 250
PSO17	NON RETURN VALVE	250 NB C.W WAFER DUEL PLATE (BOLTED BETWEEN FLANGES)	2	Cast steel
PSO16	BEND	250 NB STD 90° LONG RADIUS BUTT WELD	2	Carbon Steel To JIS G3452 HDG
PSO15	FLANGE	250 NB SANS 1123 TABLE 1000/3 TYPE NP/8	12	Carbon Steel A106 HDG
PSO14	DELIVERY PIPE	250 NB NB SCH 40	12 m	ASTM A106 Grade B Carbon Steel Seamless HD
PSO13	REDUCER	150 X 250 NB STD CONCENTRIC (BUTT WELD)	2	Carbon Steel To JIS G3452 HDG
PSO12	FLANGE	150 NB EN1092-2 TO SUIT ETANORM 200-150-400 PUMP DISCHARGE	2	Carbon Steel To JIS G3452 HDG
PSO11	PUMP ARRANGEMENT	ETANORM 200-150-400 PUMP C.W WEG W20 55 kW MOTOR	2	
PSO10	FLANGE	200 NB EN1092-2 TO SUIT ETANORM 200-150-400 PUMP SUCTION	2	Carbon Steel A106 HDG
PSO9	REDUCER	350 X 200 NB ECCENTRIC	2	Carbon Steel To JIS G3452 HDG
PSO8	SUCTION PIPE	300 NB NB SCH 40	2	ASTM A106 Grade B Carbon Steel Seamless HD
PSO7	VALVE	300 NB GATE HAND OPP. FLANGE DRILLING TO SANS 1123 TABLE 1000/3	2	Cast iron to SANS 1024 GR 250
PSO6	FLANGE	300 NB SANS 1123 TABLE 1000/3 TYPE NP/8	14	Carbon Steel A106 HDG
PSO5	REDUCER	450 X 300 NB ECCENTRIC (FABRICATED 1000 LG)	2	ASTM A106 Grade B Carbon Steel Seamless HD
PSO4	DISMANTLING JOINT	450 NB FLANGE DRILLING TO PN10	2	SANS 1431 GR 350 WA
PSO3	FLANGE	450 NB SANS 1123 TABLE 1000/3 TYPE NP/8	12	Carbon Steel A106 HDG
PSO2	PADDLE FLANGE	450 NB TO ASME 16.5 (OD 550 X 460 ID X 5 THK)	1	Mild steel HDG
PSO1	BEND	450 NB STD 90° LONG RADIUS BUTT WELD	2	Carbon Steel To JIS G3452 HDG
MARK	ITEM	DESCRIPTION	QTY	MATERIAL

### FOR INFORMATION

	REV	ISIONS		
	No.	DATE	ВҮ	DESCRIPTION
	0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS ISSUED FOR INFORMATION

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9

2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE
FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

DELIVERY.
4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. ( ADDITIONAL 5% TO BE SUPPLIED ).

PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION OF MATING FLANGE.

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110. 7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924

MAIL: corne@dynatech1.co.za



PLAN Nr.	DESCRIPTION

APPROVED:

PRINT ISSUED ON



# Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM


**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT

#### HIGH LIFT PUMP SET NO 1 LAYOUT SHEET 1 OF 2

DESIGN	DAIL	C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025

**SCALE** AS SHOWN

### DYN-075-006-003



SCALE 1:75

P30 RUNNING NIPPLE

ITEM

P29 SOCKET

MARK

20 NB BSP THREAD TO BS 1740

20 NB BSP THREAD SOCKET TO BS 1740

DESCRIPTION

### FOR INFORMATION

	REVISIONS			
	No.	DATE	BY	DESCRIPTION
	0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

4)BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (

ADDITIONAL 5% TO BE SUPPLIED ). PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION OF MATING FLANGE. 6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924



REFERENCE DRAWINGS DESCRIPTION

APPROVED:

PRINT ISSUED ON



# Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

#### **UPGRADING OF HARTSWATER WATER TREATMENT PLANT**

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE **EQUIPMENT ROOM - LOW LIFT PUMPS** 

HIGH LIFT PUMP SET NO 1

**LAYOUT SHEET 2 OF 2** 

DESIGN	DATE	DRAWN	DATE	
		C.SWART - DYNATECH	NOV 2025	
SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025	
		7 2 2		

**SCALE AS SHOWN** 


16 WROUGHT STEEL

QTY

WROUGHT STEEL

MATERIAL

DYN-075-006-004



#### **REVISIONS**

	No.	DATE	BY	DESCRIPTION
	0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B"

- 3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
  ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR
- 4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (
- ADDITIONAL 5% TO BE SUPPLIED ).
- PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO
- 5) DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE
- MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION OF MATING FLANGE. 6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.

7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924

MAIL: corne@dynatech1.co.za



REFERENCE DRAWINGS

	·				
	PLAN Nr.	DESCRIPTION			
ı					

APPROVED:

PRINT ISSUED ON



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

#### **UPGRADING OF HARTSWATER WATER TREATMENT PLANT**

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE

**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT


> HIGH LIFT PUMP SET NO 2 LAYOUT SHEET 1 OF 3

	2-20-01	2,	C.SWART - DYNATECH	NOV 2025
	SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025
lſ				

AS SHOWN

**SCALE** 

DYN-075-006-005



REV	'ISIONS		
No.	DATE	BY	DESCRIPTION
0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

- 1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B" 3) ALL PIPING TO ASTITATION GRADE B
  3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
  ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE
  FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR
- 4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. ( ADDITIONAL 5% TO BE SUPPLIED ).
- PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO
- 5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION OF MATING FLANGE. 6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.
  7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924



### MAIL: corne@dynatech1.co.za REFERENCE DRAWINGS DESCRIPTION PLAN Nr.


ARROVED:				

APPROVED:

PRINT ISSUED ON



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT

> HIGH LIFT PUMP SET NO 2 **LAYOUT SHEET 2 OF 3**

ı		DESIGN	DAIL	DIVAWIN	DAIL
				C.SWART - DYNATECH	NOV 2025
		SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025
ı					


**SCALE** 

**DYN-075-006-006** 

AS SHOWN

REVISION No.

0.5



MARK

ITEM

DESCRIPTION

QTY

MATERIAL

FOR INFORMATION

DRAWING REVISED AS PER COMMENTS -

2) ALL PIPING TO ASTM A106 GRADE "B" 3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE

4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. ( ADDITIONAL 5% TO BE SUPPLIED ).

PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.

CONSULTING COMPANY

DYNATECH CONSULTING



REFERENCE DRAWINGS DESCRIPTION



**PHOKWANE LOCAL MUNICIPALITY** 

**UPGRADING OF HARTSWATER WATER TREATMENT PLANT** 


PHOKWANE LM

**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT

> HIGH LIFT PUMP SET NO 2 LAYOUT SHEET 3 OF 3

DESIGN	DAIL	DIVAWIN	DAIL
		C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025

DYN-075-006-007



QTY

MARK

ITEM

DESCRIPTION

MATERIAL

### FOR INFORMATION

**REVISIONS** 

	No.	DATE	BY	DESCRIPTION
	0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B"

- 3) ALL PIPING TO ASTITATION GRADE B
  3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
  ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE
  FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR
- 4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (
- ADDITIONAL 5% TO BE SUPPLIED ). PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO
- 5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION
- OF MATING FLANGE. 6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.
  7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

CONSULTING COMPANY

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za



REFERENCE DRAWINGS

	PLAN Nr.	DESCRIPTION

PRINT ISSUED ON



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE **EQUIPMENT ROOM - LOW LIFT PUMPS** 


PHASE 1 PUMP ARRANGEMENT

SERVICE WATER PUMP SET LAYOUT SHEET 1 OF 3

220.3.1		C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED	DATE
		A.DE WET	NOV 2025

AS SHOWN

DYN-075-006-008



REVISIONS			
No.	DATE	ВУ	DESCRIPTION
0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS -

### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE
FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

DELIVERY.
4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (

ADDITIONAL 5% TO BE SUPPLIED ). PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

5) ♠ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION OF MATING FLANGE. 6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.
7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924



#### REFERENCE DRAWINGS

MAIL: corne@dynatech1.co.za

PLAN Nr.	DESCRIPTION


APPROVED:

APPROVED:

PRINT ISSUED ON



# Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE** LOCAL MUNICIPALITY

PROJECT

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT


#### SERVICE WATER PUMP SET **LAYOUT SHEET 2 OF 3**

DESIGN	DATE	C.SWART - DYNATECH	NOV 202
SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 202

AS SHOWN

**SCALE** 

DYN-075-006-009



REVISIONS

No. DATE BY DESCRIPTION

0.5 04/11/25 C.S DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

 ALL BENDS TO ANSI B16.9
 ALL PIPING TO ASTM A106 GRADE "B"
 ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (
ADDITIONAL 5% TO BE SUPPLIED).

PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO SUIT.

5) ♣ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION

OF MATING FLANGE.
6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.
7) PIPE DESIGN,FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924



#### REFERENCE DRAWINGS

MAIL: corne@dynatech1.co.za

	PLAN Nr.	DESCRIPTION

APPROVED:


ENGINEER: DATE:

APPROVED:

PRINT ISSUED ON



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

# UPGRADING OF HARTSWATER WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE

EQUIPMENT ROOM - LOW LIFT PUMPS PHASE 1 PUMP ARRANGEMENT

# SERVICE WATER PUMP SET LAYOUT SHEET 3 OF 3

DESIGN	DATE	DRAWN	DATE
		C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED	DATE
		A.DE WET	NOV 2025


SCALE


DRAWING No.

### DYN-075-006-010

AS SHOWN

0.5





REV	'ISIONS		
No.	DATE	ВУ	DESCRIPTION
0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9
2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

DELIVERY.
4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (

ADDITIONAL 5% TO BE SUPPLIED ).
PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

SUIT.
5) DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE
MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION
OF MATING FLANGE.

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.
7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308

MAIL: braam@dynatech1.co.za

CELL: 079 4052 924

MAIL: corne@dynatech1.co.za



## REFERENCE DRAWINGS

I	PLANINI.	DESCRIPTION

APPROVED:

ENGINEER:\_\_\_\_\_ DATE:\_\_\_\_


APPROVED:

CLIENT:\_\_\_\_

PRINT ISSUED ON



#### Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

# UPGRADING OF HARTSWATER WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE
EQUIPMENT ROOM - LOW LIFT PUMPS

PHASE 1 PUMP ARRANGEMENT
RECOVERY WATER PUMP SET


LAYOUT SHEET 2 OF 4

		C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED	DATE
		A.DE WET	NOV 2025

SCALE

**AS SHOWN** 

DYN-075-006-012



MARK

### FOR INFORMATION

**REVISIONS** No. DATE BY DRAWING REVISED AS PER COMMENTS -

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9 2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION
ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE
FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. ( ADDITIONAL 5% TO BE SUPPLIED ).

PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO 5) DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE
MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION

OF MATING FLANGE.

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110. 7) PIPE DESIGN, FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

#### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dynatech1.co.za CELL: 079 4052 924

MAIL: corne@dynatech1.co.za



REFERENCE DRAWINGS DESCRIPTION

APPROVED:

APPROVED:

PRINT ISSUED ON



# Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



**PHOKWANE LOCAL MUNICIPALITY** 

PROJECT

#### **UPGRADING OF HARTSWATER** WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

DRAWING TITLE

**EQUIPMENT ROOM - LOW LIFT PUMPS** PHASE 1 PUMP ARRANGEMENT


#### RECOVERY WATER PUMP SET **LAYOUT SHEET 3 OF 4**


		C.SWART - DYNATECH	NOV 2025
SURVEYED DA	ATE	CHECKED A.DE WET	DATE NOV 2025

**SCALE** 

DYN-075-006-013

AS SHOWN





PIPE SUPP. MARKED AS "SP3" - PLAN

SCALE 1:10

	RE\	/ISIONS		
	No.	DATE	ВУ	DESCRIPTION
	0.5	04/11/25	C.S	DRAWING REVISED AS PER COMMENTS - ISSUED FOR INFORMATION

#### GENERAL NOTES

1) ALL BENDS TO ANSI B16.9
2) ALL PIPING TO ASTM A106 GRADE "B"
3) ALL PIPING TO BE PAINTED IN ACCORDANCE WITH CLIENT SPECIFICATION ALL CLOSURE PIECES ARE TO BE SUPPLIED WITH ONE LOOSE FLANGE SUITABLY BOLTED TO THE FIXED FLANGE FOR

DELIVERY.

4) BOLTS, NUTS AND WASHERS TO BE BAGGED AND TAGGED FOR DELIVERY WITH RELEVANT LINE IDENTIFICATION NUMBER. (
ADDITIONAL 5% TO BE SUPPLIED ).
PIPE SUPPORTS TO BE FABRICATED & POSITIONED ON SITE TO

5) ♣ DENOTES A CLOSURE PIECE; PIPE LENGTH TO BE SITE

MEASURED & LOOSE FLANGE WELDED ON TO SUIT ORIENTATION

OF MATING FLANGE.

6) ALL PIPING TO CONFORM TO THE GENERAL PIPE CONSTRUCTION DWS1110.

7) PIPE DESIGN,FABRICATION AND INSTALLATION TO ASME 31.3

#### CONSULTING COMPANY

### DYNATECH CONSULTING

CELL: 082 3710 308 MAIL: braam@dyna†ech1.co.za CELL: 079 4052 924



MAIL: corne@dynatech1.co.za

Computer Aided Draughling and Design

REFERENCE DRAWINGS

PLAN Nr. DESCRIPTION

APPROVED:


ENGINEER: DATE:

APPROVED:

PRINT ISSUED ON



#### Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

# UPGRADING OF HARTSWATER WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

EQUIPMENT ROOM - LOW LIFT PUMPS
PHASE 1 PUMP ARRANGEMENT


RECOVERY WATER PUMP SET LAYOUT SHEET 4 OF 4


DESIGN	DATE	C.SWART - DYNATECH	NOV 2025
SURVEYED	DATE	CHECKED A.DE WET	DATE NOV 2025


SCALE


DYN-075-006-014


**AS SHOWN** 











SCALE 1 : 20

13	150NB Flange Adaptor	As per Manufacture	1
12	150NB Puddle pipe	Mild steel HDG	1
11	100NB Special Tee with eccentric reducer	Mild steel HDG	1
10	100NB Knife gate valve	As per Manufacture	2
9	100NB Swing check valve	As per Manufacture	2
	100NB Pipe supports	Mild steel HDG	5
7	100NB Puddle	Mild steel HDG	3
6	100NB Pipe with socket	Mild steel HDG	2
5	100NB 90 ° Bend	Mild steel HDG	4
4	100NBFlange T/1000/3	As per Manufacture	18
3	100NB Pipes with different dimensions	Mild steel HDG	7
2	100NB Pipe support	Mild steel HDG	4
1	Xylem NP 3127HT3 Adaptive 489 Submersible pump set	As per Manufacture	2
ITEM	DESCRIPTION	MATERIAL	QTY

RE	<b>VISIONS</b>		
No.	DATE	BY	DESCRIPTION
NO	TES		

REFERENCE DRAV	WINGS
PLAN Nr.	DESCRIPTION

APPROVED:

ENGINEER:\_\_\_\_\_\_ DATE:\_\_\_\_\_

APPROVED:

CLIENT:\_\_\_\_\_ DATE:\_\_\_\_\_

PRINT ISSUED ON



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

UPGRADING OF HARTSWATER WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

GENERAL ARRANGEMENT:
SUPERNATANT PUMP STATION
BUILDING
SHEET 2 OF 2

DESIGN	DATE	DRAWN	DATE
A. de. Wet	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		E.vd Hoff	JUN 2025


SCALE AS SHOWN

DRAWING No.


WCE-2025-06-001a

REVISION No.


0.1




LAYDUT Scale 1:15



SECTION B-B
SCALE 1:15



SECTION A-A scale 1 : 15



ISOMETRIC scale 1:15

11	80NB Pipe Flanged (T/1000/3)	Mild steel HDG	1
10	80NB Special T-piece	Mild steel HDG	1
9	80NB 90° Bend Flanged (T/1000/3)	Mild steel HDG	2
8	80NB Pipe support	Mild steel HDG	3
7	80NB Pipe Flanged (T/1000/3)	Mild steel HDG	2
6	80NB Knife gate valve	As per Manufacture	2
5	80NB Swing check valve	As per Manufacture	2
4	80NB Flanged combination nipple standard type (T/1000/3)	As per Manufacture	2
3	80NB High Quality reinforced rubber flexible host	As per Manufacture	2
2	80NB Cascade Clamp	As per Manufacture	2
1	Xylem DP 3069 LT3 412 Pump Set	As per Manufacture	2
ITEM	DESCRIPTION	MATERIAL	QTY


REVISIONS			
No.	DATE	BY	DESCRIPTION

NOTES

REFERENCE I	REFERENCE DRAWINGS			
PLAN Nr.	DESCRIPTION			
A PRODUCED.				
APPROVED:				
ENGINEER:	DATE:			
APPROVED:				
CLIENT:	DATE:			
PRINT ISSUED ON				



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkom, PO Box 2600,Welkom, 9460, South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

UPGRADING OF HARTSWATER WATER TREATMENT PLANT

IMPLEMENTING AGENT:

PHOKWANE LM

GENERAL ARRANGEMENT:
TYPICAL DRAINAGE PUMP
STATION
SHEET 2 OF 2


DESIGN	DATE	DRAWN	DATE
A. de. Wet	JUN 2025		JUN 2025
SURVEYED	DATE	CHECKED	DATE
		E.vd Hoff	JUN 2025
	I		I

SCALE AS SHOWN

DRAWING No.
WCE-2025-06-002

WCE-2025-06-002

REVISION No.



BEKA-LEDLUME-MIDI LED 5119 Side Entry Street Light Filting or Similar Approved bearing SABS mark, with high efficiency LED's (770 JumensW), Ownections, Circult Breaker, Cathyre and, amounted on Glass Filter Reinforced Polyester (GRP) pute (mounting height specified).

BEKA LEDinod (140, 290)W Pi65, EN176/RO-4400 (LM6)
Aluminum floodight or Similar Approved bearing SASS mark
Control Gear, Adjustable Bracket, Lamp, PFC Capacitor, Teffor and
Silcon Wifing, Disphragin Grommets and , Earthing, Designation
Data.

BEKA LEDnova 75W OPTIC 1300 Floodlight IP96 rating or Similar Approved bearing SABS mark, Impact Resistant Clear Glass, Bracket, Compress Gland, Diaphraym Grommels and , Earthing, Designation Data,

BEKA LEDSTREAM [14, 27]/N OPTIC 1300 Mini Floodlight I IP66 rating or Similar Approved bearing SABS mark, Impact Resistant Clear Glass, Bracket, Compress Gland, Diaphragm Grommets and , Earthing, Designation Data,

REVISIONS			
No.	DATE	BY	DESCRIPTION

NOTES

REFERENCE DRAWINGS			
PLAN Nr.	DESCRIPTION		

APPROVED:
ENGINEER: DATE:

APPROVED:
CLIENT: DATE:

PRINT ISSUED OF



Mobile: + 27 (0)83 265 1524 329 Stateway Chambers, Stateway, Welkor BO Pox 2600 Wolkom, 8460, South Africa



PHOKWANE LOCAL MUNICIPALITY

PROJECT

### UPGRADING OF HARTSWATER WATER TREATMENT PLANT

PHOKYY

PHOKWANE LM

DRAWING TITL

#### SITE PLAN EXTERNAL AREA LIGHTENING

	DESIGN	DATE	DRAWN	DATE
ı	A.de. Wet	JUN 2025	=	JUN 2025
П	SURVEYED	DATE	CHECKED	DATE
I	-	-	E.vd Hoff	JUN 2025

SCALE AS SHOWN

DRAWING No.

1.0

WCE-2025-06-003