

T2.2-12: RFP Clarification Request Form

RFP No: TP/2025/03/0003/92209/RFQ/CIDB

RFP deadline for questions / RFQ Clarifications: **Before 12h00 pm on 29 May 2025.**

ATTENTION: Seipati Sebakamotse

EMAIL Seipati.sebakamotse@transnet.net

DATE: 26/05/2025

FROM: AFMS Group (Pty) Ltd

RFP Clarification No [to be inserted by Transnet]

REQUEST FOR RFP CLARIFICATION

1. It is noted that you require a CIDB Grading of 3ME and 2EB. Your tender document states that in case of a joint venture the main partner needs to have both of these grading or a grade lower.

In the case of subcontracting, can the main contractor produce a CIDB Grading certificate of 3ME and subcontract to a service provider with a 2EB?

2. Please provide us with the KVA or each generator.

1. The main contractor should have the grading of 3EM and 2EB or higher, should the main contractor subcontract the services required, then that subcontractor should have the required CIDB grading of 3ME and 2EB or higher

2. • Bellville, Belcon building – 300KVA

• Bellville, Transnet Park building – 150KVA

• Bellville, RNC building – 200KVA

• Windermere CTC – 100KVA

• Cape Town, No. 1 Adderley Street – 250KVA

• Saldanha, Salkor building – 680KVA

• Saldanha, CTC building – 65KVA