

Questions	Answers
<p>Good day sir,</p> <p>Reference is made to the above attached Technical Schedules, are we supposed to complete all of them? The BOQ only mentions 8 of them, namely;</p> <p>4.1 Incomer Protection Relay (MAINI)  4.2 Radial Feeder Protection Relay ( RADIALF)  4.3 (MIANFO) with directional element  4.4 (DIFFO) without directional element  4.5 Bus-Section / Interconnector Protection Relay (MAINI)  4.6 Transformer Protection Relay (DIFFT)  4.7 Transformer AVR Relay (AVR)  4.8 Lock-out Protection Relay (LO1, LO2 &amp; MTR) must be a separate mechanical latching relay</p> <p>Kind Regards</p>	<p>Respond as per BID BOQ</p>
<p>Good morning,</p> <p>Could you please confirm whether ORHVS levels 1–10 is strictly required, or if we may submit at least levels 1–4, as it is currently difficult to obtain levels 1–10?</p> <p>Thank you in advance for your prompt response.</p>	<p>Yes, we require strictly ORHVS levels 1to10</p>
<p>Good Day,  Good Day Ndivhuwo</p> <p>I am just making a follow up on my email.</p> <p>I would like to enquire about the specifications for Bid 2602 S. Could you kindly confirm whether we are required to complete the schedules and submit them together with the tender, or if they are for information purposes only?</p> <p>Thank you for your assistance.  Good day Ndivhuwo,</p>	<p>The schedules from the specification are not a must</p>

I would like to enquire about the specifications for Bid 2602 S. Could you kindly confirm whether we are required to complete the schedules and submit them together with the tender, or if they are for information purposes only?

Thank you for your assistance.

Regards,