

Type	Description	Installation	Lamps		Location	Comments
			Type	Colour		

A		1200x300 60W Surface mounted LED Light Fitting, high quality PP thermoplastic diffuser, white powder coat finish aluminium trim, and Electronic Control Gear. High quality SMD LED's tested to IES LM80 and IES TM21 or Equivalent and Approved by the Health Department	Surface Mounted	60W LED	Cool White	Board Room/ Assesment Room/SCM Storage & Filling/ Waiting Room	Supplied by Lighting Projects RAM40403012-01
B		30W LED Vapour Proof Light Fitting With Electronic Control Gear or Equivalent	Surface Mounted	30W LED Vapour Proof	Cool White	Workshop/Machine Room/Spray Room/Weld Room/Oven Room/ Flammable Sore/ Ablutions	Supplied by Lihelilite/ Swanlite BEKA VAPOURLINE - VLN 30
C		Round Bulkhead Fitting Complete With 17W LED Lamps, mounted on Ceiling, or on Wall @ ± 2200mm AFFL(white trim ring) or Equivalent	Surface Mounted	17W LED	Cool White	Ablutions /Stores	Supplied by Lihelilite/ Swanlite Beka Series 30 - 17W
		Round Bulkhead Fitting Complete With 17W LED Lamps, mounted on Ceiling, or on Wall @ ± 2200mm AFFL(black trim ring) or Equivalent	Surface Mounted	17W LED	Cool White	External Walllls	Supplied by Lihelilite/ Swanlite Beka Series 30 - 17W
E		600x600 edge lit flat panel luminaire. 1 hour self contained maintained emergency version where indicated..	Recessed in access ceiling,	40W LED	4000	Offices	Robus Atmos

ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE: <b>Ngwelezane Hospital - Orthopedics &amp; Prosthetics Centre</b>				
<b>S.Nzama</b>	<b>RM</b>	<b>May '21</b>	<b>SN</b>	<b>A4</b>					
PROJ No.:	DWG No	REV	SCALE						
<b>0</b>	<b>Original Issue</b>	<b>RM</b>	<b>07/05/21</b>	<b>SN</b>	<b>20013</b>	<b>600</b>	<b>0</b>	<b>n.t.s</b>	<b>Luminaire Schedule</b>
REV	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	SHEET:	<b>1 of 2</b>		



**IBUYA** Consulting Engineers  
"POWERING DEVELOPMENT"

BLOCK D  
ESSEX PARK  
4B ESSEX TERRACE  
WESTVILLE  
P.O. BOX 1892  
WANDSBECK 3631

TEL: +27 (0)31 266 7831  
FAX: +27 (0)31 266 7831  
E-mail: ibuya@ibuya.co.za

