

## Transformer test equipment evaluation criteria

Criteria	Scoring	Returnable
Test voltage 25V-12kV	Total=10  10 points deducted if proof is not submitted	Datasheet to be provided
Accuracy of test machine must be guaranteed at <=1%	Total=10  10 points deducted if proof is not submitted	Datasheet to be provided
Measurement of tan delta/power factor, open circuit, short circuit tests must be able to be performed on the test equipment	Total=40  30 points deducted if only one test can be done  20 points deducted if only two test can be done	Datasheet to be provided
Current rating 0-5 A	Total=10  10 points deducted if proof is not submitted	Datasheet to be provided
Capacitance 0-100uF	Total=10  10 points deducted if proof is not submitted	Datasheet to be provided
PC compatibility – windows 7/10	Total=10  10 points deducted if proof is not submitted	Datasheet to be provided
Accessories – all relevant cabling and USB port with PC compatibility testing	Total=10  10 points deducted if proof is not submitted	Datasheet to be provided

The minimum threshold is 85% to qualify for further evaluation and will be scored out of 100