

 Eskom	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

To whom it may concern	Date	21 July 2025
	Enquiries	Dawn Geeson
	E-mail address	geesond@eskom.co.za

Dear Sir/Madam

Request for Enquiry Number	E1493DXKZNOU
Description / Project Title	The manufacture, testing and supply of the estimated Polymer Distribution Class, Non-linear Metal Oxide Surge Arrestors without Spark Gaps for installation on 11KV, 22 KV, 33 KV and 19 KV SWER Distribution System on an “as and when” required basis for Distribution Division for a period of three (03) years.
Tender Questions Closing Date	25 August 2025

Item	Questions	Answers	Clarity Published Dates
1.	A time extension was requested to the tender closing date	A time extension to the tender closing date was granted, please check addendum 1	21 July 2025
2.	Could you please provide the creepage distance? Or if you have the real product photo? It'll help us confirm surge arrester more carefully.	As per Clause 4.3 b) of the technical specification 240-56062797 - SPECIFICATION FOR DISTRIBUTION CLASS NEUTRAL SURGE ARRESTERS FOR 11 KV AND 22 KV SYSTEMS the arresters shall have a minimum creepage distance of 140 mm.	21 July 2025
3.	In the Commercial Presentation it is stated that: ▪ All pages must be <u>initialed</u>	Due to the new size constraints when submitting documents electronically. Please ensure that all mandatory documents submitted by your company are	21 July 2025

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

	Tender Questions and Answers	Document Identifier	240-7124948	Rev	1
		Effective Date	01 April 2023		
		Review Date	April 2026		

	Please confirm which documents need to be initialled on all pages. Does this refer to every page of all submission documents or only to certain documents e.g. NEC3 document; PS5 Price Schedule, Conditions of tender? Does this refer only to the Commercial documents or also to Technical, Quality & SHEQ?	initialed. The contractual requirements cant be verified later	
--	---	---	--

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30