Nº
KBR-286-0-017







NOTE: STEELFRAME TO BE (F BOLTED) CONSTRUCTION U.O.S.
DIMENSION OF FLOORPLAN ARE - GIVEN WITHOUT GAP OF 15mm BETWEEN 70×8 ℞ AND 6mm CHQ ℞ TYPE 'VASTRAP'
ALL WELDING TO BE DONE IN ACCORDANCE WITH SPEC. UKZ-10.06.
ALL FLOORING TO BE SALWELDED, EXCEPT WERE OTHERWISE STATED.
BOLTED PLATES TO BE SEALED WITH PLASTIC SEALANT.
ALL STRUCTURALS TO BE STRICTLY IN ACCORDANCE WITH ESCOM SPECIFICATIONS.























DRAWING RECORDS TEKENINGLÊER

0 61/9306 Rv0

TITLE:
ESCOM—TUTUKA—EVKOM
ELEVATOR PIT COVER
STRUCTURAL DETAILS
BOILER Nº1 — DUST HANDLING PLANT

ESCOM DRG Nº

SCALE	1:20 / 1:50 / 1:2 / 1:5		
DRAWN	H ZACH	15 FEB 83	D.O.M.
CHECKED		10.3.83	ENG.
APPROVED		10.3.83	CLIENT
PROJECT Nº 36-206			
SHEET 1 OF 1			

BÜHLER-MIAG SOUTHERN AFRICA (PTY) LTD.
POSTAL ADDRESS P.O. BOX N
OFFICE JOHANNESBURG 2000, RSA
MASONIC CENTRE
IN LOVEDAY STREET
TELEPHONE 832-3861
TELEX R-2013 SA
CABLE NOM "BÜHLERMIAG"

DWG. Nº AKBR-286-0-017
REV. Nº

DRAWING Nº	REV	ISSUED BY	DESCRIPTION
AKBR-286-0-002			CONCRETE DETAILS OF CONV. SUPPORT BASES

DRAWING Nº	REV	ISSUED BY	DESCRIPTION

REVISIONS

REV	DRAWN DATE	CHK'D DATE	DESCRIPTION

REV	DRAWN DATE	CHK'D DATE	DESCRIPTION

All rights on this drawing rest at any time with our firm. Without our written consent it may not be copied or reproduced, neither may it be communicated or reviewed accessible to third parties.
BÜHLER MIAG

MECH. ENG.
ELECT. ENG.
INSTRUM. ENG.
CIVIL ENG.
STRUCT. ENG. 10.03.83
PROJ. ENG.

MICROBOX