



## MINUTES OF THE SCOPE CLARIFICATION MEETING

TENDER NO: CTT 26740 -

### SUPPLY AND INSTALLATION OF HIGH-SECURITY PERIMETER FENCING AT PETROSA FUEL DEPOT, BLOEMFONTEIN

<b>Meeting No.:</b>		<b>Date:</b>	17 April 2026 11: 00
<b>Present:</b>	<p><b>PetroSA:</b> Saseka Sihlwayi, Fumane Mokhele, Sylvia Motshabi, Esme Kleinhans (on-line) Luyanda</p> <p><b>Tenderers :</b> Darryl Petersen, Frans De Jongh, Moitei Shata, Seipati Lepheane, Daniel Zungu</p>		
<b>Apologies:</b>	None		
<b>Copies to:</b>	All Tenderers		
<b>Chair</b>	Saseka Sihlwai	<b>Scribe:</b>	Saseka Sihlwai

#### DISCUSSION

<b>1.</b>	<p><b>Welcome &amp; Introduction</b></p> <p>The meeting commenced at 11:00. The Chairperson welcomed everyone present at the meeting.</p> <p>Safety inductions was presented by SHEQ Department.</p> <p>PetroSA team introduced themselves.</p>
<b>2.</b>	<p><b>Technical Questions:</b></p> <p><b>Question</b></p> <p>The scope has provided for two (2) options of electric fence. Which one should bidders price on?</p> <p><b>Answer</b></p> <ul style="list-style-type: none"> <li>• The electrified razor smart coil shall be installed on the entire fence and all the gates (excluding sliding gates).</li> <li>• The sliding gates shall have 500 mm electrical straight topping with 100 mm wire strands spacing.</li> </ul>

DOCUMENT NO.	SUB DIRECTORY	ISSUE DATE	PAGE
			Page 1 of 3

	<p><b>Question</b> Who will be responsible to integrate the alarm monitoring system into the current system?</p> <p><b>Answer</b> The contractor is responsible in ensuring that system is integrated and in working order. <b>(Refer to scope 2.4.1.4)</b></p> <p><b>Question</b> There is two (2) layers of fence, will both be removed.</p> <p><b>Answer</b> Only the vibacrete (precast) fence is to be removed.</p> <p><b>Note:</b> The contractor is responsible to double check the length of the fence stated as 710m.  Updated scope of work on <b>items 2.4.1.2 and 2.4.1.3.</b></p>
3.	<p><b>General</b></p> <ul style="list-style-type: none"> <li>• The full tender documentation is accessible on the e-procurement portal. Tenderers will be required to log in using their CSD MAAA....number.</li> <li>• Tenderers to submit the tender in time to enable us to assist you should you require assistance.</li> <li>• Tenderers to comply with all instruction on Tender Document in order to make the evaluation process easier.</li> <li>• All companies that do business with PetroSA must be registered on the National Treasury’s Database.</li> <li>• Tenderer must pay attention to detail as failure to provide any of the information requested in the technical questionnaire will result in the tender not scoring points for that question.</li> <li>• Tenderers to check the PetroSA website regularly for updates regarding the Tender, i.e. minutes, etc.</li> <li>• For all updates / additional information go to: <a href="http://www.procurement.petrosa.com/tenders/tenders/default.aspx">http://www.procurement.petrosa.com/tenders/tenders/default.aspx</a> It is the tenderer’s responsibility to visit the site on a regular basis.</li> <li>• <b>The tender closing date has been amended to be 12 May 2026, 12:00am.</b></li> </ul>
4.	<p><b>Closure</b> A walkabout was done by bidders with safety officer and thereafter a meeting was conducted. Meeting closed</p>

DOCUMENT NO.	SUB DIRECTORY	ISSUE DATE	PAGE
			Page 2 of 3

## Annexure "A"

### Supplementary Scope of Work

Below is a supplement and clarification to current scope of work:

- **Updated Scope of Work.**
- **Bill of Quantities.**

DOCUMENT NO.	SUB DIRECTORY	ISSUE DATE	PAGE
			Page 3 of 3