


Type. D Crealco Swift 38 or eq. approved fixed aluminium casement window, per layout. Casement sash 1500 x 1200mm max capacity
 Fixing lugs suitable for fixing to plastered brickwork reveals.
Exposure AAAMSA exposure category: A1. SANS613 - 1000Pa wind load capacity
Coating: Class 2 powder coated to SANS 10322:2014; Coatings in accordance with SANS 1796 using powders in accordance with SANS 1578.
colour: TBC. Provisionally Mat Black
Furniture Nil
Glazing Glazing throughout to be 6,38mm thick normal strength PVB laminated Low E safety glass
 SHGC Req. 0.57 per PG Glass E-Range Solarvue Neutral SHG (or equal approved)
 U-Value Req. 5.8 W/m².K (system) Glazing - 3.7 W/m².K
Mesh security screen: Nil
 Blinds / Curtains: Nil

QUANTITY:	2 x No Blinds+Mesh
2	WG10 WG11

NOTES:	REVISIONS			
	Rev.	Date	Description	By
	A	2024.08.06	Window & description updated.	PD
1. ALL DIMENSIONS TO BE CHECKED ON SITE PRIOR TO MANUFACTURE. 2. WINDOWS DRAWN AS VIEW FROM EXTERIOR.				

PROJECT: PORT SHEPSTONE HOSPITAL NEW PSYCHIATRIC WARD	Architect: ARTEK 4 ARCHITECTS (KZN) CC Durban: 46 Lena Ahrens Road, Glenwood, Durban 4000 tel: 031 201 0445 fax: 031 201 6609 email: admin@artek4.co.za Port Shepstone: 19 Tradewinds, Marine Drive, Shelly Beach tel: 039 682 2447 fax: 039 682 2446 email: admin@artek4.co.za	
DRAWING DESCRIPTION: WINDOW SCHEDULE WINDOW TYPE D		

Scale	Date	Drawn	Project No.	Drawing No.	Rev.
1:25	14.11.2022	WP	1518	401-4	A