



DETAIL OF WATER METER AND MANHOLE CHAMBER

NOTES:

1. ALL BOLTS, NUTS AND WASHERS TO BE GALVANISED.
2. ALL FLANGES TO BE ACCORDING TO SABS 1123-1977 (1600/3) (TABLE D)
3. ALL VALVES ACCORDING TO SABS 664 CLASS 16
4. PADDLE FLANGES 20mm THICK
5. CONCRETE CLASS 25/19
6. MIN COVER FOR REINFORCING = 40mm
7. STEEL PIPE GRADE B AND 4,5mm WALL THICKNESS.
8. TOP CONCRETE EDGES OF WALLS MUST BE CHAMFERED 20x20mm
9. AIR VENTS IN WALL MUST BE ABOVE GROUND LEVEL AND COVERED BY STEEL GUASE ON INSIDE OF CHAMBER.
10. ECCENTRIC REDUCERS AND FLANGE ADAPTORS ARE NOT INCLUDED IN THIS ITEM BUT MEASURED ELSEWHERE

TABLE FOR DIMENSIONS THAT VARY		
DIMENSION	WATER METER SIZE (mm)	
	250 mm	100mm
A	350	350
B	350	350
C	250	250
D	150	150
E	200	200



Notes/Notas

[illegible]

PO BOX 15110
NELSPRUIT
1200
TEL NO: 013 752 7475
EMAIL: info@tfce.co.za

Designed Ontwerp		Traced Nagetrek	
Drawn Geteek		Checked Nagesien	

		Pr.Eng. Pr.Ing.	
Consulting Eng./Raadgewende Ing.			Date/Datum

Client/Klient	Date/Datum
---------------	------------

Client/Klient



Project/Projek

ADDITIONAL 3,5 Mℓ
RESERVOIR
FOR HAZYVIEW

Plan Description/Planbeskrivning

WATER METER MANHOLE DETAIL

Scale/Skaal	Date/Datum July 2022
-------------	-------------------------

Plan No.

NS 3293/04