

TENSION PER CONDUCTOR IN kN	
400kV STRINGER (3 CONDUCTOR PER PHASE)	18kN
132kV STRINGER (2 CONDUCTOR PER PHASE)	9kN
EARTHWIRE	2kN

BUSBAR CONDUCTOR SIZE	
400kV TUBULAR	ϕ250mm x 6mm WT
132kV TUBULAR	ϕ200mm x 6mm WT

NOTES:
1. FEK INDICATES FIRE EQUIPMENT KIOSK. FOR MORE DETAILS ON THE FEK SEE DRG 0.54/390 SH56.
2. ◈ INDICATES 24m HIGH FLOODLIGHTING MAST.
3. ALL TERMINAL TOWER POSITIONS ARE PRELIMINARY. FOR TERMINAL TOWER SEPARATIONS SEE 0.54/4201.
4. FOR MORE DETAILS ON THE ENTRANCE GATES SEE DRG 0.54/7470.

DETAILED DESIGN
NOT FOR CONSTRUCTION

ORIGINAL DWG #: 0.12/7794 REV 2
CONCEPT DWG #: N/A

REV	REVISION DESCRIPTION	DRAWN	CHKD	AUTH	DATE	SOLP19P03- REF DRAWINGS
P	400kV YARD BUSBAR SUPPORTS SHIFTED TO ACCOMODATE 3No SPACING & SPACER DAMPER LOCATIONS. 132kV BUSBAR SUPPORT COLUMNS SHIFTED TO ALIGN TO FUTURE BAYWIDTH.				13/7/2022	
1	6m GATE ADDED.	RBA	SC	MP	18/11/2021	
0	400kV YARD BUSBAR SUPPORTS SHIFTED TO ACCOMODATE 3No SPACING & SPACER DAMPER LOCATIONS. 132kV BUSBAR EXTENDED TO ALIGN WITH 400kV BUSBAR SUPPORTS. 132kV FEEDER 4 BUSBAR STUBBIES ADDED. FLOOD MASTS.	RBA	SC	MP	29/04/2020	SC-013 STEELWORK SC-09 FOUND./TRENCH SC-06 STATION ELECTRIC

APPROVED BY		Eskom	Eskom Holdings SOC Ltd Reg No 2002/015521/30
M PEFFER			
DATE: 29/04/2020			
CHECKED BY		UPINGTON MTS	
S CHELLAN		KEY PLAN	
DATE: 29/04/2020			
DRAWN BY			
M VENTER / E RAMPLUPH	©		
DATE: 29/04/2020		SOLP19P03-SE-D7	SHEET NUMBER: - REVISION: 2
SCALE 1:750			SIZE: ANSI-B AOL