



Terms of Reference:

Servicing UPS and fire suppression systems for ARC-Natural Resource and Engineering (NRE) network room at Glen

The ARC requests service providers to provide a quote for the servicing of the UPS and fire suppression systems for the ARC-Natural Resource and Engineering (NRE) network room at Glen

Location:

ARC-Natural Resource and Engineering (NRE): Glen

Glen Agricultural College

Verbeeck Building

Gielie Joubert Street

Glen

9360

Specifications:

UPS system:

1. Technicians responsible for servicing the UPS system must be qualified on Tescom Micro Matla Range products
2. Two (2) 6KVA units must be serviced



Fire suppression and control system:

Please note:

Fire suppression system is currently inactive as canisters discharged.

1. Technicians responsible for servicing the fire suppression system must be qualified on HFC-227ea low pressure systems
2. Empty canisters must be replaced



3. Smoke and moist detectors must be serviced

4. TEC247 Techno Switch fire detection system must be serviced



Please note:

- Service date and time must be scheduled in advance (at least **three** days before actual service date)
- Downtime should be avoided as far as possible or minimized to minimum service time required