

## CONTENTS

1. INTRODUCTION.....	3
2. SUPPORTING CLAUSES .....	3
2 1 SCOPE	3
2 1 1 Purpose	3
2 1 2 Applicability	3
2 2 NORMATIVE/INFORMATIVE REFERENCES	4
2 2 1 Normative	4
2 2 2 Informative	4
2 3 DEFINITIONS	5
2 3 1 Classification	5
2 4 ABBREVIATIONS	5
2 5 ROLES AND RESPONSIBILITIES	5
2 5 1 Auxiliary Engineering	5
2 6 PROCESS FOR MONITORING	5
2 7 RELATED/SUPPORTING DOCUMENTS	5
3. TUTUKA FLUE STACK STRUCTURAL INSPECTIONS WORKS INFORMATION.....	5
3 1 OVERVIEW	5
3 2 DESCRIPTION OF THE SERVICES	7
PHASE C Development of Contract Documentation	8
PHASE D Technical Supervision	9
3 3 DELIVERABLES	9
3 4 EXISTING INFORMATION	10
3 5 OPERATING PHILOSOPHY	13
3 6 SCOPE OF WORK FOR THE FLUE STACK INSPECTIONS	13
3 6 1 Scope overview	13
3 6 2 Obligation	15
3 8 WORK DONE	15
3 9 EQUIPMENT	16
3 10 DOCUMENTS INCLUDED IN THE WORKS INFORMATION	16
3 11 QUALITY MANAGEMENT	16
3 11 1 Data Books	17
3 12 DOCUMENTATION MANAGEMENT AND CONFIGURATION MANAGEMENT	17
3 12 1 Document Management	17
3 12 1 1 Document Identification	17
3 12 1 2 Drawings Format and Layout	18
3 12 1 3 Document Submission	18
3 12 2 Engineering Change Management	18
3 12 3 As-Built Plant Drawings	18
3 12 4 Plant Coding	18
3 12 5 Procedures, Guidelines & Other Documents	19
3 13 OTHER PROJECT DELIVERABLES	19
3 13 1 Project planning	19
3 13 2 Deviations, Exclusions and qualifications	19
3 13 3 References	19
4. AUTHORIZATION .....	19
5. REVISIONS.....	20
6. DEVELOPMENT TEAM .....	20
7. ACKNOWLEDGEMENTS .....	20

### CONTROLLED DISCLOSURE

When downloaded from the EDS database this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database

## 1. INTRODUCTION

The successful tenderer will be expected to carry out the following activities on both chimneys

- Perform visual inspections with a camera on 250m high concrete windshield and flues. Areas to be inspected are access restricted,
- Take concrete samples and analyse for strength and degradation. Care must be taken to not damage reinforcing,
  - Sample test certificates to be supplied (sampling and testing to be in accordance with the relevant SANS standards)
- Repair sampled areas as per the approved methodology,
- Perform non-destructive testing and assess life expectancy of structures,
- Measure expansion gaps,
- Compile report detailing scope of work for remedial actions (including method of repair), next inspection and life expectancy as per [6],
- Prepare scope of work including bill of quantities and cost estimates for repair work,
- Technical supervision during repairs,
- *Contractor* to supply as built drawings of the windshields and chimneys only (stair cases, elevators etc not required),
  - These drawings will be overlaid with a grid system to identify location of defects
  - The *Contractor* will transfer and assign copyright to the employer allowing the employer to reproduce and distribute the drawings as they so wish.
  - The owner of the copyright must be displayed on the drawing (s)
- The *Contractor* is responsible for providing specialist access for external and internal inspections
- The *Contractor* shall make provision for secondment of two Tutuka Civil Engineers to the designer's offices to complete designs as part of their professional development and skills transfer.
- In the repair scope the *Contractor* must provide the paint spec for the top of the smoke stacks.

The Contractor shall take note that the internal inspection of the flue ducts will only be performed during the Unit outage, The Employer will forward the schedule of Unit outages where access will be granted.

## 2. SUPPORTING CLAUSES

### 2.1 SCOPE

The scope of the works includes the destructive and non-destructive testing and inspections of the Tutuka flue stacks. The inspections must be followed up with a detailed report including recommendations for the works that needs to be performed to ensure the structural integrity of the Flue Stacks, maintenance strategy, relevant drawings and Bill of Quantities.

#### 2.1.1 Purpose

The purpose of the document is to provide requirements for scope of work to perform structural inspections on the Tutuka Flue stacks.

#### 2.1.2 Applicability

This document will apply to Tutuka Power station.

### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database

## 2.2 NORMATIVE/INFORMATIVE REFERENCES

The applicable reference documents are listed below. These documents (latest revision) form part of this specification to the extent as specified in this specification. In the event of a conflict between the text of this specification and the applicable parts of the Eskom documents listed below, the text of this specification takes precedence. However, this specification does not supersede applicable laws and regulations (including the SANS standards), unless a specific exemption has been obtained from the relevant authorities.

### 2.2.1 Normative

- |      |                                  |   |
|------|----------------------------------|---|
| [1]  | ISO 9001 2008                    | Quality Management Systems  |
| [2]  | 240-50317699                     | Manage Technical Queries Procedure  |
| [3]  | 240-53113685                     | Design Review Procedure   |
| [4]  | 240-53114186                     | Document and Records Management   |
| [5]  | 240-53665024                     | Engineering Quality Manual  |
| [6]  | 240-99527377                     | Inspection Manual for Civil Works at Eskom's Power Stations   |
| [7]  | QM-58                            | Supplier Contract Quality Requirements Specification  |
| [8]  | 15ENG GEN-699                    | Tender Technical Evaluation for Tutuka Flue Stack Structural Inspections  |
| [9]  | SANS 5865                        | Concrete tests – <i>The drilling, preparation, and testing for compressive strength of cores taken from hardened concrete</i> |
| [10] | SANS 5863                        | Concrete tests – Compressive strength of hardened concrete  |
| [11] | 240-86973501                     | Engineering drawing Standard  |
| [12] | 240-76992014<br>Work Instruction | Project / Plant Specific Technical Documents and Records Management   |
| [13] | 240-66920003<br>Projects         | Documentation Management Review and Handover Procedure for Gx Coal  |
| [14] | 240-65459834                     | Project Documentation Deliverable Requirement Specification   |
| [15] | 240-54179170                     | Technical Documentation Classification and Designation Standard   |
| [16] | 240-53114002                     | Engineering Change Management (ECM) Procedure   |
| [17] | 240-53113685                     | <i>Design Review Procedure</i>  |
| [18] | 15ENG MN-676                     | Tutuka AKZ Coding Procedure   |

### 2.2.2 Informative

- |      |              |   |
|------|--------------|---|
| [19] | 240-99527377 | Inspection Manual for Civil Works at Eskom's Power Stations   |
| [20] | SANS 1200    | Standardised specification for civil engineering construction |
| [21] | 240-56364545 | Structural design and engineering standard                    |
| [22] | 39-60        | Contract quality requirements                                 |

## CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

## 2.3 DEFINITIONS

### 2.3.1 Classification

- a **Controlled disclosure:** controlled disclosure to external parties (either enforced by law, or discretionary)

## 2.4 ABBREVIATIONS

Abbreviation	Description
AKZ	Plant labelling code
DT	Destructive Testing
ISO	International Standards Organisation
NDT	Non-destructive Testing
NOx	Nitrogen Oxides
QCP	Quality Control Plan
SANS	South African National Standards
SOx	Sulphur Oxides

## 2.5 ROLES AND RESPONSIBILITIES

### 2.5.1 Auxiliary Engineering

- a Initiator of project

## 2.6 PROCESS FOR MONITORING

Design reviews will be conducted to verify the contents of this document

## 2.7 RELATED/SUPPORTING DOCUMENTS

N/A

## 3. TUTUKA FLUE STACK STRUCTURAL INSPECTIONS WORKS INFORMATION

### 3.1 OVERVIEW

The *Consultant* shall appoint an experienced professional civil engineer or civil technologist (ECSA Pr Eng / Pr Tech registered) specialising in reinforced concrete structures to perform detailed inspections,

#### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database

investigations and full structural assessment and design works where necessary, development of contract documentation inclusive for repair and maintenance methodologies, for the two windshield chimney structures and six flue ducts at Tutuka Power Station all in order to ensure the safe use of the windshield chimneys and flue ducts. All inspections and investigations shall be performed in accordance with 240-99527377, *Inspection Manual for Civil Works at Eskom's Power Stations* for chimneys.

The chimney and flue ducts structural elements in its entirety shall be inspected in detail and subjected to full detailed structural assessments. Structural elements include of the chimney and flue ducts include but are not limited to -

- Concrete windshield internal and external,
- Brick flues or lining internal and external,
- Concrete support slabs,
- Bearing pads,
- Lightning protection and other fixtures at the chimney top,
- Waterproofing at the top slab,
- Chimney lift structure,
- Steel staircase,
- Thermal insulation,
- Flue insulation,
- Condition and visibility of windshield paint.

The *Consultant* shall provide all temporary works, access, plant, materials, equipment and tools required to perform all inspections and investigations necessary. The *Consultant* shall inform the Employer in advance of all access limitations and obstructions preventing execution of the services. The Employer is aware that access to inspect the flue ducts and brick lining is limited and will only be provided during outage of specific Unit.

All civil and structural work is carried out by a professional engineer or technologist, registered with the Engineering Council of South Africa (ECSA) The *Consultant* shall provide a method statement to the *Employer* for review and acceptance prior to the commencement of any works by the *Consultant*. The method statement includes the following as a minimum -

- a) The detailed investigation approach, methodology and sequencing of works including a description of all investigative works necessary, all types of testing required, and all tools, equipment, materials, temporary works necessary to perform the works;
- b) Detailed description of any speculated structural assessments, analyses and design deemed necessary which is to be confirmed as required following completion of point (a) above.

The *Employer* had appointed a *Consultant* in 2010 to perform a visual inspection of the chimneys: *Coal Fleet Critical Structures Investigations and Monitoring Programme at Tutuka Power Station Cooling Towers*, and *Tutuka Power Station, Cooling Towers Deformation Report*. The results of the previous surveys and inspections are included in this *Contract* to be used as a basis and comparison with the surveys and other associated tasks to be executed as part of this *Contract*

The *Consultant* takes note that the *Employer* also performed a conditional visual inspection in May 2019, and has identified several defects at the chimneys.. These were consolidated into a report together with photographic evidence and which forms the starting point of the *Consultant's services*: 360-TUT-ADDB-D00180-8, *Tutuka Power Station, Structures and Buildings Visual Inspection Report*.

The Technical Specification. 360-TUT-AABB-D00139-83, *Tutuka Power Station, Technical Specification for Remedial Works on Existing Infrastructure*, also developed by the *Employer* for the remedying of certain identified defects is also utilised by the *Consultant* as a starting point in developing the Works Information for repair works (See PHASE C)

#### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database

The reports provided by the Employer serve only as a guide to the Consultant and are provided for information purposes to assist the *Consultant in execution of the services*

The creation, issuing and control of all drawings is in accordance with 240-86973501, Engineering Drawing Standard – Common Requirements

Drawings issued to the Employer will be a minimum of 2 hard copies signed by the responsible professional registered structural engineer or technologist and in electronic format. The *Consultant* submits electronic drawings that can be opened with or compatible to Micro Station (DGN) format, and scanned drawings in pdf format. Drawings issued to Employer may not be “Right Protected” or encrypted

The *Consultant* takes note that review and acceptance of any document or drawing by the *Employer* in no way relieves the *Consultant* of his liability for the works. He remains liable for all works conducted as per this Contract

The *Employer* owns the *Consultant's* right over material prepared for this Contract by the *Consultant*. The *Consultant* shall submit their assignments, drawings and or reports and, if applicable, interim assignments or progress reports, in accordance with the dates specified in the Contract

All original documents furnished/supplied by *Consultant* to the *Employer* and all documents, plans, computer programmes and other data prepared by the *Consultant* in connection with this Contract shall be lodged with the *Employer* and shall become the property of Eskom

The copyright and Intellectual Property in all documents prepared by the *Consultant* in terms of this Agreement and the Letters of Appointment shall be vested in Eskom, which shall have the right to adapt them for other projects or otherwise apply or dispose of at its sole discretion

The *Consultant* provides documents which transfer these rights to the *Employer*. The *Employer* has the right to reuse that information without copyright limitations or without requiring authorisation from the *Consultant* for the reuse thereof

### 3.2 DESCRIPTION OF THE SERVICES

#### Phase A: Detailed Visual Inspections and Assessments

The detailed visual inspections of the chimneys must be done during the outage of the flue duct or arranged and agreed with *Employer* and includes the following key focus inspection points, as a minimum -

- a) Inspect for major geometrical imperfections of the windshell and flue ducts,
- b) Inspect for signs of cracks in the windshell,
- c) Inspect for water seeping through the windshell,
- d) Inspect for any signs of localised windshell spalling,
- e) Inspect the annular foundations at windshell for visible signs of differential settlement,
- f) Inspect the nature and extent of chemical attack on the brick material and on the mortar,
- g) Inspect the condition of the chimney lift support structure,
- h) Inspect for cracks in the connections of bracing components; and
- i) Inspect safety of walkways, handrails, cat ladder etc

During the detailed inspections and investigations, the *Consultant* is expected to perform the necessary tests on the concrete elements in order to ensure the safe use of the cooling towers. The assessments and test will include but not limited to

#### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database

- a) Readings of surface hardness (Schmidt hammer),
- b) Depth of carbonation, tested at critical / key points,
- c) Concrete strength by taking core samples,
- d) Concrete cover, tested at critical/ key points,
- e) Potential half-cell method for corrosion testing,
- f) Sulphate/ Chloride/Nitrate attack,
- g) Environmental factors, as detailed below,
  - Analysis of concrete, brick and mortar samples (chemical analysis),
- h) Windshield and flue ducts Life expectancy under normal and abnormal conditions, and
- i) 3D laser scan survey and model to measure the deformations and possible settlement and loading patterns of the as-built windshell structures and report on the deformations found  
Excessive deformations will be highlighted for further investigation

The *Consultant* shall inspect for signs of structural distress and / or indication of deterioration  
Photographic records shall be compiled to assist and document the inspections and investigations  
Observations shall be referenced to the photographs

The *Contractor* shall make provision for secondment of two Tutuka Civil Engineers to the designer's offices to complete designs as part of their professional development and skills transfer

#### **PHASE B: Design Works**

Structural assessment and design works comprises of the following

- a) Life expectancy of the windshield and flue ducts under abnormal conditions

The Consultant performs a design analysis which includes calculation of loading and the applicable design checks to ensure the safety and structural integrity of the windshield and flue ducts and in order to determine the residual life of the chimney The structural analyses includes, at minimum -

- Linear-elastic analysis,
- Failure analysis for cracked structures using finite element analysis technique.

Structural assessment analyses and designs (where required) for repair of the defects identified based on the root cause, in order to prevent recurrence of the defects All designs are carried out in accordance with the Employer's design standard 240-56364545, *Structural Design and Engineering Standard* and 240-144332407, *Guideline for Eskom Power Stations Concrete Remedial Work*

The *Contractor* shall make provision for secondment of two Tutuka Civil Engineers to the designer's offices to complete designs as part of their professional development and skills transfer

#### **PHASE C: Development of Contract Documentation**

Development of a comprehensive Works Information compiled in accordance with the NEC 3 form of contract for the repair works to be constructed by a *Contractor*, including all supporting documentation i.e reports, construction drawings, bill of quantities, technical specifications and procedures The SANS 2001 series of standardised specifications are used with necessary amendments The Works Information is submitted to the *Employer* for review and acceptance The construction of all repair work will be done by others in accordance with the accepted Works Information

The *Contractor* will compile a detailed bill of quantities with price estimates

#### **CONTROLLED DISCLOSURE**

When downloaded from the EDS database this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database

#### PHASE D: Technical Supervision

The technical supervision (As pre construction regulations) should be priced separately and not form part of scope of work in this *Contract*, as the execution of such works is dependent on when the *Employer* appoint others to conduct the repair works

Technical supervision of the *works* which includes the following tasks as a minimum

- a) Compiling a tender cost comparison for the repair works,
- b) Attending negotiations between the potential repair tenderer and Eskom to negotiate on Eskom's behalf,
- c) Technical quality assurance during execution to ensure that such is executed as per the approved scope of work, technical specifications and procedures,
- d) Reviewing, witnessing and approving (by signature) intervention points captured in the *Contractor's* Quality Control Plan, where applicable to Engineering,
- e) Raising Notice of Defects/ Non Conformance Reports, where work performed by the *Contractor* is not in compliance with the approved scope of work, technical specifications and procedures,
- f) Review and acceptance by signature of *Contractor's* method statements, rigging studies (where applicable) construction data books and other related documents developed by the *Contractor*,
- g) Review of *Contractor's* design calculations where rigging is from existing infrastructure,
- h) Responding to technical queries and clarifications from the *Contractor*,

#### PHASE E: Civil Maintenance Philosophy for Cooling Towers

The *Consultant* shall review and where necessary provide comments chimney's civil maintenance and inspection strategy that is developed by the *Employer*

### 3.3 DELIVERABLES

The *Consultant* provides the following at each of the phases, where applicable

- a) **PHASE A** - The *Consultant* must produce a detailed report indicating all findings with photographic evidence from the investigative works, for review and acceptance by the *Employer*. The report also indicates all necessary structural assessments and design works to be conducted in PHASE B. The report is signed by a professional engineer or technologist registered with ECSA and includes the following as a minimum:
  - The detailed investigation approach,
  - Results of visual inspections,
  - Description of all testing conducted, raw data and test results,
  - Survey data,
  - Measurements and photos taken,
  - Drawings / sketches etc,
  - A detailed description of all structural assessments, analyses and designs deemed necessary together with design criteria and design philosophy to be followed,
  - Skills transfer

#### CONTROLLED DISCLOSURE

- b) **PHASE B** – The report produced in PHASE A is revised to include the results from all structural assessments, analyses and design, for review and acceptance by the *Employer*. The report is signed by a professional engineer or technologist registered with ECSA and includes the following as a minimum
- Structural analysis models including inputs and outputs,
  - Detailed design calculations,
  - All assumptions made,
  - Summary of findings and recommendations/ remedial work required,
- c) **PHASE C** - Upon acceptance of the detailed report by the *Employer*, the *Consultant* submits a comprehensive Works Information for all repair works, compiled in accordance with the NEC3 form of contract complete with all supporting documentation i.e. reports, technical specifications, construction drawings, procedures and bill of quantities. The SANS 2001 series of standardised specifications are used with necessary amendments. The Works Information is submitted to the *Employer* for review and acceptance.
- d) **PHASE D** – The *Consultant* to submit the estimated price to perform the quality control and assurance during the execution of the works. The quotation or estimated price separately and it shall not form the part of scope of work in this *Contract*, as the execution of such works is dependent on when the *Employer* appoints the *Contractor* to conduct the repair works.
- e) **PHASE E** – The *Consultant* to reviews and approve the civil maintenance philosophy for the cooling towers developed by the *Employer*.

### 3.4 EXISTING INFORMATION


Tutuka Power Station is located within the Gert Sibande District, in the Lekwa Municipality, approximately 21 km northeast of the town Standerton in the Mpumalanga Province. Tutuka's first unit was put in commercial on 1 June 1985 and the last unit on 4 June 1990. Tutuka Power Station is an important link in the 765kV extra-high-voltage transmission system linking Mpumalanga with the Western Cape and KwaZulu-Natal. The technical details are as follows -

- Six 609MW units,
- Installed capacity of 3654MW

Tutuka Power Station is equipped with multiple flue chimney consisting of two reinforced concrete windshield structure housing three brick flues each.

Figure 1 below shows the positioning of chimneys at Tutuka Power Station

### CONTROLLED DISCLOSURE



**Figure 1: Layout of Tutuka Power Station**

In chimney structures, there are essentially two different building materials combined. The structure consists of the windshield which is the reinforced concrete structure and flue duct which comprises brickwork. These two materials are in turn subjected to different exposure conditions, thus different forms of behaviour and ageing are to be expected. The normal operating temperature of chimneys at Tutuka Power Station is 138°C. Under fault conditions, the temperature may lower to 120°C and this actually occurs very suddenly. Because of these flue gas temperature variations, uneven heating and large temperature gradients may result in the cracking of the brick lining disintegrating, particularly where the lining is not insulated.

The brick flues have a typical internal diameter of about 8m and a wall thickness of about 100mm above the bottom cone section. The wall thickness in the 2m high cone section may vary between 150mm and 285mm. A mineral wool layer typically provides thermal insulation to the brickwork. Table 3-1 below illustrates the dimension of the chimneys -

**Table 3-1: Chimney Dimension Information**

Power Station	No	Height (m)	Inside Diameter (at base) (m)	Inside Diameter (at top) (m)	Typical wall thickness (mm)
Tutuka	2	275	23.87	18.05	700 at base

**CONTROLLED DISCLOSURE**

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

					400 at top
--	--	--	--	--	------------

Access to the top of a chimney is provided by means of a cat ladder attached to a concrete shell

Many of Eskom's chimney shells were cast in rings by means of a climbing formwork system in 1 20m high sections. The shell has a cylindrical shape at the base and rests on a ring-shaped foundation. The annular ring beam is founded either on piles or on a mass concrete foundation.

In most instances the brickwork lining was constructed in free-standing cylindrical lifts. These lining lifts are supported directly on concrete corbels in the shell. Where the quality of the brick is not specified on drawings, it is assumed that high quality clinker bricks laid on blast furnace cement mortar were used. The minimum space between the lining and the shell typically varies between 60mm and 115mm. The ventilation of this air space is provided by means of radially-placed asbestos cement pipes, through the concrete shell just below each corbel, at identical intervals.

Cast iron capping rings are provided at the top of the chimneys. The chimneys are also equipped with lightning protection.

Typically the brick flues of a multiple flue chimney are supported on concrete platforms. The platforms consist of a reinforced concrete slabs and reinforced concrete beams, supported on elastomeric bearing pads onto reinforced concrete corbels and onto the windshield. The elements of a multiple flue chimney are

- **Concrete windshield**

The top 40m of the chimney is treated with acid resistant paint. Rainwater falling onto the top support slab drains off through a series of weep holes in the windshield.

- **Brick flues**

Three are situated within each of the windshields.

- **Concrete support slabs**

The reinforced concrete slabs support the individual brick flues.

- **Bearing pads**

The bearing pads between the concrete corbels and the support slabs.

- **Lightning protection and other fixtures at the chimney top**

- **Waterproofing at the top slab**

Typically waterproofing consists of acid resistance ceramic tiles on top of a mortar screed. The tiles have an adequate slope to drain rainwater away. The jointing material is also acid resistant.

- **Chimney lift**

The steel gantry tower is braced back to the inner face of the windshield at regular intervals.

- **Brick Lining**

The brick lining should be inspected for integrity with special focus on structural stability. The nature and extent of any chemical attack on the brick material and mortar.

- **Steel staircase**

The stairs provides access. The steel structure is supported by columns which are founded on plinths at ground level and is anchored to the inner face of the windshield at regular intervals.

- **Thermal insulation**

Mineral wool is used as thermal insulation.

#### CONTROLLED DISCLOSURE

### 3.5 OPERATING PHILOSOPHY

The chimneys are always operated when the unit is on load. The primary function of the chimneys is to remove flue gases containing ash, SO<sub>x</sub> and NO<sub>x</sub> to atmosphere.

Due to the operational philosophy of the Power Station, the flue ducts will not be able to be inspected when the unit is on load. An arrangement will be made with the Consultant to come when and as required to perform the detailed inspections, tests and surveys which will most likely be during the outage of respective unit.

The Consultant's report will be subjected to review and acceptance by Employer's Chief Structural Engineer from the CoE Department of Structural Design or any other Consulting Engineering specialist that may be appointed by the *Employer*.

### 3.6 SCOPE OF WORK FOR THE FLUE STACK INSPECTIONS

#### 3.6.1 Scope overview

- Contractor to perform detailed assessment and visual inspection;
- Identify and quantify defects such as spalled areas etc,
- Identify and quantify area of structural distress where cracks are larger than 0.4mm and observed large deflection,
- Determine depth of carbonation for all structural surfaces exposed to the weather (Phenolphthalein test)
- Determine the life of passivating layer,
- Produce a report with a photographic record and repair methodologies that must be implemented,
- A quality control plan must be supplied by the *Contractor* for review by the *Employer*,
- Perform visual inspections assessing for signs of structural distress and degradation on each chimney (internal and external) and windshield,
- Concrete cores will be taken from each windshield over the height of the windshield. A reinforcement detector will be used to determine the position of the reinforcement in order to prevent coring through reinforcement. These cores will be chemically tested in an accredited laboratory to assess the sulphur content, carbonation and chloride content in the concrete due to the down-wash of the flue gases. The areas where cores were removed must be repaired by the *Contractor*. Sampling will be in accordance with [9]. Method to be detailed in the method statement.
- Structural measurements and non-destructive testing will be performed on the concrete structure (windshields, slabs etc) to assess the life expectancy of the structures. Necessary remedial actions will then be recommended to ensure the integrity of the structures over the remaining life of the Power Station (2050). This will consist of measurements and tests such as concrete surface hardness, depth of concrete cover to reinforcement, sulphur and chlorides content, and carbonation depths. Testing will be in accordance with the relevant SANS standard [10]. Method to be detailed in the method statement.
- An electromagnetic cover-meter will be used to determine the concrete cover depths to the reinforcement.

#### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

- Concrete surface hardness and compressive strength will be tested by using a Schmidt impact hammer.
- An important parameter indicating the potential for corrosion and consequent deterioration of reinforced concrete is the depth of carbonation. The depth of carbonation will be measured on the concrete structures at various locations using the phenolphthalein indicator test.
- An internal inspection of the brick flues with the assistance of a specialist contractor, which will provide the platform or cage and winches. This specialist contractor must be provided by the *Contractor*.
- Measurement of flue expansion gaps to assess whether remaining gaps are greater than 30mm.
- The windshield on the outer face will be inspected by means of a theodolite or similar equipment to determine and graphically plot any defects visible such as cracks, honeycombing, degradation, etc.
- Inspect the acid resistant protective cover at the top 25m of the windshield for any degradation (provide paint specification).
- Compile a structural assessment report based on the non-destructive test results and inspection that includes images, remedial actions/recommendations (including method of repair), maintenance strategy, bill of quantities with price estimates, life expectancy. The report must be as per [6].
- The *Contractor* must compile a scope of work for repair (NEC). The *Contractor* will remain responsible for ensuring the scope is executed as per design/specification.
- Compile cost comparison report for repair tenders.
- Negotiate prices on behalf of Eskom with potential repair *Contractors*.
- *Contractor* to supply as built drawings:
  - These drawings will be overlaid with a grid system to identify location of defects.
  - The *Contractor* will transfer and assign copyright to the employer allowing the employer to reproduce and distribute the drawings as they so wish.
  - The owner of the copyright must be displayed on the drawing (s).

**The following elements in the chimneys will be inspected and assessed:**

- Windshield-internal and external (including paint condition and visibility),
- Brickflues-Internal and gaps,
- Steel inlet duct into the chimney
- Ash build up inside the chimney,
- Intermediate support slab-spaced approximately 25m apart,
- Steel stairway,
- Insulation to the brickflues,
- Lift structure and connections,
- Lightning Conductor,
- Flue insulation,
- Acid resistant protective cover on the top 25m of the windshield.

**CONTROLLED DISCLOSURE**

### 3.6.2 Obligation

The *Contractor* is responsible for ensuring the inspection and subsequent report is a true reflection of the status of the structure. The *Contractor* is responsible for supplying a detailed repair strategy including bill of quantities for any remedial actions that are required to ensure structural integrity is maintained. The *Contractor* will remain responsible for ensuring the repair scope is executed as per design/specification.

## 3.7 QUALITY AND INSPECTION REQUIREMENTS

### 3.7.1 Quality Assurance

- 1 The *Contractor* complies with the quality requirements as stipulated [22]
- 2 The *Employer* reserves the right to evaluate the *Contractor's* and its subcontractors' Quality Management System documentation. The *Employer* or its representatives also reserve the right to carry out appraisals and quality audits of the *Contractor's* and its subcontractors' Quality Management Systems, at any time before and during the period of the contract, to verify compliance with and maintenance of the quality system and contract requirements.
- 3 The *Contractor* and its subcontractors must have a Quality Management System that complies with the applicable requirements of [1]
- 4 The requirements of the Code of Practice for Quality Management System [1] as applicable to this scope of work are included as requirements of this specification.
- 5 The *Contractor* will be responsible for the complete quality assurance requirements to be imposed on his sub-contractors and suppliers of materials, in terms of [1] and [7]
- 6 The *Contractor* will comply in full with the above *Employer's* quality assurance requirements and any amendments thereto which the *Employer* considers necessary or expedient during the contract.

### 3.7.2 Quality Control and Inspection

- 1 The *Contractor* will exercise strict and adequate quality control during all phases of the work.
- 2 The *Contractor* will prepare suitable quality control plans (QCP's) and Inspection and Test Plans (ITP's) for all work carried out.
- 3 The *Employer*, the Inspection Authority, the *Employer* QC Representative and the *Contractor* must review these QCP's/ITP's jointly and the actual scope of quality control and inspection required for the Contract agreed upon.
- 4 The QCP's/ITP's must be subject to the *Employer's* approval and must indicate all inspection and test points, the methods and procedures to be used and the acceptance criteria to be applied.
- 5 The *Contractor* is required to notify the *Employer* 24 hours in advance of witness and hold intervention points.

## 3.8 WORK DONE

The *Contractor* is responsible for executing the required work in accordance with this tender specification and must remain responsible for any discrepancies, errors or omissions of any sort on the submitted data, program, layouts or shop drawings, whether it has been approved or not approved.

### CONTROLLED DISCLOSURE

Deviations from the work will not be accepted. When the standards of the equipment specified cannot be met in terms of specific design requirements, substitution or alternative equipment may be considered provided that the substituted equipment does not reduce the intended performance, operation, duty-rate, and redundancy and reliability requirements of the specification.

Deviations or substituted equipment not clearly shown and detailed in the *Deviation Schedule*, will not be considered or accepted and will not limit the Contractor's responsibility to provide equipment in terms of the specification.

Should approval for the revised equipment not be obtained from the Employer, the Contractor will be liable for all costs associated with providing equipment in terms of the specification.

### 3.9 EQUIPMENT

The Consultant shall provide all tools, machinery and equipment necessary to safely perform the required work, test and surveys. All equipment that will be used to perform the tests, surveys etc. must be calibrated and valid calibration certificates submitted to the Employer before the work commences.

### 3.10 DOCUMENTS INCLUDED IN THE WORKS INFORMATION

All Eskom documents listed in section 2.2 are available and can be obtained for Tutuka Power Station. Take note that in some cases only limited information may be available.

For other information that may be required the applicable system engineer at Tutuka Power Station can be contacted for assistance. Employer shall furnish all available data in the form of operation & maintenance manual, drawings, previous inspections and assessments reports and any other information in its possession or which he is able to obtain, pertinent to and reasonably required by the Consultant to carry out the Services under this Contract.

The Consultant shall submit their assignments, drawings and or reports and, if applicable, interim assignments or reports, in accordance with the dates specified in the Contract.

All original documents furnished/supplied by Consultant to Employer and all documents, plans, computer programmes and other data prepared by the Consultant in connection with this Contract shall be lodged with the Employer and shall become the property of the Employer.

The copyright and Intellectual Property in all documents prepared by the Consultant in terms of this Agreement and the Letters of Appointment shall be vested with the Employer, which shall have the right to adapt them for other projects or otherwise apply or dispose of at its sole discretion.

### 3.11 QUALITY MANAGEMENT

The Contractor shall develop and implement a system for collation or quality verification records, including change management records, Inspection Test Plans, Manufacturing, Construction and Commissioning Record Books (Data Books).

#### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

### 3.11.1 Data Books

Data Books shall be maintained by the Contractor to substantiate conformance to product specifications and requirements. All records shall be safely stored (easily retrievable) following the final completion of the works at takeover. These records shall include as a minimum:

- Quality Management documentation
- Safety clearances (to be granted prior commissioning)
- Construction, layout and component approvals
- Routine test certificates
- Construction and as-built drawings and approvals
- Statutory certification
- Data Books (Record Books)

The data books shall be reviewed by the *Employer* for 10%, 30%, 50%, 70% and 100%

All manufacturing and construction data books shall be completed and approved when the Contractor apply for final inspection at construction completion

At takeover application, all manufacturing, construction and commissioning data books shall be completed and approved and handed over to the *Employer*

### 3.12 DOCUMENTATION MANAGEMENT AND CONFIGURATION MANAGEMENT

The contractor and Tutuka configuration management shall be responsible for the following during the design change:

- As-built plant drawings,
- Document Management
- Plant coding and Labelling,
- Design change management

#### 3.12.1 Document Management

All documents supplied by the *Contractor* shall be subject to Eskom's approval. The language of all documentation shall be in English. The *Contractor* shall include the *Employer's* drawing number in the drawing title block. This requirement only applies to design drawings developed by the *Contractor* and his Subcontractors. Drawing numbers will be assigned by the *Employer* as drawings are developed.

##### 3.12.1.1 Document Identification

The *Contractor* is required to submit the Vendor Document Submission Schedule (VDSS) as per agreed dates to the delegated Eskom Representative. Eskom will pre-allocate document numbers on the VDSS and send back to the *Contractor* through the delegated Eskom Representative. The VDSS is revisable and changes must be discussed and agreed upon by all parties. Changes in the VDSS can be additional documentation to be submitted, changes in submission dates or corrections in documentation descriptions, document numbers, etc. The Contractor's VDSS shall indicate the format of documents to be submitted.

#### CONTROLLED DISCLOSURE

When downloaded from the EDS database, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database.

### 3.12.1.2 Drawings Format and Layout

The creation, issuing and control of all Engineering Drawings will be in accordance to the latest revision of "Engineering Drawing Standard" [11] Drawings issued to Eskom will be a minimum of one hardcopy and an electronic copy All *Contractors* are required to submit electronic drawings in Micro Station (DGN) format, and scanned drawings in pdf format

No drawings in TIFF, AUTOCAD or any other electronic format will be accepted Drawings issued to Eskom may not be "Right Protected" or encrypted

### 3.12.1.3 Document Submission

All project documents must be submitted to the delegated Eskom Representative with transmittal note according to "Project / Plant Specific Technical Documents and Records Management Work Instruction" [12] In order to portray a consistent image it is important that all documents used within the project follow the same standards of layout, style and formatting as described in the Work Instruction The *Contractor* is required to submit documents as electronic and hard copies and both copies must be delivered to the *Eskom Representative* with a transmittal note

In addition, the Contractor shall be provided with the following standards which must be adhered to

- "Documentation Management Review and Handover Procedure for Gx Coal Projects" [13]
- "Project Documentation Deliverable Requirement Specification" [14]
- "Technical Documentation Classification and Designation Standard" [15]

### 3.12.2 Engineering Change Management

All Design change management shall be performed in accordance to the latest revision of the "Eskom Project Engineering Change Management Procedure" [16] and the *Employer* shall ensure that Contractor is provided with latest revisions of this procedure Any uncertainty regarding this procedure should be clarified with the *Employer* All design reviews will be conducted according to the "Design Review Procedure" [17]

### 3.12.3 As-Built Plant Drawings

The contractor shall be responsible to update all existing drawings of the "as-built plant" with the new system information

New drawings are to be supplied where changes have been made to the plant

### 3.12.4 Plant Coding

Plant Coding shall be undertaken by the *Employer* and as such the service provider shall make available the following documentation to code

*Employer* will only code the AKZ code defining Documentation listed above The *Employer* will assign a coding practitioner who will interact with the Service Provider in coding the plant as listed above It may be required that the person be based at the Service provider's offices full time The Service Provider will then be required to include allocated codes to all other designs and related documentation It is also the responsibility of the Service Provider to consistently apply the AKZ codes throughout the rest of the technical documentation

The Service provider shall ensure that all documentation is coded (as per the codes assigned by the Practitioner) prior submission to *Employer* for review

## CONTROLLED DISCLOSURE

Tutuka power station coding and plant labelling shall conform to the following Plant standards

- "Tutuka AKZ Coding Procedure" [18]

### 3.12.5 Procedures, Guidelines & Other Documents

The applicable procedures, guidelines and other relevant documentation to commission, operate, maintain and engineer the plant/system shall be supplied with the system, by the contractor. This will include as a minimum the following

- Piping and instrumentation diagrams
- General arrangement and layout drawings
- System description providing all technical specifications
- Operating and control philosophy
- Data sheets and equipment lists
- Temperature rating of detection bulbs
- Testing and commissioning procedures
- Quality Control Plan

### 3.13 OTHER PROJECT DELIVERABLES

In addition to the technical scope, the *Contractor* is to ensure the following are included in his/her submission

#### 3.13.1 Project planning

- Programme detailing the duration of each activity from the day the order is placed. For production purposes, one calendar week per belt will be allocated for the inspection. Any deviations should be noted
- List of any special equipment required to execute the work
- An example of the contractor's QCPs
- An organogram for the core crew, in particular the names and qualifications of the supervisors
- An example of the contractor's procedures

#### 3.13.2 Deviations, Exclusions and qualifications

- List of any deviations or qualifications to this specification must be provided

#### 3.13.3 References

- Verifiable experience of the *Contractor* or sub-contractor or joint venture partner regarding the scope
- Verifiable references are to be provided. The reference list is to include but not limited to, details of the project, plant owners, date and duration of the project

## 4. AUTHORIZATION

This document has been seen and accepted by

### CONTROLLED DISCLOSURE

When downloaded from the EDS database this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the database