

ANNEXURE “A”

TRANSACTION DOCUMENT

Service Order

1. CTT 24962 SCOPE OF WORK

1.1 SERVICES

PetroSA has numerous high pressure cylinders used with Breathing Apparatus and Air Line Equipment. It is a legal requirement in terms of SANS1019 that these cylinders be visually inspected every two years, and hydrostatically tested every four years at SANAS approved testing station.

The Supplier shall be required to perform the following services for PetroSA on an as and when required basis at their own premises:

- 1.1.1 Visual inspection of breathing apparatus cylinders.
- 1.1.2 Visual inspection of diving cylinders.
- 1.1.3 Hydrostatic test of diving cylinders.
- 1.1.4 Hydrostatic test of breathing apparatus cylinders.
- 1.1.5 Chemical cleaning of high-pressure cylinders.
- 1.1.6 Visual inspection of cylinders over 15 litres.
- 1.1.7 Hydrostatic test of cylinders over 15 litres.
- 1.1.8 Servicing of regulator/ BA
- 1.1.9 Delivery of cylinders to/from PetroSA
- 1.1.10 Supply 6L cylinders
- 1.1.11 Supply 50L cylinders
- 1.1.12 Onsite Fixed breathing air compressor calibration