

2016.02.26 09:48:17 CAT J. PRINSLOO (Z4173085) Phone 0215504630
OLZC012JA - 712626796
MAINT REF NO.: E107834
OPERATION 0010 - REPLACE DEFECTIVE 220V BREAKER

F/C: CONDITION 3 - SATISFACTORY

EXPLANATION: EQUIPMENT FOUND IN A GOOD WORKING CONDITION

C/A: REPAIR

FAULT CONDITION: CERTAIN OUTGOING FEEDER BREAKERS WERE FAULTY AND WORKING INTERMITTENTLY. A DECISION WAS TAKEN TO REPLACE ALL THIRTEEN OUTGOING FEEDER BREAKERS AS ITS OF THE OLDER TYPE BREAKERS.

REPAIRS: ALL THIRTEEN OUTGOING CIRCUIT BREAKERS (2 POLE) OF OLZC SWITCHBOARD REPLACED WITH NEW EQUIVALENT SPARES

T/R: ALL THIRTEEN OUTGOING FEEDER BREAKERS REPLACED WITH NEW EQUIVALENT CIRCUIT BREAKERS. ALL THE NEW INSTALLED BREAKERS WERE INSTALLED AND TESTED AND OPERATED SUCCESSFULLY.

R/C: SUSPECT COMPONENT DEGRADATION

M&TE: KEM301081(Y)

RI NUMBERS: 53717

RUNNING HRS: N/A

STARTS/ACTUATIONS: N/A

CROSS REF: PTW - 9/16-87555

W/O - 712626796

COMPLETED BY: I. GABRIELS

VERIFIED BY: W. SIMPSON

COMPLETION DATE: 2016/02/10

FOR MORE INFO CONTACT MAIN DOCS...

C.O.C; 0277/88Q; Q3:1E:1:0; SEE EQUIVALENCE E018/09E REV2;
BREAKER, CIRCUIT; MNF: MERLIN GERIN; P/N: MG C60N-10A; WITH
AUXILIARY SWITCH (OF+ SD) - NO. 26929; SWITCHGEAR DESIGN: MCB;
POTENTIAL: 230 V AC; CURRENT: 10 A; SHORT TIME CURRENT: 5 KA;
POLE: 2; CONTROL VOLTAGE: 230 V AC; CREEPAGE: >0.5 MM; BASIC
INSULATION LEVEL: 25 M OHMS; INSULATION MATERIAL: PLASTIC;
OPERATING CONTROL TYPE: 230 V AC; POLLUTION CLASS: 3;
APPLICATION: PROTECTION & ISOLATION; TEMPERATURE RATING: 40 DEG
C; WIDTH: 36 MM; LENGTH: 70 MM; HEIGHT: 81 MM; MOUNT: DIN RAIL;
M/MAN: 308,571; FUNCT.LOC: 1/2 LNA/B/C/D 001 DL; END DETAIL
DESCRIPTION; JNF 2009/04/07; CLC 2013/09/12; JNF 2015/08/05; BN
2022/10/13



TD & RM

RECORD COVER SLIP

Reference No.: KFI-RE-001

Revision: 1

Page: 1

Associated Procedure: KAA-830



1139445

ALLOC. CENTRE

DOCUMENT NUMBER

REV

0

FOR OFFICE USE ONLY

TITLE

COVER SLIP COMPLETED BY

EQUIVALENT: CIRCUIT BREAKER.

(REV 1)

CHAMELLE TULLEY

DOCUMENT TYPE

SECURITY CLASS

RECORD

RESTRICTED

AUTHOR ORIGINATOR

MB FAHRENFORT

TRIGRAMME (STATUS COMMENTS)

1/2 LNA/B/C/D 001 DL (DJ02;DJ03, 101, 102, 103, 104, 105, AND 106 JA)
1/2 LNE 001 DL (DJ02; DJ03)

ADDRESSEE

REF. DATE (CCYYMMDD)

2009/10/13

KIS / SHELF LOCATION

PT095

NO. OF PGS

59

RETENTION PERIOD

YEARS 40

REFERENCE NUMBERS

E018/09E
S2009/0180

DISTRIBUTION / COPIES

DE SUPPORT - C Tulley
B Johnson - EMS
J Fourie - MAT. Planning
E Capes - Buying
E Viljoen - Reliability Eng
S Sangweni - EMS
E Perrang - TD&RM
M Fahrenfort - DEG

AUTHENTICATED

SIGN

DATE

[Signature]
2009-10-14

FOR OFFICE USE ONLY

SCANNED

REGISTERED



RECORD FORMAT

HARDCOPY (PAPER)

DISC

RADIOGRAPH

TAPE






OTHER

NOTES

EQUIVALENCE	REV	PAGE
E 018/09E	1	1 of 10

ESKOM
KOEBERG NUCLEAR POWER STATION
DESIGN ENGINEERING GROUP

EQUIVALENCY STUDY NUMBER: E 018/09E
EQUIVALENCY STUDY TITLE: Circuit Breaker
ORIGINAL EQUIPMENT: MERLIN GERIN F32 / C32H-DC series
PROPOSED REPLACEMENTS: MERLIN GERIN C60N series

PREPARED BY:  MB Fahrenfort
REVIEWED BY:  EJ Kerr
REVIEWED BY:  SME
AUTHORISED BY:  NW Boonzaier
DATE: 2009-10-13
DATA CAPTURED  C Tulley

EQUIVALENCE	REV	PAGE
E 018/09E	1	2 of 10

KOEBERG NUCLEAR POWER STATION

DESIGN ENGINEERING GROUP

	AUTHORISED: AM Kotze	DATE:
REVISION	PREPARED BY	REVIEWED BY
Original	MB Fahrenfort	EJ Kerr
Rev 1	MB Fahrenfort	EJ Kerr

RECORD OF REVISIONS

Rev	Date	Description of Revision	Prep.	Rev.	Auth.
0	2009-03-25	Original	MBF	EJK	AMK
1	2009-09-30	Added auxiliary switch to C60N-32 A circuit breaker.	MBF	EJK	NWB

EQUIVALENCE	REV	PAGE
E 018/09E	1	3 of 10

CONTENTS

- 1.0 SCOPE
- 2.0 REFERENCES
- 3.0 EQUIPMENT
- 4.0 TECHNICAL EVALUATION
- 5.0 FAILURE MODES AND EFFECTS ANALYSIS
- 6.0 OBSOLESCENCE
- 7.0 CONCLUSION
- 8.0 INSTALLATION
- 9.0 TRAINING
- 10.0 DOCUMENTATION UPDATES
- 11.0 COMMERCIAL UPDATES
- 12.0 ATTACHMENTS

EQUIVALENCE	REV	PAGE
E 018/09E	1	4 of 10

1.0 SCOPE

1.1 Equivalency Evaluation between:

MERLIN GERIN F32 and C32H-DC series circuit breaker

and proposed replacement(s)

MERLIN GERIN C60N series circuit breaker

1.2 Equipment Trigramme

1/2 LNA/B/C/D 001 DL (DJ02; DJ03; 101, 102, 103, 104, 105, AND 106 JA)

1/2 LNE 001 DL (DJ02; DJ03)

1.3 Function of the Equipment

LNA/B/C/D 001 DL:

The circuit breakers (rated at 32 A, 10 A and 2 A) and auxiliary switch (only on the 32 A circuit breaker), are used in the dirty supply circuit (DJ03), as the outgoing feeders (101 -106 JA) and in the inverter control circuit (DJ02), respectively in the 5 kVA inverter units.

LNE 001 DL:

The circuit breakers (DJ02 and DJ03, both rated at 2 A), are used in the auxiliary power circuit on the 20 kVA inverter units.

1.4 Reason for change

The original MERLIN GERIN F32 and C32H-DC series circuit breakers are obsolete.

1.5 Classification

Classification No : 0277/88Q
Safety : 1E
Seismic : 1
Quality : Q3
Environmental : 0
Importance : CSR

2.0 REFERENCES

2.1 DSE-LNi;

2.2 DSE-LNE;

EQUIVALENCE	REV	PAGE
E 018/09E	1	5 of 10

- 2.3 MM 308;
- 2.4 MM 571;
- 2.5 MERLIN GERIN catalogue;
- 2.6 Schneider Electric Catalogue (Jan 2002);
- 2.7 SAR II-11.2.2.2.1;
- 2.8 Equivalency study E 039/91E ;
- 2.9 Equivalency study E 061/91E;
- 2.10 Equivalency study E 061/93E.

3.0 EQUIPMENT REQUIREMENTS

3.1 Service Conditions

3.1.1 Normal Environment:

Temperature	:	5 to 40°C
Pressure	:	Atmospheric
Humidity	:	40 to 90%
Radiation	:	Background

3.1.2 Accident Conditions

The circuit breaker is safety related and is required to operate under seismic and nuclear accident conditions.

3.2 Functional Requirements

The following are the functional requirements for the item under evaluation:

Voltage rating (V ac)	:	220
Rated current (A) @ 40°C	:	32, 10 and 2
No. of poles	:	2
Maximum short circuit current (kA):	:	5
Frequency (Hz)	:	50
Auxiliary switch	:	1 NO

3.3 Physical Requirements

Mounting	:	DIN rail
Terminals	:	Self-clamping

EQUIVALENCE	REV	PAGE
E 018/09E	1	6 of 10

3.4 Verification and Test

KWM-EP-MAC-017 (for 5 kVA inverters) and KWM-EP-MAC-018 (for 20 kVA inverters).

3.5 Quality Assurance

Final inspection and test certificates are sufficient, based on NOTE 8 of section 4.1 and the attached seismic justification report (see attachments 12.4 and 12.5).

3.6 Availability

The circuit breaker is available through Schneider Electric distributors.

4.0 TECHNICAL EVALUATION / OE

4.1 TECHNICAL EVALUATION

DESCRIPTION Attachment 12.6 lists all the criteria considered.	FUNCTIONAL REQUIREMENTS	MERLIN GERIN C32H-DC series circuit breaker see attachment 12.2	MERLIN GERIN C60N series circuit breaker see attachment 12.3	COMMENTS
FUNCTION				
Voltage rating (V ac)	220 (ref. LNi-DSE)	220	230	Acceptable Note 1
Rated current (A) @ 40 °C	LNi-DSE (ref. Inverter design).	32, 10 and 2	32, 10 and 2	Same
Breaking Capacity (kA)	5 (ref. LNi-DSE)	20	10	Acceptable Note 2
No. of poles	2 (ref. LNi-DSE Inverter design).	2	2	Same
Mechanical life span-operations (10 ³)	None. (ref. Original equipment specification)	20	20	Same
Tropicalisation	77% @ 40°C (ref. LNi-DSE)	95% @ 55°C	95% @ 55°C	Acceptable Note 3
Tripping characteristics	No design basis. 5,5 to 8,8 In Based on the original F32 circuit breaker.	U-curve (5,5 to 8,8 In)	C-curve (5 to 10 In)	Acceptable Note 4
Auxiliary switch	1NO. (ref. Original equipment specification)	1 NO	1 NO	Same
Cable size (mm ²)	≤ 25 (ref. inverter design – MM571)	≤ 25	≤ 60	Acceptable Note 5
FORM/FIT				
Dimensions (LxHxD) mm	Requirement acceptance based on visual inspection.	36x80,5x66	36x81x70	Acceptable Note 6
Mounting	DIN rail (Visual inspection)	DIN rail	DIN rail	Same

DESCRIPTION	FUNCTIONAL REQUIREMENTS	MERLIN GERIN C32H-DC series circuit breaker see attachment 12.2	MERLIN GERIN C60N series circuit breaker see attachment 12.3	COMMENTS
FORM/FIT				
Terminals	Tunnel terminals, self-clamping (Visual inspection)	Tunnel terminals, self-clamping	Tunnel terminals, self-clamping	Same
CLASSIFICATION				
Seismic	1A (ref. Classification: 0277/88Q)	1A	1A	Same Note 7

- Note 1:** The recommended supply voltage in accordance with IEC 60038 is 230 V ac (see attachment 12.8), which is the basis for SANS 1019 (Standard Voltages, Currents and Insulation Levels for Electricity Supply).
- Note 2:** The short circuit breaking capacity stipulated in DSE-LNi (document no. TS/EE-DC-0346 p8) is 5 kA. This value is applicable to the main supply busbars and sub-components e.g. circuit breakers and contactors.
- Note 3:** The relative humidity stipulated in the DSE-LNi (document no. TS/EE-DC-0244 p12) is 77%@40°C.
- Note 4:** There are no tripping characteristics stated in the DSE-LNi. The characteristic of the original circuit breaker (F32 series) is 5 to 9,5 In-see attachment 12.1. The tripping characteristic of the proposed circuit breaker envelopes the tripping characteristic of the original and is considered to be acceptable.
- Note 5:** The proposed circuit breaker has the same tunnel type, self clamping terminals as the original, and can accommodate a larger cable.
- Note 6:** There are slight height and depth dimensional differences (0,5 mm and 4 mm respectively) between the original and the proposed equivalent circuit breaker. There is sufficient space on the mounting rail (DIN type), inside the inverter unit to fit the new circuit breaker.
- Note 7:** EDF Directive 81 does not allow for a qualified item/component to be replaced by a non-qualified item/component. In the case of the MG 30 inverters supplied by Data Systems and Solutions, the inverters are qualified but certain individual components like the circuit breakers are not qualified. The obsolete MG F32 and MG C32H-DC series circuit breakers are replaced by the MG C60N series. Qualification by Analysis (of the inverter and circuit breaker) was performed by Data Systems and Solutions to demonstrate that the replacement of the circuit breakers does not affect negatively the seismic qualification of the inverters (see attachments 12.4 and 12.5).

4.2 OPERATING EXPERIENCE

No OE could be found.

EQUIVALENCE	REV	PAGE
E 018/09E	1	8 of 10

5.0 FAILURE MODES AND EFFECTS ANALYSIS

5.1 There are no new failure modes introduced by the proposed MG C60N series circuit breakers.

6.0 OBSOLESCENCE

6.1 End of production

MERLIN GERIN has confirmed that the equipment will be available for the next 5 years (2014).

6.2 End of support

The expected end of support date is 3 years (2017).

7.0 CONCLUSIONS

7.1 Based on the technical evaluation performed in Section 4.1, the proposed MG C60N series circuit breakers has the same form and function as the original equipment, and an acceptable fit. DE Support, therefore considers the proposed circuit breaker equivalent to the original.

7.2 The outcome of the safety screening, S2009/0180 rev 1 is that neither a safety evaluation nor NNR approval is required. See attachment 12.7.

8.0 INSTALLATION

8.1 The equipment shall be installed in accordance with KWM-EP-MAC-017 (for 5 kVA inverters) and KWM-EP-MAC-018 (for 20 kVA inverters).

9.0 TRAINING

No Maintenance, Operating or Engineering training is required.

10.0 DOCUMENTATION UPDATES

The following documentation has been identified as requiring inclusion/updating.

10.1 DDR 2009/02749;

10.2 Log equivalency on EPMS-EQ number 46681.

EQUIVALENCE	REV	PAGE
E 018/09E	1	9 of 10

11.0 COMMERCIAL UPDATES

11.1 The SAP material no. 0240514 be created to reflect the following description:

Manufacturer	:	MERLIN GERIN
Supplier	:	Schneider Electric
Equipment type	:	Circuit breaker
Part no.	:	MG C60N – 2 A
Classification	:	1E/1/Q3/0 in accordance with 0277/88Q
Specification	:	C.O.C. based on E 018/09E
Trigramme	:	1/2 LNA/B/C/D 001DL 1/2 LNE 001/002/003 DL
Equivalency no.	:	E 018/09E rev 1

11.2 The SAP material no. 0240515 be created to reflect the following description:

Manufacturer	:	MERLIN GERIN
Supplier	:	Schneider Electric
Equipment type	:	Circuit breaker
Part no.	:	MG C60N – 10 A
Classification	:	1E/1/Q3/0 in accordance with 0277/88Q
Specification	:	C.O.C. based on E 018/09E
Trigramme	:	1/2 LNA/B/C/D 001DL
Equivalency no.	:	E 018/09E rev 1

11.3 The SAP material no. 0240516 be created to reflect the following description:

Manufacturer	:	MERLIN GERIN
Supplier	:	Schneider Electric
Equipment type	:	Circuit breaker + Auxiliary switch
Part no.	:	MG C60N – 32 A and auxiliary switch (OF + SD), no. 26929
Classification	:	1E/1/Q3/0 in accordance with 0277/88Q
Specification	:	C.O.C. based on E 018/09E
Trigramme	:	1/2 LNA/B/C/D 001DL
Equivalency no.	:	E 018/09E rev 1

EQUIVALENCE	REV	PAGE
E 018/09E	1	10 of 10

12.0 ATTACHMENTS

- 12.1 MG F32 data sheets;
- 12.2 MG C32H-DC data sheets;
- 12.3 MG C60N data sheets;
- 12.4 Data Systems and Solutions seismic report (translated version);
- 12.5 Data Systems and Solutions seismic report (original version);
- 12.6 Input Consideration Checklist for circuit breakers;
- 12.7 Safety Screening Form S2009/0180;
- 12.8 IEC 60038 recommended voltages.

EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.1

MG F32 data sheets

5 PAGES

disjoncteurs basse tension

compact F32 - F32H

Ces disjoncteurs sont élaborés en fonction des recommandations internationales CEI 157-1, de la norme européenne CEE 19 et des normes françaises UTE NFC 63 120 (disjoncteurs industriels) et NFC 61 400 (disjoncteurs pour installations domestiques ou analogues).

Le Compact F 32 H se distingue du Compact F 32 par son haut pouvoir de coupure (10 kA).

Le Compact F 32 u est admis à la marque de qualité NF USE.

Le Compact F 32 MM est homologué par le Bureau Véritas (1).

Les caractéristiques de montage et d'encombrement sont identiques pour tous les appareils.

Utilisation
Protection des lignes et des circuits d'éclairage et de chauffage; commande et protection des moteurs de petite puissance.

Déclencheurs
Un déclencheur à maximum de courant par pôle. Ils sont de type magnétothermique, non réglables.

Pour la description générale de l'ensemble des disjoncteurs Compact consulter la fiche technique F 9.30.

32 A
C.A. 380 V
C.C. 250 V
1, 2, 3 ou 4 pôles
pas 17,5 mm

marque de qualité
NF USE (F 32 u)

homologation Bureau
Véritas (F 32 MM) (1)



caractéristiques

pouvoir de coupure

Calibres 10 à 32 A			
réseau 220/380 V		F 32	F 32 H
normes de référence		hautes performances	
NFC 63 120 P1	220 V	8 000 A	12 000 A
CEI 157-1 P1	380 V	8 000 A	10 000 A
NFC 61 400 (CEE 19 révisée)		3 000 A	
Bureau Véritas	220 V	5 000 A (1)	
Calibres inférieurs à 10 A : un seul modèle, le Compact F 32 (réseau 220/380 V - norme NFC 63 120 - P1 et CEI 157-1 P1).			
calibres	pouvoir de coupure		
1 A	10 000 A (20 000 A bipolaire 220 V)		
2 et 3 A	8 000 A (18 000 A bipolaire 220 V)		
5 A	8 000 A (10 000 A bipolaire 220 V)		
Bureau Véritas	5 000 A (1) sous 220 V		

Sur les réseaux 110/220 V, pouvoirs de coupure plus élevés. L'unipolaire sous 380 V (cas du défaut double) a un pouvoir de coupure de :
2 500 A pour le F 32,
3 000 A pour le F 32 H.

Utilisation en courant continu voir fiche technique N 9.05.




(1) Tension nominale 250 V 2 ou 3 pôles
Pouvoir de coupure
5 kA sous 220 V, cos φ ≥ 0,7



3/5

Courbes de déclenchement

La variation du temps de déclenchement est donnée en fonction du rapport I/I_n (courant réel, I_n courant nominal).
 À 25 °C, la courbe de déclenchement d'un appareil de calibre quelconque se trouve dans la plage délimitée par les courbes ci-dessous.



160

Choix des calibres

Le choix du calibre dépend du courant d'utilisation et de la température ambiante.
 Coefficient de réduction de l'intensité nominale de service suivant la température ambiante.

Calibres (A)	20 °C	35 °C	45 °C
1-2-3-5	1	0,8	0,65
10-15-20-25-32	1	0,85	0,75

(1) références réelles

Installation en coffret

Pour tenir compte de l'élévation de température à l'intérieur du coffret, il est d'usage de prendre un coefficient de sécurité et de multiplier par 0,8 les calibres.

Coffrets MGA


En coffrets MGA type G, Méga D ou D, pour des calibres supérieurs à 10A fonctionnant simultanément et placés côte à côte, les intensités à ne pas dépasser sont:
 14 A pour le calibre 15
 16 A pour le calibre 20
 20 A pour le calibre 25
 22 A pour le calibre 32
 pour une température ambiante de 25 °C à l'extérieur du coffret.

En circuit d'éclairage incandescent ces précautions suffisent largement.
 En circuit d'éclairage fluorescent, suivant l'efficacité de la compensation, d'autres précautions peuvent parfois s'avérer nécessaires: consulter le catalogue Merlin Gerin ou le pratique d'installation sur ce sujet.

auxiliaires

Bloc Vigil F 32
 Bloc déclencheur différentiel de ou tétra encadrable
 Sensibilité $I_{\Delta n} = 30$ et 300 mA
 Cf. fiche technique F 2.303


Déclencheur à émission de courant
 (un fil sorti)
 Bloc unipolaire encadrable
 Tension :
 110 à 380 V C.A., 115 à 125 V C.C




En pointillé, raccordement et tournure non réalisés par construction.

Contact auxiliaire O - F
 montage en usine. Présentation identique au déclencheur à émission.

Contact signal défaut à ouverture
 montage en usine. Occupe un pôle supplémentaire indépendant électriquement des autres pôles.



coffret Méga D 2



coffret G 2

11/5

association avec des fusibles

Dans certains cas de courants de court-circuit élevés, l'association judicieuse du Compact F32 avec des fusibles permet d'assurer la protection nécessaire tout en conservant l'économie d'exploitation. le plus grand nombre de défauts reste à éliminer par le disjoncteur, le fusible n'intervenant qu'exceptionnellement. En général, dans le cas du tétrapolaire, ne pas mettre de fusible sur le neutre.

Dimensions des fusibles

Suivant les calibres, les fusibles sont à choisir dans les tailles 10 x 38, 14 x 51, 22 x 58 pour le type cylindrique et 00 pour le type à couteaux.

H bloc 32

Ensemble, monté câblé sur platine, livré prêt à raccorder, comprenant : un disjoncteur F32 équipé d'un déclencheur à émission de courant ou d'un bloc différentiel Vigi F32, un jeu de coupe-circuit HPC, un voyant lumineux et des fusibles de protection du circuit de signalisation.

Le H bloc 32 :

- assure un pouvoir de coupure de 50 kA
- réalise la coordination entre le disjoncteur et les coupe-circuit HPC
- assure la coupure omnipolaire en cas de fusion d'un coupe-circuit
- visualise la fusion du coupe-circuit de neutre, pour interdire la manœuvre de réenclenchement du disjoncteur avant changement du coupe-circuit.

Gain en pouvoir de coupure
Association avec FUSIBLES AMONT réalise la coupure omnipolaire*
pouvoir de coupure de l'association 50 kA.



calibre F32 (A)	fusibles aM		fusible gF	
	calibre (A) maxi	calibre (A) mini	calibre (A) maxi	calibre (A) mini
1	40	2	63	6
2	40	4	63	12
3	40	6	63	16
5	80	12	100	32
10	80	20	100	50
15	80	25	100	63
20	80	32	100	80
25	80	40	100	100
32	80	50	100	100

* Le courant de court-circuit provoque la fusion du fusible et le déclenchement simultané du disjoncteur (coupure omnipolaire).

Sélectivité avec FUSIBLES AVAL
Association avec fusibles ava. gF avec garantie de sélectivité

calibre F32 (A)	calibre max du fusible gF
10	2
15	2
20	2
25	4
32	6

Exemples d'association fusibles amont
le nombre de départs dépend de la puissance admise par le fusible employé



utilisations particulières


Réseau 440 V, 50 et 60 Hz.
Pouvoir de coupure cycle P1, bi, tri, tétra
F 32 : 3 000 A
F 32 H : 5 000 A

Réseau 400 Hz.
■ comportement des déclencheurs comme sur réseau 50 Hz
■ déclassement des calibres en fonction de la température ambiante :


température ambiante	25°	35°	45°
coefficient de déclassement	0,9	0,75	0,6

montage

Encombrement



Montage sur platine avec ou sans cache-bornes
L'encliquetage se fait de la même façon que sur le profilé Oméga symétrique de 35 mm. La platine se fixe sur panneau par deux vis. Le cache-bornes se fixe sur la platine par encliquetage et se verrouille par une vis incorporée plombable.



	uni	bi	tri	tétra
A	8,8	26,3	43,8	61,3
B	23	40,5	58	75,5

Il existe des cache-bornes pour le F32 équipé de ses auxiliaires encliquetables.

Masse


uni : 150 g
bi : 300 g
tri : 440 g
tétra : 590 g

Fixation sur profilé Oméga symétrique de 35 mm (profondeur 5 mm minimum) par encliquetage

montage




démontage




Fixation sur profilé DIN asymétrique
Une pièce intermédiaire et un Fixocap blanc permettent de monter le disjoncteur comme sur le profil Oméga asymétrique.

- a : vis de fixation
- b : rail asymétrique
- c : fixocap
- d : pièce intermédiaire




Montage derrière panneau plan de découpe


étriers de fixation : la même pièce permet les 2 modes de fixation.



- a : longueur du rail DIN (n - 1) x 17,5 mm
- n : nombre de pôles F32




en sautoir



encastré

Montage en coffrets

- métalliques MGA avec ou sans jeu de barres fonctionnel.
- isolants D, Méga D, E, F, FT.



jeu de barres 1012

MERLIN GERIN
département Compact
Grenoble France
adresse postale
38 X
39043 GRENOBLE CEDEX

En raison de l'évolution des normes et du matériel, les caractéristiques ou cotés d'encombrement donnés ne nous engageant qu'après confirmation par nos services

EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.2


MG C32H data sheets

3 PAGES

IEC 157-1 C32H mcb

**U type tripping curve :
10000 A**

Selection table for Multi 9 mcbs : see page 8.



type	width in modules of 9 mm	rating (A)	cat No.
1P		10	20054
		15	20055
		20	20056
		25	20057
		32	20058
		40	20059

1 protected pole

Application
Control and protection of circuits in installations with high short-circuit current.

Technical data
 ■ current rating : 10, 15, 20, 25, 32, 40 A at 40°C.
 ■ voltage rating : 220/240/380/415 V AC.
 ■ breaking capacity : to IEC 157-1, NF C 63-120 and BS 4752 (O-CO sequence).

rating (A)	type	voltage (V)	breaking capacity (A)
10 to 40	1P	220	10000
		240	8000
	2, 3, 4P	220	20000
		380	10000
	2, 3, 4P	415	8000

■ number of operating cycles (O-C) : 20 000.

■ tripping characteristics⁽¹⁾ : U curve : the magnetic releases operate between 5.5 and 5.8 In.

■ tropicalization : treatment 2 (relative humidity 95% at 55°C).

■ overall dimensions : see page 96.

■ weight (g) :

type	1P	2P	3P	4P
	127	250	385	495

■ other technical data :

see pages 104 to 108.

■ connections : tunnel terminals for cables up to 25 mm².

■ approvals :

Lloyds approval : 10 to 40 A, 2P, 3P, 4P :

220 V, 50/60 Hz, b.c. : 2100 A ;


440 V, 50/60 Hz, b.c. : 6100 A ;

70 V DC, b.c. : 15000 A (2 poles take part in breaking).

Veritas approval.


Installation

In all enclosures designed for Multi 9 equipment.




type	width in modules of 9 mm	rating (A)	cat No.
2P		10	20074
		15	20075
		20	20076
		25	20077
		32	20078
		40	20079

2 protected poles



type	width in modules of 9 mm	rating (A)	cat No.
3P		10	20084
		15	20085
		20	20086
		25	20087
		32	20088
		40	20089

3 protected poles



type	width in modules of 9 mm	rating (A)	cat No.
4P		10	20094
		15	20095
		20	20096
		25	20097
		32	20098
		40	20099

4 protected poles

Electrical auxiliaries : page 32.
 Application guide : pages 104 to 127.
 Connection and installation accessories : page 33.

(1) the identification of the curve is made by the colour of the clip : red for U type.


C32/C45/C63 (Fixing on symmetrical DIN rail)

Circuit-breaker

Vigi module C32/C45


Vigi module C63

Auxillaries



P25M

installation accessories




C100 (Fixing on symmetrical DIN rail)

Circuit-breaker

Vigi module

Codis block


Other auxiliaries



connection accessories

4-pole busbar assembly C32/C45
cat. No. 05020

4-pole busbar assembly C100
cat. No. 05034




installation accessories

Back plate and terminal shields C32/C45

Metal enclosure C32/C45

Isolatable back plate C32/C45/C63



	1P	2P	3P	4P
A	8.8	26.3	43.8	61.3
B	23	40.5	58	75.5

(1) Use clip-spacer cat. No. 14860 (2 mod.)

(1) for C32a/N/H, C45/C45N
(2) for C32L, C63L

EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.3






MG C60N data sheets

6 PAGES

C60N (1-63A) C120N (80-100A)

C curve

10kA
VC8036
IEC 947-2

Pole	Width in mod of 9mm	Type	In (A)	Ref.	Price			
1 protected pole 	1P	C60	1	60862	153.49			
			2	60863	153.46			
			3	60864	153.46			
			6	60866	101.38			
			10	60867	101.38			
			16	60868	101.38			
			20	60869	101.38			
			25	60870	117.71			
			32	60871	117.71			
			40	60872	117.71			
			50	60873	127.71			
3 protected poles 	3P	C60	63	60874	127.71			
			80	60729	144.32			
			100	60730	167.20			
			2 protected poles 	2P	C60	1	60875	397.06
						2	60876	397.05
						3	60877	397.05
						6	60879	278.77
10	60880	278.77						
16	60881	278.77						
20	60882	278.77						
25	60883	305.53						
32	60884	305.53						
40	60885	305.53						
3 protected poles 	3P	C60	50	60886	312.57			
			63	60887	312.57			
			80	60733	382.00			
			100	60734	397.87			
			4 protected poles 	4P	C60	1	60888	505.88
						2	60889	505.88
						3	60890	505.88
						6	60892	382.97
						10	60893	382.97
						16	60894	382.97
20	60895	382.97						
25	60896	382.97						
32	60897	443.51						
40	60898	443.51						
50	60899	457.59						
63	60900	457.59						
4 protected poles	4P	C120				80	60737	598.40
			100	60738	649.00			
			4 protected poles	4P	C60	1	60901	802.53
						2	60902	802.53
						3	60903	802.53
6	60905	594.17						
10	60906	594.17						
16	60907	594.17						
20	60908	594.17						
25	60909	594.17						
32	60910	718.05						
40	60911	718.05						
50	60912	957.41						
63	60913	957.41						
4 protected poles	4P	C120	80	60741	1222.10			
			100	60742	1299.10			

Application

- Control and protection of circuits against overloads and short circuits
- In commercial and industrial electrical distribution systems

Technical data

- Current rating: 1 to 100A at 40° C
- Voltage rating: 230 / 400 V AC
- Breaking capacity:

IEC 947.2

Rating (A)	Type	Voltage (V)	Breaking capacity (A)
1 to 63	1P	230	10000
63	2, 3, 4P	400	10000

•positive contact indication

•fast closing

- Number of operating cycles (O-C): 20000

•Tripping characteristics:

C curve: the magnetic releases operate between 5 and 10 In

- Tropicalisation: treatment 2 (relative humidity 95% at 55°C).


•Connections: tunnel terminals for rigid cables up to: 25mm for rating < 25A, 50mm for rating < 63A

•Installation: in all enclosures designed for Multi 9 equipment.

C60 Dimensions



C120 Dimensions



Auxiliaries: page 19
Accessories: page 20
Vigi module: page 24
DC characteristics: page 4
Temperature derating: page 4
Tripping curves: page 7


- Add on Vigi's: 1/12
- Electrical auxiliaries: 1/13
- Accessories: 1/13-14
- Rotary handle: 1/13
- Padlocking devices: 1/14
- Comb Busbar: 1/14
- Cascading & discrimination tables: 14/8
- Temperature derating tables: 14/4-5
- DC characteristics: 14/6-7

Protection & Isolation

Merlin Gerin Multi 9 System – Miniature Circuit Breakers
 C60N – 1 to 63A
 10kA at 230/415V, C & D Curves
 IEC60947-2




60867

Type C60N	Rating (A)	C Curve	D Curve
1P 	1	60862	60506
	2	60863	60507
	3	60864	60508
	6	60866	60509
	10	60867	60510
	16	60868	60511
	20	60869	60512
	25	60870	60513
	32	60871	60514
	40	60872	60515
	50	60873	60516
63	60874	60517	


Width in mod of 9mm - 2




60880

2P 	1	60875	60518
	2	60876	60519
	3	60877	60520
	6	60879	60521
	10	60880	60522
	16	60881	60523
	20	60882	60524
	25	60883	60525
	32	60884	60526
	40	60885	60527
	50	60886	60528
63	60887	60529	


Width in mod of 9mm - 4




60893

3P 	1	60888	60530
	2	60889	60531
	3	60890	60532
	6	60892	60534
	10	60893	60535
	16	60894	60536
	20	60895	60537
	25	60896	60538
	32	60897	60539
	40	60898	60540
	50	60899	60541
63	60900	60542	


Width in mod of 9mm - 6



60906

4P 	1	60901	60543
	2	60902	60544
	3	60903	60545
	6	60905	60547
	10	60906	60548
	16	60907	60549
	20	60908	60550
	25	60909	60551
	32	60910	60552
	40	60911	60553
	50	60912	60554
63	60913	60555	

Width in mod of 9mm - 8



Connection: Tunnel terminals for the following cables
 • up to 25A : 25mm² stranded
 • 32 to 63A : 35mm² stranded

Protection & Isolation


Merlin Gerin Multi 9 System - Miniature Circuit Breakers
 Tripping Curves
 Markings & limitation Capability



Trip Unit Variations

Circuit Protection

A choice of several curves
 Whatever circuit has to be
 protected, a C60 or C120 circuit
 breaker provides the perfect
 solution with a suitable curve.



Type 2 Curve
 tripping:
 4 to 7 In;
 protection of circuits,
 general applications.



Curve C
 tripping:
 5 to 10 In;
 protection of circuits,
 general applications.




Curve D
 tripping:
 10 to 14 In;
 protection of high surge
 circuits, welders,
 transformers, motors.



Curve MA
 (magnetic only)
 tripping: 12 In;
 protection of motor
 starters (+ thermal
 protection when
 combined with
 contactor).


Circuit Breaker Marking



1. Circuit Breaker Model Number
2. Circuit Breaker Current Rating
3. Operating Voltage
4. Rated Breaking Capacity
5. Specification
6. Circuit Breaker Part Number
7. Electrical Diagram - No. of Poles

Circuit Breaker Limitation Capability

The limitation capability of a circuit breaker is that characteristic whereby only a current less than the prospective fault current is allowed to flow under short-circuit conditions.



This is illustrated by limitation curves which give:

- The limited peak current in relation to the RMS value of the prospective short-circuit current (the short-circuit current being that current which would flow continuously in the absence of protection equipment).
- The limited current stress in relation to the RMS value of the prospective short-circuit current.
- Current limiting capability. The advanced design of the Multi-9 range provides current limitation with far better protection than conventional circuit breakers. For example, on a 6A rating with a prospective short circuit of 5000A, the current will be limited at 350A or 7%.


Installation of current limiting circuit breakers offers several advantages:

- **Better network protection**
 Current limiting circuit breakers considerably reduce the undesirable effects of short-circuit currents in an installation.
- **Reduced thermal effects**
 Cable heating is reduced, hence longer cable life.
- **Reduced mechanical effects**
 Electrodynamic forces reduced, thus electrical contacts are less likely to be deformed or broken.
- **Reduced electromagnetic effects**
 Measuring equipment situated near an electrical circuit less affected.

Adaptable electrical auxiliaries for

Multi 9

C60, C120, DPN Vigi, ID



Combined with the Multi 9, C120 circuit-breakers, ID residual current and DPN Vigi circuit-breakers.

They ensure remote tripping or indication.

Auxiliary contacts: "OF" and "OFS"

Indication of the "open" or "closed" position of the circuit-breaker (OF) or the residual current circuit-breaker (OFS) with which they are combined.

Fault indicating switch: "SD"

Indication of the "fault trip" position of the circuit-breaker or residual current circuit-breaker with which it is combined. Visualisation of the fault (circuit-breaker) or earth fault indication (ID) on the front face by means of a mechanical indicator.

Changeover contact: "OF+SD/OF"

- > Upper circuit: OF, lower circuit: OF or SD.
- > OF: remote indication of the "open" or "closed" position of the circuit-breaker or residual current circuit-breaker with which it is associated.
- > SD: remote indication of the "tripped" or fault position of the circuit-breaker or residual current circuit-breaker with which it is associated.
- > Function choice using the selector switch on the right side.
- > The selected function is indicated on the front face.

Undervoltage selective release: "MN"

Undervoltage release that controls the opening of the circuit-breaker or residual current circuit-breaker with which it is combined; it allows a 0.5 second time delay on a brownout or voltage drop.

Undervoltage instant release: "MN"

When its supply voltage drops (between 70 and 35%), it controls the tripping and opening of the circuit-breaker or residual current circuit-breaker with which it is combined. Furthermore, it prevents the circuit-breaker or the residual current circuit-breaker from reclosing as long as its supply voltage is not restored.

- > Utilisation:
 - emergency stop using a pushbutton,
 - safety on the circuits supplying several machines by preventing "uncontrolled" restart of all motors.

Shunt release: "MX + OF"


When energised, it controls the tripping and opening of the circuit-breaker or residual current circuit-breaker with which it is combined. Equipped with an O +C contact to indicate the "open" or "closed" position of the circuit-breaker or the residual current circuit-breaker.

Release for pushbutton: "MNx"

Completely unaffected by power supply circuit cuts, it is recommended for fail-safe emergency stops. Replaces the "voluntary" MX release equipped with its NO/NC indicator lights.


Release with voltage threshold: "MSU"

Specially designed to monitor voltage between the neutral and phase(s) conductors, it cuts off the power supply by opening the circuit-breaker in the event of overvoltage (case of neutral breaking).








The range

Auxiliaries



Wiring schemes



Owing to changes in standards and equipment, the characteristics given in the text and images in this document are not binding until they have been confirmed with us.

Implementation

- > Designed for installation in modular electrical enclosures and cubicles.
- > Easy connection and reliability ensured by the serrated tunnel terminals with guard.
- > Captive screws with mixed \pm imprint.
- > Simplified combination with C60, C120, DPN Vigi circuit-breakers and ID residual current circuit-breakers using clip-ons. The electrical auxiliaries allow remote tripping or indication of the circuit-breakers with or without Vigi module. They are mounted on the left-hand side of the circuit-breaker (max. width: 54 mm). Use of the OF.S auxiliary contact is compulsory for adding the MN, MX, SD, OF, MNx, MSU functions to the ID residual current circuit-breaker switch.

Operation simulation

- > On the front face of the auxiliary contacts (26924 26927), a test button allows for the OF and SD functions to be simulated without generating the circuit-breaker or the residual current circuit-breaker.

Technical data

Type	Voltage (V)	Width in mod. of 9mm.	Cat. no.
Auxiliary contacts			
OF		1	26924
OF.S		1	26923
Fault indicating switch			
SD		1	26927
Changeover contact			
OF+SD/OF		1	26929
Undervoltage release			
MN	220 to 240 V AC	2	26960
	48 V AC	2	26961
	48 V AC	2	26962
MN S	220 to 240 V AC	4	26963
0.2 sec delay			
Release for PB pushbutton with opening			
MNx	230 V AC	4	26969
	400 V AC	4	26971
Shunt release			
MX+OF	220 to 415 V AC	2	26946
	110 to 130 V DC		
	48 to 13 V AC	2	26947
	48 V DC		
	24 V AC - DC	2	26948
	12 V AC - DC	2	26949
Voltage increase release			
MSU	230 V AC	4	26979
	400 V AC	4	26980
Release consumption			
Type	Voltage (V)	(W, or VA)	
MX	415 V AC	120	
	220 to 240 V AC	50	
	110 to 130 V AC	200	
	110 to 130 V DC	10	
	48 V AC - DC	22	
	24 V AC - DC	120	
	12 V AC - DC	120	
	MN 220 240 V AC	4.1	
	48 V AC	4.3	
	48 V DC	2.0	
MN S	220 to 240 V AC	4.1	
MNx	230 V AC	50	
	400 V AC	120	
Contact auxiliary breaking capacity			
Voltage (V)		(A)	
415 V AC		3	
\leq 240 V AC		6	
130 V DC		1	
\leq 24 V DC		6	

Schneider Electric New Zealand Ltd

Customer Care Freecall 0800 652 999

www.schneider-electric.co.nz

© Schneider Electric 2009

EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.4

Data Systems and Solutions seismic report (translated version)

15 PAGES

Seismic Qualification Justification
For Breakers C60 and C32

INVERTER MG30

UPDATING BOARD

Issued Date / Written By	Modified Pages	Origin and Designation of the Modification
A – 2006 / 03 / 27		Original issue
B – 2006 / 07 / 04	All	Adding of Breaker C32 for Inverters MG30 5kVA Type FRA-BEV 21200-00. Cancellation of Standard CEI 68-3-3 extract

TABLE OF CONTENTS

1	AIM OF THE DOCUMENT	Page 4
2	REFERENCE DOCUMENT	Page 4
3	ANALYSIS	Pages 5 and 6
3.1	Approach	Page 5
3.2.	Seismic Resistance of the Cabinet	Pages 5 and 6
3.3.	Seismic Resistance of the New Breakers	Pages 6 and 7
3.3.1	Resolution of the acceleration at the level of the inverter's breakers	Pages 7 and 8
3.3.2.	Seismic Qualification Tests already performed	Pages 8 and 9
4	CONCLUSIONS	Page 9

Annex 1 : Extreme Spectrum Respons of the Seismic Testing Procedure for all the Spinline 3 Projects ;

Annex 2 : Extract of the SOPEMEA Report LV 12573 - Axis 0X ;

Annex 3 : Extract of the SOPEMEA Report LV 12573 - Axis 0Z.

1. AIM OF THE DOCUMENT

To prove that the replacement of the breakers F32 with breakers C60 and C32 does not invalidate the seismic qualification of the inverters MG30.

2. REFERENCE DOCUMENT

Ref . N°	Document N°	Designation
1	LV 12573	SOPEMEA Report "Seismic Resistance Tests" on inverter MG-30-CS 5kVA FRA Type
2	LV 12041 / 1	SOPEMEA Report " Seismic Vibration Tests" on Merlin Gerin inverter 5kVA
3	LV 12041 / 2	SOPEMEA Report " Seismic Vibration Tests" on Merlin Gerin inverter 20kVA
4	CEI 68-3-3	Applicable Seismic Test's Methodology to equipment
5	3000430 B	Seismic Testing Procedure for all Project – SPINLINE 3
6	3000439 C	Seismic Test report for all Project – SPINLINE 3

3. ANALYSIS

3.1 Approach

To be sure that the seismic qualification of the inverters is not invalidated, we will demonstrate the following:

- The modification does not challenge seismic qualification of the cabinet,
- The new circuit breakers have a satisfactory seismic resistance response as determined by the original testing of the inverters MG30.

3.2. Seismic Resistance of the Cabinet

The aim is to demonstrate that the installation of the new breaker does not challenge the seismic qualification of the inverters MG30.

➤ Breaker of the Power Supply Board for inverters 5kVA – FRAMATOME Type

Mass	Breaker Type	Element taken into account	Weight
Previous	Breaker F32	Both contacts for remote's display and support	500g
New	Breaker C60N Bipolar	Both contacts for remote's display SD and support	350g
Previous		Breaker F32	450g
New		Breaker C32H-DC Bipolare	300g

➤ Breaker DJ02 or DJ03 for the inverters 5kVA – EDF Type or 20kVA

Mass	Breaker Type	Element taken into account	Weight
Previous		Breaker F32	450g
New		Breaker C60N Bipolare	300g

Consequently, the difference of mass between the original and the new circuit breakers are negligible related to the total mass of the inverter's cabinet MG30:

➤ MG30 5kVA – FRAMATOME Type

- Mass of the Cabinet = 650kg,
- Mass of the Breakers F32 = $2 \times 0,45 + 6 \times 0,5 + 1 \times 0,45 = 4,35$ kg,
- Mass of the Breakers C60 and C32 = $2 \times 0,3 + 6 \times 0,35 + 1 \times 0,3 = 3,00$ kg,
- Δ Mass = 1,35 kg

➤ MG30 5kVA – EDF Type

- Mass of the Cabinet = 550kg,
- Mass of the Breakers F32 = $2 \times 0,45 = 0,9$ kg,
- Mass of the Breakers C60 = $2 \times 0,3 = 0,6$ kg,
- Δ Mass = 0,3 kg

➤ **MG30 20kVA**

- Mass of the Cabinet = 770kg,
- Mass of the Breakers F32 = 2 x 0,45 = 0,9 kg,
- Mass of the Breakers C60 = 2 x 0,3 = 0,6 kg,
- Δ Mass = 0,3 kg

That difference in mass is not able to significantly impact on the resonance frequencies of the inverter.

The replacement of the breakers results in a reduction of the total mass of the inverter. Consequently, this will increase the frequencies of the cabinet. The first resonance's frequency being 9,5 Hz (Case of the inverter 5kVA – FRAMATOME Type), the undergone constraints by the cabinets will be lower.

- Case of inverter 5kVA – FRAMATOME Type

$$Fr_f = \sqrt{\frac{M_i}{M_f}} \times Fr_i = \sqrt{\frac{650}{648,65}} \times 9,5 = 9,5099\text{Hz}$$

- With
- Fr_f = Resonance frequency After Modification
 - Fr_i = Resonance frequency Before Modification
 - M_f = Mass After Modification
 - M_i = Mass Before Modification

The influence of that modification is obviously quite favourable regarding the cabinet behavior.

Consequently, the mechanical behavior and the functionality of the cabinet are not challenged.

3.3. Seismic Resistance of the New Breakers

The references of the used new breakers are the following:

- **HUA 10128** : Bipolar C60N 10A / Curve D for :
- Distribution MG30 5kVA – FRAMATOME Type
- **HUA 12728** : Bipolar C32H-DC 10A / Curve C for :
- Auxiliary Power Supply LN* 110JA MG30 5kVA – FRAMATOME Type
- **1PRE 013097** : Bipolar C60N 2A / Curve C for :
- DJ02 MG30 5kVA, DJ02 and DJ03 MG30 20kVA
- **012485** : Bipolar C60N 32A / Curve D for : DJ03 MG30 5Kva.

According to numerous and earlier seismic qualifications of the equipment, the C60 breaker family has widely been used as to equip for example the RPN equipment of Qinshan (*China*) and CP0 (*1st French Program*).

To demonstrate the acceptable seismic response of the new equipment, we will consider the latest qualification, which means, the seismic qualification of the « SPINLINE 3 product ».

In this case, the circuit breakers which have been used are bipolar C60N 20A / Curve D and bipolar C32H-DC 32A / Curve C type. Afterwards, we will consider that these breakers are representative of the bipolar C60N and C32H-DC breaker's family (Same arc chute and same volume).

3.3.1 Resolution of the acceleration at the level of the inverter's breakers

The SOPEMEA reports Ref. 1, 2 and 3 describe the accelerations taken on different area of the cabinet.

The considered data are the N°1 and 2 which are measure on the top of the cabinet. Therefore, to take into account of the accelerations of the circuit breakers is obviously conservative, regarding that they are breakers are located lower down in the cabinet.

➤ Inverters MG30 5kVA – FRAMATOME Type

Data N°	Axis	Maximum Acceleration (g)	Acceleration of nill period (g)	Curve N°
1	OX	7,5	3,2	14
	OY	7,2	2,8	38
	OZ	2,1	2,1	62
2	OX	7,5	4	16
	OY	7,5	3,9	40
	OZ	1,6	1,6	64

- Test perform with accelerogram

➤ Inverters MG30 5kVA – EDF Type

Data N°	Axis	Maximum Acceleration (g)	Frequency (Hz)	Curve N°
1	OX	6,2 ⁽¹⁾	12 ⁽¹⁾	70
	OY	3,1	11,5	77
	OZ	Not recorded ⁽²⁾	Not recorded ⁽²⁾	
2	OX	6,5	12	71
	OY	6,5	11,5	78
	OZ	Not recorded ⁽²⁾	Not recorded ⁽²⁾	

- (¹) Measurement performed with noise
- (²) Resonance frequency > 30 Hz
- 5 tests performed at different frequencies.

➤ **Inverters MG30 20kVA – EDF Type**

Data N°	Axis	Maximum Acceleration (g)	Frequency (Hz)	Curve N°
1	OX	1,5 ⁽¹⁾	11,5	65
	OY	2,8	12	75
	OZ	Not recorded	Not recorded	
2	OX	4,5 ⁽¹⁾	11,5	67
	OY	5	12	78
	OZ	Not recorded	Not recorded	

- (¹) Measurement performed with noise
- 5 tests performed at different frequencies.

Severity taken into account for all the breakers of the inverter MG30

To still be conservative and to standardize the severities for all the breakers which have been installed on the different inverters MG30, we will consider only the most restrictive data of the 3 in the tables below. Moreover, the highest severity will be kept for the horizontal axis as described here under for the inverter MG30 5kVA – FRAMATOME Type.

Data N°	Axis	Maximum Acceleration (g)	Acceleration of nill period (g)	Curve N°
1	Vertical	2,1	2,1	62
2	Horizontal	7,5	4	16

Refer to Annex 2 and 3

3.3.2. Seismic Qualification Tests already performed

The qualification « SPINLINE 3 product », indicates some information relative to the behavior of the bipolar breakers C60N.

The Annex 1 describes the extreme Spectrum's responses applied to the sub-equipment where was installed in the area of the C60 circuit breaker.

The figure 3 is representing the SDD spectrum (sizing spectrum) on the vertical axis and the figure 4 is representing the SDD on horizontal axis.

These tests applied to the sub-equipment are in accordance with RCC-E 2002 version which means 5 DSD (1/2 sizing seismic spectrum) followed with one SDD (sizing spectrum) on each of the axis. Therefore, they are more restrictive than the seismic tests performed in 1976 and 1977 on the inverters MG30.

We can notice on the curves figure 3 and 4 the following and remarkable data :

Axis	Maximum Acceleration (g)	Acceleration of nill period (g)	Annex 1 Figure N°
Vertical	36	3,6	3
Horizontal	50	5	4

The circuit breakers did not fail functionally before, during or after the seismic tests.


4. CONCLUSIONS

The breakers C60 have been qualified for some severity levels widely greater than the levels that they would be undergone inside the inverters.

Moreover, the testing conditions are definitely more severe.


Furthermore, that study entitles to demonstrate that the replacement of the breakers F32 with breakers C60N and C32H-DC does not challenge the seismic qualification of the inverters MG30.

ANNEX 1 : Utmost Spectrum's responses (Testing Procedure for all Project « SPINLINE 3 »)



SDD 0Z


Figure 3 – Vertical Excitation (Severity target level)




**SDD
OX and OY**

Figure 4 – Horizontal Excitation (Severity target level)

ANNEX 2 : Extract of SOPEMEA Report « LV 12573 – axis 0X »



ANNEX 3 : Extract of SOPEMEA Report « LV 12573 – axis OZ »



Translator's NOTE about SOPEMEA:

SOPEMEA is a French laboratory located in Villacoublay (near Paris) in charge of about 150 official and different tests

SOPEMEA, a company for the Improvement of Aerospace Materials and Equipment, is born in January 1948

In 1965, **CNES** entrusts to **SOPEMEA** the creation, then the development of its space environment tests laboratory located in Brétigny-sur-Orge, which will be transferred to Toulouse in 1972 and will become **INTESPACE**, a common subsidiary both to **CNES** and to **SOPEMEA** in 1984

In 1969, **SOPEMEA** extends and establishes a site in Vélizy-Villacoublay.

In 1987, **SOREAS** sells 51 % of the company capital to **MESSIER-BUGATTI**, a subsidiary of the **SNECMA** group that becomes its principal shareholder.

In 2000, **SOPEMEA** assigns its whole shareholding in **INTESPACE**.

In 2001, **SOPEMEA** joins the **APAVE** group, an expert in commanding the industrial risk of installation controlling and products compliance.

SOPAVIB is created in Vaulx-en-Velin in 1997 on **SOPEMEA** (50 %), **APAVE** (40 %) and **VIBRATEC** (10 %) initiative to offer a better service to its customers of the South-Eastern part of France.

Located in Valenciennes, in the heart of the European pole of rail and car transportation, **SOPAVAL** is inaugurated in 2002 by its shareholders: **SOPEMEA** (50 %) and **APAVE** (50 %).


The earthquake risk is important enough, even in our country, to be taken into account from the design of an industrial development.

The regulation texts that have been applied for many years to nuclear installations are and will be more and more widely spread to all types of industrial and strategic installations.

SOPEMEA qualifies assemblies and sub-assemblies of small or huge dimensions :

Either by the test that consists in reproducing an earthquake with given specifications, in a laboratory, on biaxial vibrations tables

- Or by computation,
- Or while associating both possibilities to validate the models of computations via experimental methods.




Earthquake resistance tests of an electronic rack on a 4000 daN biaxial table

SOPEMEA is the **leading centre** of the Group. With fifty years experience in the tests field and a 125 people team, our laboratory can offer every day all its available services to its customers all over the world : **tests engineering, tests, facility tests maintenance, training** for laboratories personnels, according to of international standards

SOPEMEA itself combines nearly **150 tests installations**.

Discover *SOPEMEA Group tests facility means* unique in Europe.

From qualification to research and development tests, as well as tuning and « halt and hass » tests, **SOPEMEA** and ist Lyons and Valenciennes subsidiaries are present at your side at any moment during the marketing implementation of new products.



EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.5

Data Systems and Solutions seismic report (original version)

11 PAGES



Désignation du document <i>Designation of the document</i>	Justificatif de la qualification sismique des disjoncteurs C60 et C32	
Affaire <input type="checkbox"/> <i>Product</i>	ONDULEURS MG30	
Equipement <input checked="" type="checkbox"/> <i>Equipment</i>		
Sous-ensemble <input type="checkbox"/> <i>Subassembly</i>		
Autres <input type="checkbox"/> <i>Others</i>		
Document contractuel (pour le client) oui <input type="checkbox"/> non <input checked="" type="checkbox"/> Nbre de pages <input type="text" value="10"/> <i>Contractual document (for customer) yes no Nr pages</i>		
Code projet <i>Project code</i>	<input type="text" value="Niv1"/> <input type="text" value="Niv2"/>	
Diffusion interne: <i>Internal dispatching</i>	<input type="text"/>	
Diffusion externe: <i>External dispatching</i>	<input type="text"/>	
Tampon archivage MB		
Version française		
Rédigé par <i>Written by</i>	Vérifié par <i>Checked by</i>	Approuvé par <i>Approved by</i>
Nom: P. OLMOS <i>Name:</i> Visa: <i>Signature:</i> Date: 03/10/06 <i>Date:</i>	Nom: G. JALIER <i>Name:</i> Visa: <i>Signature:</i> Date: 03/10/2006 <i>Date:</i>	Nom: P. VIALA <i>Name:</i> Visa: <i>Signature:</i> Date: <i>Date:</i>
Version étrangère		
Rédigé ou traduit par <i>Written by</i>	Vérifié par <i>Checked by</i>	Approuvé par <i>Approved by</i>
Nom: <i>Name:</i> Visa: <i>Signature:</i> Date: <i>Date:</i>	Nom: <i>Name:</i> Visa: <i>Signature:</i> Date: <i>Date:</i>	Nom: <i>Name:</i> Visa: <i>Signature:</i> Date: <i>Date:</i>



TABLEAU DE MISE A JOUR
Updating board

Indice /date Rédigé par <i>Issue/date</i> <i>Written by</i>	Pages modifiées <i>Modified pages</i>	Origine et désignation de la modification <i>Origin and designation of the modification</i>
A / 27/03/2006 P. OLMOS		Edition originale
B / 04/07/2006 P. OLMOS	Toutes	Ajout du disjoncteur C32 pour l'onduleur MG30 5kVA de type FRA – BEV 21200-00 Suppression de l'extrait de la norme CEI 68-3-3

Identification des moyens de production de ce document

Identification of ways of production of this document

Outils : Microsoft Word 2003 **Fichier :** 3003743B Qualif Sismique C60 C32
(remplac F32) MG30.doc

Tools : **File:**



TABLE DES MATIERES
Table of contents

1. BUT DU DOCUMENT	4
2. DOCUMENTS DE REFERENCE	4
3. ANALYSE	5
3.1. DÉMARCHÉ	5
3.2. TENUE DE L'ARMOIRE	5
3.3. TENUE DES NOUVEAUX DISJONCTEURS	6
3.3.1. Détermination de l'accélération au niveau des disjoncteurs de l'onduleur	6
3.3.2. Essais de qualification sismique déjà réalisés	7
4. CONCLUSIONS	7
ANNEXE 1 – Spectres de Réponses Extrêmes de la PE sismique Toutes affaires Spinline3	8
ANNEXE 2 – Extrait du Rapport Sopéméa LV 12573 - axe 0X	9
ANNEXE 3 - Extrait du Rapport Sopéméa LV 12573 - axe 0Z	10



1. BUT DU DOCUMENT

Montrer que le remplacement des disjoncteurs F32 par des disjoncteurs C60 et C32 ne remet pas en cause la qualification sismique des onduleurs MG30.

2. DOCUMENTS DE REFERENCE

Réf. N°	N° du document	Désignation
1	LV12573	Rapport SOPÉMÉA "Essais de tenue aux séismes sur un onduleur MG-30-CS* Type 5KVA FRA
2	LV12041/1	Rapport SOPÉMÉA "Essais de vibrations de tenue aux séismes sur un onduleur Merlin Gerin 5KVA"
3	LV12041/2	Rapport SOPÉMÉA "Essais de vibrations de tenue aux séismes sur un onduleur Merlin Gerin 20KVA"
4	CEI 68-3-3	Méthodes d'essais sismiques applicables aux matériels
5	3000430 B	Procédure d'essais sismique Toutes affaires - Spinline3
6	3000439 C	Rapport d'essais sismiques Toutes affaires - Spinline3



3. ANALYSE

3.1. Démarche

Pour s'assurer que la qualification sismique des onduleurs MG30 n'est pas remis en cause, nous démontrerons:

- que la modification ne remet pas en cause la bonne tenue de l'armoire
- que les nouveaux constituants ont un comportement satisfaisant au même niveau sismique qu'ils auraient subis lors de l'essai sur les onduleurs MG30.

3.2. Tenue de l'armoire

Il s'agit de démontrer que le chargement du nouveau disjoncteur ne remet pas en cause l'onduleur MG30.

- **Disjoncteurs de la platine de distribution** pour l'onduleur 5kVA de type FRA:
Masse avant, disjoncteur F32, contact de report à distance et son support: 500g.
Masse après, disjoncteur C60N bipolaire, son contact de report à distance SD et son support: 350g.
Masse avant, disjoncteur F32: 450g.
Masse après, disjoncteur C32H-DC bipolaire: 300g.
- **Disjoncteurs DJ02 ou DJ03** pour l'onduleur 5kVA de type EDF ou 20kVA:
Masse avant, disjoncteur F32: 450g.
Masse après, disjoncteur C60N bipolaire: 300g.

Par conséquent, la différence de masse entre les anciens disjoncteurs et les nouveaux sont négligeables vis à vis de la masse totale de l'armoire onduleur MG30:

- MG30 5kVA de type FRA
Masse de l'armoire = 650kg
Masse des disjoncteurs F32 = $2 \times 0,45 + 6 \times 0,5 + 1 \times 0,45 = 4,35\text{kg}$
Masse des disjoncteurs C60 et C32 = $2 \times 0,3 + 6 \times 0,35 + 1 \times 0,3 = 3\text{kg}$
 $\Delta\text{Masse} = 1,35\text{kg}$
- MG30 5kVA de type EDF
Masse de l'armoire = 550kg
Masse des disjoncteurs F32 = $2 \times 0,45 = 0,9\text{kg}$
Masse des disjoncteurs C60 = $2 \times 0,3 = 0,6\text{kg}$
 $\Delta\text{Masse} = 0,3\text{kg}$
- MG30 20kVA
Masse de l'armoire = 770kg
Masse des disjoncteurs F32 = $2 \times 0,45 = 0,9\text{kg}$
Masse des disjoncteurs C60 = $2 \times 0,3 = 0,6\text{kg}$
 $\Delta\text{Masse} = 0,3\text{kg}$

Cette modification de masse n'est pas en mesure de modifier significativement les fréquences de résonance de l'onduleur.

Le remplacement des disjoncteurs se traduit par une diminution de la masse totale de l'onduleur. Cela a pour conséquence de relever les fréquences de résonance de l'armoire. La première fréquence de résonance étant de 9,5 Hz (cas de l'onduleur 5kVA de type FRA), les contraintes subies par l'armoire seront donc plus faibles.

Cas du MG30 5kVA de type FRA $\Rightarrow Fr_f = \sqrt{\frac{M_i}{M_f}} \times Fr_i = \sqrt{\frac{650}{648,65}} \times 9,5 = 9,5099\text{Hz}$

Avec Fr_f = Fréquence de résonance après modification M_f = Masse après modification
 Fr_i = Fréquence de résonance avant modification M_i = Masse avant modification

L'influence de cette modification est donc plutôt favorable sur le comportement de l'armoire.

Par conséquent, la tenue mécanique et fonctionnelle des armoires n'est pas remise en cause.



3.3. Tenue des nouveaux disjoncteurs

Les nouveaux disjoncteurs utilisés ont les références:

- HUA10128: C60N bipolaire 10A courbe D Distribution MG30 5kVA type FRA
- HUA12728: C32H-DC bipolaire 10A courbe C Alim. auxiliaire LN*110JA MG30 5kVA type FRA
- 1PRE013097: C60N bipolaire 2A courbe C DJ02 MG30 5kVA; DJ02 et DJ03 MG30 20kVA
- 0120485: C60N bipolaire 32A courbe D DJ03 MG30 5kVA

Dans le cadre de nombreuses qualifications sismiques antérieures d'équipements, la famille des disjoncteurs C60 a largement été utilisée comme par exemple, les équipements RPN Qinshan et RPN CP0.

Pour cette démonstration de bonne tenue sismique, nous considérerons la dernière qualification en date, c'est à dire celle de la qualification sismique "produit SPINLINE3".

Dans ce cas, les disjoncteurs utilisés sont le C60N bipolaire 20A courbe D et le C32H-DC bipolaire 32A courbe C. Nous considérerons par la suite que ces disjoncteurs sont représentatifs de la famille des disjoncteurs C60N et C32H-DC bipolaire (même chambre de coupure et même encombrement).

3.3.1. Détermination de l'accélération au niveau des disjoncteurs de l'onduleur

Les rapports SOPEMEA Réf. 1, 2 et 3 nous donnent les accélérations relevées en différents points de l'armoire.

Les points considérés sont les points n°1 et 2. Ceux sont les mesures effectuées tout en haut de l'armoire. Prendre ces accélérations est donc conservateur vis à vis des disjoncteurs placés en dessous

MG30.5kVA de type FRA

Point n°	Axe	Accélération maximale (g)	Accélération de Période Nulle (g)	Courbe n°
1	OX	7,5	3,2	14
	OY	7,2	2,8	38
	OZ	2,1	2,1	62
2	OX	7,5	4	16
	OY	7,5	3,9	40
	OZ	1,6	1,6	64

Essais par accélérogramme

MG30 5KVA de type EDF

Point n°	Axe	Accélération maximale (g)	Fréquence (Hz)	Courbe n°
1	OX	6,2	12 ¹	70
	OY	3,1	11,5	77
	OZ	Non relevée ²	Non relevée ²	
2	OX	6,5	12	71
	OY	6,5	11,5	78
	OZ	Non relevée ²	Non relevée ²	

¹ = mesure bruitée

² = Fréquence de résonance > 30Hz

Essais par 5 battements à différentes fréquences



MG30 20kVA de type EDF

Point n°	Axe	Accélération maximale (g)	Fréquence (Hz)	Courbe n°
1	OX	1,5 ¹	11,5	65
	OY	2,8	12	75
	OZ	Non relevée	Non relevée	
2	OX	4,5 ¹	11,5	67
	OY	5	12	78
	OZ	Non relevée	Non relevée	

¹ = mesure bruitée

Essais par 5 battements à différentes fréquences

Sévérité retenue pour l'ensemble des disjoncteurs du MG30

Pour rester encore conservateur et uniformiser les sévérités sur l'ensemble des disjoncteurs présents sur les différents onduleurs MG30, nous considérerons les relevés les plus contraignants des 3 tableaux ci dessus. De même, la sévérité la plus élevée sera conservée pour les axes horizontaux. C'est à dire, les relevés ci dessous de l'onduleur 5kVA de type FRA:

Point n°	Axe	Accélération maximale (g)	Accélération de Période Nulle (g)	Courbe n°
1	Vertical	2,1	2,1	62
2	Horizontal	7,5	4	16

Voir ANNEXE 2 et ANNEXE 3

3.3.2. Essais de qualification sismique déjà réalisés

La qualification produit Spinline3 nous donne des informations quand à la tenue des disjoncteurs C60N bipolaire:

L'ANNEXE 1 nous donne les Spectres de Réponses Extrêmes appliqués au sous ensemble sur lequel était présent le disjoncteur C60. La figure 3 représente le spectre SDD (Spectre De Dimensionnement) sur l'axe vertical et la figure 4 représente le SDD sur les axes horizontaux.

Ces essais appliqués au sous-ensemble répondent aux contraintes du RCCE version 2002, c'est à dire 5 DSD (Demi Séisme de Dimensionnement) suivi d'un SDD (Spectre De Dimensionnement) sur chaque axe. Ils sont donc plus contraignants que les essais sismiques réalisés en 1976 et 1977 sur les onduleurs MG30.

On peut relever sur la courbe figure 3 et 4 les points singuliers suivant:

Axe	Accélération maximale (g)	Accélération de Période Nulle (g)	Annexe 1 Figure n°
Vertical	36	3,6	3
Horizontal	50	5	4

Les disjoncteurs n'ont pas eu de problèmes fonctionnels avant, pendant et après les essais sismiques.

4. CONCLUSIONS


Les disjoncteurs C60 ont été qualifiés pour des niveaux de sévérités largement supérieurs aux niveaux qu'ils auraient subis dans les onduleurs.

De plus, les conditions d'essais sont nettement plus sévères.

Cette étude permet donc bien de montrer que le remplacement des disjoncteurs F32 par des disjoncteurs C60N et C32H-DC ne remet pas en cause la qualification sismique des onduleurs MG30.




ANNEXE 1 – Spectres de Réponses Extrêmes de la PE sismique Toutes affaires Spinline3



SDD OZ

- Figure 3 – Excitation verticale (sévérité niveau objectif)




SDD
OX et OY

- Figure 4 – Excitation horizontale (sévérité niveau objectif)




ANNEXE 2 – Extrait du Rapport Sopéméa LV 12573 - axe 0X





ANNEXE 3 - Extrait du Rapport Sopéméa LV 12573 - axe OZ




EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.6

Input Consideration Checklist for circuit breakers

2 PAGES

EQUIVALENCE	REV
E 018/09E	1

 Eskom Generation Rev 0	EQUIVALENCY CHECK SHEET ELECTRICAL CIRCUIT BREAKERS		EQUIVALENCY NUMBER: E 018/09E
	DESCRIPTION	Applicable	Not Applicable
SYSTEM DATA			
Circuit breaker voltage rating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Current rating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Rated power	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
COMPONENT DATA			
Operational voltage	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Rated current	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Contacts configuration	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Short circuit capacity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Enviromental conditions e.g. temperature	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Derating required??	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
No of poles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
COMPONENT MATERIALS			
INSTALLATION DATA			
Mounting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Dimensions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Terminal connections (cable, busbars)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Mass	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
GENERAL			
Has the obsolescence database been checked for a possible resolution?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Has the SAP database been checked for links to other plant systems?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Compiler: MB Fahrenfort
Name

Reviewer: E. J. KEAR
Name


Signature

Date: 2009-10-08

EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.7

Safety Screening Form S2009/0180

4 PAGES



TITLE

SAFETY SCREENING FORM

ALL CENTRE

FORM REF. NUMBER

REV

TO BE USED IN CONJUNCTION WITH - (ASSOCIATED DOCUMENTS / PROCEDURES)

38F

KFA-047

0

KAA-709

No: S2009/0180

Rev. 1

CONCLUSION

Safety Evaluation Required (in accordance with section 4.0 or 5.0)? YES NO Safety Evaluation Number: E
 NNR approval required (in accordance with Section 6.0 or 7.0)? YES NO

PREPARED BY:

NAME: MB Fahrenfort

SIGNATURE:

DATE: 2009-10-01

(Preparer to be qualified in accordance with KTA-001)

INDEPENDENTLY REVIEWED BY:

NAME: EJ Kerr

SIGNATURE:

DATE: 2009-10-08

(Reviewer to be qualified as an Evaluator if a Safety Evaluation is NOT required)

APPROVED BY:

NAME: R Goldstein

SIGNATURE:

DATE: 2009-10-13

(Approver cannot be the reviewer and does need to be a qualified Screener / Evaluator)

1.0 DESCRIPTION

1.1 This screening is for:

Procedure Temporary Alteration Modification (30% phase) Test Other

Revision/Activity/Condition No.: *Equivalency no. E 018/09E rev 1*Title: *Circuit breaker for LNA/B/C/D 001 DL and LNE 001/002/003 DL*

Brief Description of Activity or Plant Condition:

The circuit breakers MG F32 and MG C32H series are obsolete. The equivalency study evaluates the proposed equivalent circuit breaker MG C60N against the original and the system functional requirements for interchangeability.

2.0 EDITORIAL CHANGES
RE-REVIEWSYES NO

(KAA-709, Appendix 2)

YES NO

(For Re-Reviews Sections 3-5 may be skipped)

2.1 If editorial change is "YES" (in accordance to Appendix 2), provide a short explanation why sections 3-5 can be skipped.

YES NO

2.2 If a screening/evaluation has been compiled previously for this change provide a short explanation why the previous screening remains valid for the additional process, both in terms of impact and applicability. (Reference original screening/evaluation)

3.0 KLA-001 CLASSIFICATION:

3.1 What parameters or SSCs are affected, by this activity/condition? *LNA/B/C/D 001 DL and LNE 001/002/003 DL*3.2 KLA-001 classification of SSCs identified in 3.1 above: *CSR/SR (LNE)*

4.0 IMPACT ON DESIGN / LICENSING BASIS

4.1 Is the activity/condition a change to or does it impact on one of the following:

YES NO

4.1.1 Operating Technical Specifications

4.1.2 Radiation Protection Licencing Requirements

4.1.3 Emergency Operating Procedures/SAMGs

4.1.4 Emergency Plan

4.1.5 Any other document referenced in Appendix 6 (KAA-709)

4.2 Does the proposed activity/condition involve a change to an SSC that affects the design as described in the SAR?

YES NO

TITLE			
SAFETY SCREENING FORM – Continued			
ALL CENTRE	FORM REFERENCE NUMBER	REV	TO BE USED IN CONJUNCTION WITH – (ASSOCIATED DOCUMENTS/PROCEDURES)
38F	KFA-047	0	KAA-709
No: S2009/0180 Rev. 1			
4.3	Does this proposed activity involve a change to a procedure that affects how design base (SAR and DSE) described SSC design functions are performed or controlled?	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>
4.4	Does this proposed activity involve revising or replacing an SAR described evaluation methodology that is used in establishing the design bases or used in the safety analysis?	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>
4.5	Does this proposed activity involve a test or experiment not described in the SAR where a SSC is utilised or controlled in a manner that is outside the reference bounds of the design for that SSC or is inconsistent with analyses or descriptions in the SAR?	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>
<p>Conclusion and supporting arguments: <i>The technical evaluation performed in equivalency study E 018/09E rev 1 proves that the proposed circuit breaker meets the functional requirements and is an acceptable replacement to the original. The design base is not affected by this change.</i></p>			

TITLE **SAFETY SCREENING FORM – Continued**

ALL CENTRE	FORM REFERENCE NUMBER	REV	TO BE USED IN CONJUNCTION WITH – (ASSOCIATED DOCUMENTS/PROCEDURES)
38F	KFA-047	0	KAA-709

No: S2009/0180 Rev. 1

5.0 GENERAL

Will/could the activity/condition:	YES	NO
5.1 adversely affect the ability of the operator to assess, or control, the nuclear safety status of the plant?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5.2 adversely affect the nuclear safety reponse of the plant to normal evolutions, anticipated operational occurrences, or accidents?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5.3 adversely affect the qualification or operational characteristics of installed important to safety components classified?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5.4 increase the potential for the release of radioactive material to the environment, or have an impact on the activity migration model?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5.5 increase the potential for an initiating event (list in Appendix 5)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5.6 introduce a new common mode failure?	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments:

If ANY answer in Section 4.0 or 5.0 is "YES" a safety evaluation is required

6.0 SAR IMPACT

SAR Sections Reviewed: II-11.2.2.2.1

SAR Update Request raised? Yes No No.:

Note: NNR approval is required for SAR updates

7.0 NNR APPROVAL

Does this activity/condition:	YES	NO
7.1 require a change to a NL-1 Licence Condition, LD or subsequent LCRs?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7.2 require a change to a document which needs NNR approval as listed in Appendix 6 ?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
7.3 require approval according to the requirements of LD-1012?	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Use the Licence Impact Form to assist in answering the above. Copies of NL-1, LDs and LCRs can be found on g\\userg\nuclear engineering\design engineering\safeval\

EQUIVALENCE	REV
E 018/09E	1

ATTACHMENT 12.8

IEC 60038 recommended voltages

2 PAGES

2 Rules and statutory regulations

A4

Low-voltage installations are governed by a number of regulatory and advisory texts, which may be classified as follows:

- Statutory regulations (decrees, factory acts, etc.)
- Codes of practice, regulations issued by professional institutions, job specifications
- National and international standards for installations
- National and international standards for products

2.1 Definition of voltage ranges

IEC voltage standards and recommendations

Three-phase four-wire or three-wire systems Nominal voltage (V)		Single-phase three-wire systems Nominal voltage (V)
50 Hz	60 Hz	60 Hz
-	120/208	120/240
-	240	-
230/400 ⁽¹⁾	277/480	-
400/690 ⁽¹⁾	480	-
-	347/600	-
1000	600	-

(1) The nominal voltage of existing 220/380 V and 240/415 V systems shall evolve toward the recommended value of 230/400 V. The transition period should be as short as possible and should not exceed the year 2003. During this period, as a first step, the electricity supply authorities of countries having 220/380 V systems should bring the voltage within the range 230/400 V +6 %, -10 % and those of countries having 240/415 V systems should bring the voltage within the range 230/400 V +10 %, -6 %. At the end of this transition period, the tolerance of 230/400 V ± 10 % should have been achieved; after this the reduction of this range will be considered. All the above considerations apply also to the present 380/660 V value with respect to the recommended value 400/690 V.

Fig. A1 : Standard voltages between 100 V and 1000 V (IEC 60038 Edition 6.2 2002-07)

Series I		Series II	
Highest voltage for equipment (kV)	Nominal system voltage (kV)	Highest voltage for equipment (kV)	Nominal system voltage (kV)
3.6 ⁽¹⁾	3.3 ⁽¹⁾ 3 ⁽¹⁾	4.4 ⁽¹⁾	4.16 ⁽¹⁾
7.2 ⁽¹⁾	6.6 ⁽¹⁾ 6 ⁽¹⁾	-	-
12	11 10	-	-
-	-	13.2 ⁽²⁾	12.47 ⁽²⁾
-	-	13.97 ⁽²⁾	13.2 ⁽²⁾
-	-	14.52 ⁽¹⁾	13.8 ⁽¹⁾
(17.5)	- (15)	-	-
24	22 20	-	-
-	-	26.4 ⁽²⁾	24.94 ⁽²⁾
36 ⁽²⁾	33 ⁽²⁾	-	-
-	-	36.5	34.5
40.5 ⁽³⁾	- 35 ⁽³⁾	-	-

These systems are generally three-wire systems unless otherwise indicated. The values indicated are voltages between phases. The values indicated in parentheses should be considered as non-preferred values. It is recommended that these values should not be used for new systems to be constructed in future.

Note 1: It is recommended that in any one country the ratio between two adjacent nominal voltages should be not less than two.

Note 2: In a normal system of Series I, the highest voltage and the lowest voltage do not differ by more than approximately ± 10 % from the nominal voltage of the system. In a normal system of Series II, the highest voltage does not differ by more than +5 % and the lowest voltage by more than -10 % from the nominal voltage of the system.


(1) These values should not be used for public distribution systems.

(2) These systems are generally four-wire systems.

(3) The unification of these values is under consideration.


Fig. A2 : Standard voltages above 1 kV and not exceeding 35 kV (IEC 60038 Edition 6.2 2002-07)

212	06-12-86	CAB	FCJA	RT	RECORDED AS PER DCR 1053/86
A	20-8-86	T.S.	OMP	RD	ESKON No. ALLOCATED REF DCR 61/86
REV	DATE	DRAWN	CHECKED	APPROVED	MODIFICATION
TITLE					SHEET
0 LZB					16
Dwg No. 31.46 / 1003					BEFORE
					17




212	09.12.96	CAW	FOR A	BT	RECORDED AS PER DCR 1053/96	
A	20.8.96	Y.JL	TO	BD	ESKOM No. ALLOCATED - REF DCR 61/96	
REV	DATE	DRAWN	CHECKED	APPROVED	MODIFICATION	SHEET
TITLE					0 LZB	DWG No. 31.46 / 1003
					MICRO FEB96116	17 BEFORE 18

0 LZB



Z16	21.08.01	PSW	MJA	18-1 P3	MOD 91011 : DDR 2001/01958
Z15	13.09.00	PSW			AS PER DDR 2000/0199
Z12	09.12.96	CAW	FGA	BT	RECADDED AS PER DDR 1053/96
A	15.8.86	Y.W.	TD	BD	ESKOM No. ALLOCATED - REF DCR 61/86
REV	DATE	DRAWN	CHECKED	APPROVED	MODIFICATION
TITLE					SHEET
0 LZC					18
DWG No. 31.46 / 1003					BEFORE
MICRO FEB96117					19



	TITLE TD & RM EHR COVER SLIP	Reference No KFI-RE-002
		Revision: 1 Page: 1
		Associated Procedure: KAA-830

ALLOC CENTRE	DOCUMENT NUMBER	 1464326	REV 0	FOR OFFICE USE ONLY
--------------	-----------------	--------------------	----------	---------------------

TITLE E L E C T R I C A L M A I N T E N A N C E D E F E C T I N V E S T I G A T I O N A N D R E P A I R R E P L A C E D E F E C T I V E 2 2 0 V B R E A K E R S R E P L A C E A L L 1 3 X 1 0 A B R E A K E R S O N O L 2 C 0 0 1 T B	COVER SLIP COMPLETED BY DOCUMENT TYPE SECURITY CLASS RECORD R AUTHOR ORIGINATOR
--	--

TRIGRAMME (STATUS COMMENTS)																								
3 8 - 0 L 2 C 0 0 1 T B 2 8 - 0 L 2 C 3 8 - 0 L 2 C 0 1 2 J A																								
25 trigrammes may be entered																								

REF. DATE (CCYYMMDD) 20160210	KIS / SHELF LOCATION PT 773	NO OF PGS 0010	RETENTION PERIOD YEARS 005
---	---------------------------------------	--------------------------	--------------------------------------

REFERENCE NUMBERS																								
MAINT REF NO. E107834	W/O 713085864 712626796																							
25 work order numbers may be entered																								

DISTRIBUTION / COPIES	FOR OFFICE USE ONLY SCANNED REGISTERED	RECORD FORMAT HARDCOPY (PAPER) DISC RADIOGRAPH TAPE OTHER
-----------------------	--	--

NOTES
Empty space for notes

Order Header

Order 713085864 INVEITGATE AND REPAIR BREAKERS AND INVER
Notification 22971028

- * 2014.11.11 11 45:59 CPS-BATCH CPS-BATCH (CPS-BATCH)
- * Supply to HV control room plugs and unit 2 control room
- * electronic LCO screen lost. Initially found OLZC010JA
- * tripped. After resetting 010JA power was still absent. Line
- * up verified as per KWB-S-0-LZC
- * 2014.11.12 14 53:44 CHANTAL MOLPUS (D97095) Phone 0215505013
- * Operating restored breaker 010JA. EMS verified the load on the 10A breaker to be 4A. Notification kept open for a day to see if any variation in the current, no deviation noted. Due to recurring event, EMS will replace the breaker when breaker spare available as current breaker on plant is fairly old and dont latch first time when closing
- For more information contact Chantal Molpus at 5912

Reported by PHILIP JOHN IRELAND Telno. 0215504917
 Main Work center EM9 EMS UNIT 9
 Maint plan group 004 EMS UNIT 0 2 & 6 Telno.
 Order type M300 Elective Maintenance
 Maint Act Type 135 Normal Maint
 Priority 4 Priority 4

Start date 2015.02.04 End date 2015.02.06

INVEITGATE AND REPAIR BREAKERS AND INVERTER OLZC001DL

Acceptance of work to be performed, and understanding thereof

Supervisor _____

Signature _____

Craig McClusky
2016 -02- 09
Sign

Reference Object

Functional Location 38-OLZC 220 V AC GENERATION AND DISTRIBUTION
 Room L650 Location Unit Nine Electrical Building 15.5M
 ABC Indicator 3 Availability Related

Operations

Operation 0010 (1071826300)REPLACE ALL 13X 10A BREAKERS PM01
 System Cond.
 Work Centre EMO EMS UNIT 0
 Work 12.0 H Duration 6.0 H People 2
 Start Date 2015.02.04 End Date 2015.02.05

Materials

Material Number 0240515 Quantity 15.000 EA
 Material Description BKR,CIRC.MG C60N-10A ,10 A ;230 VAC ;2
 Reservation 0089431945 0001

Field Key KBG0001 KOEBERG USER DATA
 PROCEDURE No. KWM-EM-DEF-001
 JOB TYPE ELECTIVE
 RADIATION CERT. N/A
 PERMIT TO WORK ISOLATION

Additional text

(1071826300)REPLACE ALL 13X 10A BREAKERS ON OLZC001TB BOARD

COMPLETED BY Jean Paul De La Cruz	REVIEWED BY	QUALITY CONTROL	DOUBLE VERIFY
2016-02-03			
			10/02/2016

Feedback

Start Date 10/02/2016 Time End Date 10/02/2016 Time

Time worked 8 Hrs Completed Yes / No Time remaining NONE

Confirmation Text REPLACE ALL 13 10A BREAKERS ON OLZC OULTB BOARD COMPLETED.

Work done by 3958191 Unique No. 10/02/2016 Date

I. Gabriel Name & Signature

Work done by Unique No. 10/02/2016 Date

 Name & Signature

General Feedback

Malfunction Start / / Time : Malfunction End / / Time :

Equipment Dismantling Feedback
Equipment Dismantled? Yes / No
If Yes:

Item Dismantled	Item Installed
Equipment Number: <u> </u>	<u> </u>
Material Number: <u> </u>	<u> </u>
Serial Number: <u> </u>	<u> </u>

Certificate: Work tested and accepted

Responsible person I. Gabriel

Signature

Order Header

Order 712626796 REPLACE DEFECTIVE 220V BREAKER
Notification 22829757
 * 2014.07.14 16:20:28 CHANTAL MOLPUS (D97095) Phone 0215505013
 * REPLACE DEFECTIVE 220V BREAKER.
 * BREAKER DETAILS:MERLIN GERIN, 10A, 2POLE, NO;63120 P1, COMPACT F32.
 * FOR MORE INFORMATION CONTACT CHANTAL MOLPUS AT 5912

Reported by D97095 **Telno**
Main Work center EM9 EMS UNIT 9
Maint plan group 004 EMS UNIT 0 2 & 6 **Telno.**
Order type M300 Elective Maintenance
Maint Act Type 135 Normal Maint
Priority 3 Priority 3

Start date 2016 02.03 **End date** 2016 02.04

Acceptance of work to be performed, and understanding thereof

Craig McClusky
 2016 -02- 08
 Sign

Supervisor _____

Signature _____

Reference Object

Functional Location 38-0LZC012JA CIRCUIT BREAKER SUPL CABLE 16 SSR (EXC)
 CIRCUIT BREAKER - SUPPLY CABLE 16 SSR (EXC) TEMPERATURE
Room L650 **Location** Unit Nine Electrical Building 15.5M
ABC Indicator 3 Availability Related

Operations

Operation 0010 REPLACE DEFECTIVE 220V BREAKER **PM01**
System Cond.
Work Centre EMO EMS UNIT 0
Work 6.0 H **Duration** 3.0 H **People** 2
Start Date 2016 02.03 **End Date** 2016 02 04

Materials

Material Number 0240515 **Quantity** 1 000 EA
Material Description BKR,CIRC:MG C60N-10A ,10 A ;230 VAC ,2
Reservation 0088769382 0001

Field Key KBG0001 KOEBERG USER DATA
PROCEDURE No. KWM-EM-DEF-001
JOB TYPE ELECTIVE
RADIATION CERT. N/A
PERMIT TO WORK ISOLATION

Additional text

REPLACE DEFECTIVE 220V BREAKER

~COMPILED BY~	~REVIEWED BY~	QUALITY CONTROL	DOUBLE VERIFY
Jean Paul De La Cruz			
2016 -02- 03	N/A	N/A	
			2016.02.10

Sign

Feedback

Start Date 10/02/2016 Time End Date 10/02/2016 Time

Time worked 8 Hrs Completed Yes / No Time remaining NONE

Confirmation Text REPLACE DEFECTIVE 220V BREAKERS COMPLETED.

Work done by 4124656 10/02/2016
Unique No. Date

L. Dolo
Name & Signature

Work done by 3958191 10/02/2016
Unique No. Date

I. GABRIELS
Name & Signature

General Feedback


Malfunction Start / / Time : Malfunction End / / Time :

Equipment Dismantling Feedback
Equipment Dismantled? Yes / No
If Yes:

Item Dismantled	Item Installed
<u> </u>	<u> </u>
<u> </u>	<u> </u>
<u> </u>	<u> </u>

Certificate: Work tested and accepted

Responsible person I. GABRIELS

Signature 

HISTORY SUMMARY

NO HISTORY CAPTURE HOURS ONLY

F/O AS FOUND CONDITION OF EQUIPMENT/COMPONENTS

CONDITION 1 COMPONENT DEGRADED
 CONDITION 2 OUT OF TOLERANCE
 CONDITION 3 SATISFACTORY
 CONDITION 4 SUPERIOR
 N/A

EXPLANATION: *Equipment found in a good working condition.*

WORK CONTROL CHECKLIST
(✓ or mark N/A as applicable)

COMPONENT SWAPPED / ASSET CHANGE FORM COMPLETED

C/A CORRECTIVE ACTIONS

REPAIR
 SERVICE
 OVERHAUL
 TEST

FAULT CONDITION: *Certain outgoing feeders ^{breakers} were faulty and working intermittently. A decision was taken to replace all thirteen outgoing feeder breakers as its of the older type breakers.*

REPAIRS: *All thirteen outgoing circuit breakers (2 pole) of OLC switchboard replaced with new equivalent spares.*

DEFECT RAISED TO REPAIR OLD ASSET

M & TE NUMBERS LISTED

TEST RESULTS LISTED

T/R TEST RESULTS

All thirteen outgoing feeder breakers replaced with new equivalent circuit breakers. All the new installed breakers were installed and tested and operated successfully.

PTW CLEARED

POST MAINT REQUAL DONE

JOB SITE CLEANED

H OR W POINTS ADHERED TO

TOOLS REMOVED AND RETURNED

R/C ROOT CAUSE AND CONSEQUENCE OF FAILURE

Suspect component degradation.

SPARES RETURNED

SAFETY TAG REMOVED

CORRECTIVE ACTIONS LISTED - NCR / PN

M & TE USED / RI NUMBERS <i>RI: 53717 KCR 301081 (X)</i>	RUNNING HOURS <i>N/A</i>	STARTS / ACTUATIONS <i>N/A</i>	CROSS REF: NCRs, WOs, MODS, PTWs, ETC <i>9/16-87555 Xref: 712626796</i>
---	-----------------------------	-----------------------------------	--

VERIFICATION OF COMPLETED WORK AND HISTORY

* CRAFTSMAN

NAME: *F. GABRIEL*
 DATE: *2016-02-25*
 SIGN: *[Signature]*

** SUPERVISOR

NAME: *W. SIMPSON*
 DATE: *2016-02-25*
 SIGN: *[Signature]*


QUALITY CONTROL

Eskom
 D. DITCHAM Q34
 2016-03-31
 SIGNATURE: *[Signature]*

I declare that the work has been done in a quality manner, the check off requirements have been met and the history summary is accurate and comprehensive.

I declare that the above history is accurate, work is complete and quality requirements of the job have been met and root cause established

TEST RESULTS



APPENDIX 6 (continued)

5.0 Have all prerequisites been met? YES NO

I. GABRIELS
Responsible Person


Signature

2016-02-10
Date

PLANT REFERENCE NUMBER: 0L2C / 0L2C012JA

AS FOUND CONDITION Certain outgoing feeder breakers working, intermittently and decision was made to replace all 13 circuit breakers (2 pole type)

WORK PERFORMED:
All 13 circuit breakers of the older type replaced with new equivalent type spares

RI No. 53717 PTW. 9/16-87555

COC REQUIRED (Y/N)? N COC No: N/A

EQUIPMENT REQUALIFICATION DETAILS:
All new circuit breakers were tested and operated successfully.


EQUIPMENT USED	M & TE No.	CALIBRATION EXPIRY DATE
<u>Fluke Multimeter</u>	<u>KEM 301081</u>	<u>2016-11-11</u>

APPENDIX 6 (continued)

RECORD OF ALTERATIONS / DISCONNECTIONS / RECONNECTIONS

Terminal Location	Wire Number Identification	Alteration Jumper Disconnect	Signature and Date	Restored to Original State Signature	Date	Verified By	Date
						<i>[Signature]</i>	2016/02/11


COMPONENT LAYOUT




APPENDIX 6 (continued)

TOOL INVENTORY CHECKLIST		
Trigramme: <u>0 LEC 001 TB</u>		
W/O. <u>713085864</u> Date: <u>10/02/2016</u>		
Quantity	Description	Removed from Site (✓)
ONE	SIDE CUTTER	✓
ONE	WIRE STRIPPER (BLUE)	✓
ONE	FLAT MEDIUM SCREWDRIVER	✓
ONE	STAR MEDIUM SCREWDRIVER	✓
ONE	10 mm RING SPANNER	✓
ONE	JUNIOR HACKSAW.	✓
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		
 		

DECLARATION All equipment shown ticked off above has been removed from the plant site

Name C. Nozje Signed: 

Verified: L. Dols Signed: 

APPENDIX 6 (continued)

POINT	QC H-OR-W	VERIFIER			DATE
		NAME	SIGNATURE	INSPECTION No	
Trace of polarity unit short circuit or overload by disconnection					
8.9.9					
8 9 14					
Cable defects and new cable installation					
8.12 15					
8 12.2.6					
Wiring or re-wiring of faulty supply or control panels					
8 14 8					
Replacement of faulty cabinet components					
8 15 6		C. McCLUSKEY			2016/02/11
Trace heating removal and replacement					
8.19 2.3					
Soldering on non-1E components					
8.22.14					
DISTRIBUTION BOARD WORK					
8.23.6					
CABINET, CUBICLE, BOX OR ENCLOSURE REPLACEMENT					
8.26.11					
SSC affected by water damage (Flooding)					
8.27 11 (e)					
SSC affected by moisture, or dirt build-up					
8 27 12 (d)					