



Non Visible PH30 Fire alarm will be strapped up in ceiling void.

Visible PH30 Fire alarm will be installed in 25mm PVC conduit. Conduits to manual call points will be surface mounted.

server room floor void

[illegible]

0.95/821-02-01

Q1 - 0000	Q2 - 01	Q3 - 02
	02	01